



Distribution Annual Planning Report

2025/26 to 2029/30

December 2025



Acknowledgement of Country

Acknowledgement of Country

SA Power Networks acknowledges the multiple Traditional Owners of the lands that host the South Australian electricity network and their connections to land, sea, and community. We would also like to pay our respects to all First Nations peoples past and present, acknowledging their deep connection to Country, Culture and Community.

Connection With Country, 2025 by Kelly Taylor & T'Keyah Ware



Contents

Introduction.....	4
Attachments to Distribution Annual Planning Report	4
Purpose of Distribution Annual Planning Report	5
Guide to this Document	5
1. About SA Power Networks.....	7
1.1. Our Statutory and Regulatory Framework	7
1.2. Our electricity distribution network.....	8
1.3. Our network operating environment	9
1.4. Our Network Distribution Assets.....	10
2. Factors impacting our Network and Future Challenges	13
2.1. Consumer Energy Resources	13
2.2. Asset Age and Condition.....	15
2.3. Climate Change Risks.....	16
2.4. Cyber threats to our network.....	18
3. Changes since the previous Distribution Annual Planning Report	19
3.1. Regulatory Investment Test for Distribution	19
3.2. Planning Criteria Review.....	19
4. Forecasts for the forward planning period.....	20
4.1. Demand and Capacity Augmentation Forecasts	20
4.2. Network asset retirements that result in a system limitation	20
4.3. System limitations resulting from asset de-ratings	26
4.4. System limitations for sub-transmission lines and zone substations.....	27
4.5. Overloads and System Limitations for Primary Feeders	41
4.6. Primary distribution feeders experiencing a system limitation from embedded generation	43
4.7. System limitations with the potential for a regulated Stand Alone Power System	43
5. Network Investment.....	44
5.1. Regulatory Investment Test for Distribution projects.....	44
5.2. Committed urgent and unforeseen investments	49
5.3. Interactions between frequency control, protection, and control systems	49
6. Demand Management and Non-Network Opportunities.....	50
6.1. Demand management non-network options.....	50
6.2. Key issues arising from applications to connect embedded generation.....	51
6.3. Actions taken to promote non-network proposals	51
6.4. Future plans for demand management and embedded generation.....	52
6.5. Consumer Energy Resources Enablement Program	53
6.6. Demand management connection enquiries and applications to connect	55
6.7. Micro embedded generators and non-registered embedded generators connection enquiries and applications to connect	55

6.8.	Activities in relation to Regulated Stand Alone Power Systems	56
7.	Asset Management.....	57
7.1.	Asset Management Approach	57
7.2.	Asset management strategies	58
7.3.	Asset life-cycle strategies	60
7.4.	Planned Strategic Improvements	61
7.5.	Distribution losses	63
7.6.	Asset management issues that may impact system limitations.....	63
7.7.	Asset management further information	64
8.	Network Performance	65
8.1.	Reliability performance	65
8.2.	Quality of supply performance.....	70
8.3.	Service Target Performance Incentive Scheme information.....	79
9.	Information and Communications Technology Systems Investments.....	82
9.1.	2024/25 Investment focus.....	82
9.2.	2026 to 2030 Investment Focus	85
10.	Planning	87
10.1.	Joint planning undertaken with ElectraNet.....	87
10.2.	Joint planning undertaken with other Distribution Network Service Providers	88
10.3.	Regional development plans	88
	Glossary.....	90
	Appendix A – SA Power Networks Contacts	93
	Appendix B – Compliance Statement	94
	Appendix C – Forecasting Methodology	101
	Appendix D – Regional Overviews	109
	Eastern Suburbs Regional Overview	109
	Western Suburbs Regional Overview.....	111
	Northern Suburbs Regional Overview.....	113
	Southern Suburbs Regional Overview.....	115
	Adelaide Central Region Overview.....	117
	Barossa Regional Overview	118
	Eastern Hills Regional Overview.....	120
	Eyre Peninsula Regional Overview	122
	Fleurieu Peninsula Regional Overview	124
	Mid North and Yorke Peninsula Regional Overview	126
	Murraylands Regional Overview	129
	Riverland Regional Overview	131
	South East Regional Overview.....	133
	Upper North Regional Overview	135

Introduction

SA Power Networks is pleased to present the latest edition of the Distribution Annual Planning Report (**DAPR**) for the period 2025/26 to 2029/30. As South Australia's primary electricity distributor, we play a vital role in the state's energy sector, with key responsibilities including the planning, construction, operation, and maintenance of the distribution network. The DAPR is an integral part of our annual obligations, providing stakeholders with insights into our future strategies and the distribution network's ability to meet the evolving needs of our customers.

On 30 April 2025, the Australian Energy Regulator (**AER**) released its final decision on our electricity distribution determination for the 2025–30 regulatory control period (**RCP**). For further details on our Revised Proposal, please refer to the [AER's Determination for SA Power Networks](#).

Since the publication of the 2024 DAPR, SA Power Networks has adopted a hybrid planning criteria approach, as the basis of our Regulatory Proposal to the AER (and incorporating AER expectations via the Determination process). Under this framework, network investment to address N-1 constraints may be deferred until projects are deemed economically viable. We are currently reviewing this new planning criteria, which may result in adjustments to project timing and inclusion in future reports.

In October 2025 we initiated a Regulatory Investment Test for Distribution (**RIT-D**) for a project at our Hindley Street substation. This substation is one of four critical zone substations supplying the Adelaide Central Business District (**CBD**) and forms part of the meshed 66kV metropolitan east network. The age and condition of the existing switchgear present significant reliability and safety risks to both SA Power Networks personnel and the public. To mitigate these risks, we are planning to replace the 66kV switchyard at the Hindley Street substation. The Options Screening Report (**OSR**) for this project has been published, and the Assessment Reports are scheduled for release in 2026. For further information, please refer to Section 5.

The Hindley Street project, along with other replacement and capacity expenditure initiatives, addresses risks associated with asset condition and supports the significant forecasted electrification and load increases as South Australia transitions to a more sustainable energy future.

Attachments to Distribution Annual Planning Report

The following attachments form part of our DAPR and are available via the relevant links on our website.

[Network Visualisation Portal](#)

This portal complements the DAPR by directing users to useful sources of network data, such as our load forecasts, and provides a visual indication of network capacity for importing and exporting to the distribution network.

The Network Visualisation Portal is accessible with a simple registration and is available to all customers.

[System Limitation Templates](#)

Excel file listing augmentation works and asset replacements projects where the unit cost of the asset exceeds \$200,000 for each year of the 2026-30 period.

[Projects with Changed Dates](#)

Key projects' timings for the 2026-30 period.

Purpose of Distribution Annual Planning Report

This DAPR has been prepared by SA Power Networks to comply with the National Electricity Rules (**NER**) clause 5.13.2. This report is published annually on our website in accordance with clause 5.13.2(a)(2) and provides the information specified in Schedule 5.8.

The DAPR is intended to inform regulators, market participants in the National Electricity Market (**NEM**), and other stakeholders about existing and forecast system limitations on our distribution network together with details related to our asset replacement programs and network performance within the forward planning period from 2025/26 to 2029/30.

Guide to this Document

The DAPR is organised into the following sections.

About SA Power Networks

Provides an overview of our business structure and the frameworks we are required to work within, as well as a description of our distribution network and assets.

Factors impacting our Network and Future Challenges

SA Power Networks must act to respond to the various factors that influence our network and the future challenges we are facing, including those challenges relating to climate change, cyber security threats, the transition to Consumer Energy Resources (**CER**), and rapid changes in network technology.

Changes since the previous Distribution Annual Planning Report

Details the changes both to SA Power Networks projects and the NER since the DAPR was last published, to inform external stakeholders of changes impacting the network.

Forecasts for the forward planning period

Details the network constraints resulting from forecast demand growth, asset retirements and asset de-ratings. Includes the system constraints at zone substations and primary feeders, and details consideration for possible regulated Stand-Alone Power System (**SAPS**) solutions. The forecasting methodology used to identify constraints is detailed in Appendix C.

Networks Investment

Provides information on the prudent and efficient network investment we are planning in response to the forecast network constraints.

Demand Management and Non-Network Opportunities

Describes how market participants can provide feedback and alternative non-network demand management solutions to address the network limitations referred to in Section 4. It also, provides information on the different demand management solutions SA Power Networks currently has in progress and those under consideration for future needs.

Asset Management

SA Power Networks' asset management approach is discussed together with our asset class and life cycle strategies.

Network Performance

Provides a review of the network reliability and quality of supply performance.

Information and Communications Technology Systems Investments

Details the information and communications technology system projects related to management of network assets in the forward planning period.

Planning

Details the joint planning currently undertaken with ElectraNet, the principal Transmission Network Service Provider in South Australia. Regional development plans are detailed in Appendix D.

Glossary and Appendices

A glossary and appendices have been included for the relevant contact people, compliance checklist, forecasting methodology and detailed regional network maps.


1. About SA Power Networks

SA Power Networks has always valued its key role in ensuring the South Australian electricity distribution network supports the needs and development of South Australia and its communities. SA Power Networks has proudly served South Australians since 1946, initially as part of the Electricity Trust of South Australia, and then as a stand-alone distribution business, established in 1999, when the electricity supply industry was transformed by a new regulatory framework.

SA Power Networks is the registered Distribution Network Service Provider (**DN**SP) in South Australia, our primary responsibility is planning, building, operating and maintaining the South Australian electricity distribution network — an essential community asset and core component of the State’s energy infrastructure. SA Power Networks does this in a safe, reliable, efficient and prudent manner.

SA Power Networks is 51% owned by CK Infrastructure Holdings Limited (**CKI**) and Power Assets Holdings, which form part of the Cheung Kong Group of companies. The other 49% is owned by the consortium PIKA HoldCo.

Figure 1. Our Role in the Community



1.1. Our Statutory and Regulatory Framework

SA Power Networks is regulated by multiple statutory and legislative requirements across areas of energy, occupational health and safety, environmental, industrial, competition, consumer protection and national security laws.

Electricity regulation of the NEM is primarily through the NER, enabled by the National Electricity Act and the National Electricity Law (**NEL**) (a schedule to the National Electricity Act).

The NEL established the key regulatory bodies of the NEM – the Australian Energy Market Commission (**AEMC**) who set the NER, the AER who enforces the NER and the Australian Energy Market Operator (**AEMO**) who operates the energy market. The NEL also sets out the National Electricity Objectives (**NEO**), which promote efficient investment in, and efficient operation and use of, electricity services for the long-term interests of consumers of electricity with respect to:

- price, quality, safety, reliability and security of supply of electricity;
- the achievement of targets set by a participating jurisdiction –
 - for reducing the Australia’s greenhouse gas emissions; or
 - that are likely to contribution to reducing Australia’s greenhouse gas emissions.

SA Power Networks aims to meet these objectives through investments that promote:

- reliability and safety,
- choice and empowerment for customers,
- support our state’s nation leading energy transition, and
- affordability and equity.

Our planned investments are assessed by the AER as part of their economic regulatory role through the revenue proposal process.

We must also comply with the conditions of the Electricity Distribution License, Electricity Distribution Code (**EDC**) and Electricity Transmission License (**ETC**) which are provided by the State-based regulator, the Essential Services Commission of South Australia (**ESCOSA**), who also retain responsibility for setting service levels. Whilst the Office of Technical Regulator (**OTR**) is responsible for setting and overseeing the safety and technical regulation of the energy industry in South Australia.

1.2. Our electricity distribution network

The electricity distribution network in South Australia is vast, covering more than 178,000km² along a coastline of over 5,000km. We supply electricity to around 945,000 customers ranging from isolated farms in rural areas to industry precincts, regional and metropolitan residential homes, businesses, and city centres.

South Australia is very sparsely populated except for the coastal area with approximately 70% of customers residing in major metropolitan areas but only serviced by 30% of the network infrastructure in terms of circuit length. This results in the remaining 30% of customers being serviced by 70% of the network infrastructure in terms of circuit length. Therefore, the average customer density per kilometre of distribution line in South Australia is the lowest amongst the DNSPs in the NEM.

1.2.1. Network configuration

Our distribution network is predominantly a three-phase system, with some single-phase components used mostly in rural and remote areas. The sub-transmission

network supplies and connects zone substations, operating at 66kV and 33kV. In rural and remote areas, the single-phase system predominantly operates at 19kV. Thirty percent of our network is comprised of these long ‘single wire earth return’ (SWER) lines. In higher density rural and urban locations, the three-phase distribution feeder system most commonly operates at 11kV, however some 7.6kV distribution feeders still exist. This 7.6kV voltage is a legacy voltage level, being phased out of the network. The standard low voltage customer supply is 230V at 50Hz.

1.3. Our network operating environment

The network is centred around Adelaide and supplies electricity to the south-east coastal region of South Australia and north towards inland South Australia as shown in Figure 2 which also demonstrates extent of our overhead network in South Australia.

Adelaide and much of South Australia has a dry climate featuring greater extremes of summer temperature than most other Australian capitals. Extended periods of heatwave conditions can occur in summer. During these heatwave periods, summer daytime temperatures can exceed 40°C for several days in a row and overnight minimums can remain above 30°C for some of those days. South Australia, as a result has one of the peakiest electricity demands in the world driven by the extraordinary demand for cooling during our hot summers.

Figure 2. Map of the Network



1.4. Our Network Distribution Assets

Our network extends for over 90,000km, and includes approximately 400 zone substations, 77,500 street transformers, more than 620,000 Stobie poles and 200,000km of overhead conductors and underground cables. Our assets also include switches, meters, and many ancillary systems as well as fleet and depot facilities spread across the State. The total power system capacity of the network under normal operating conditions with all major plant in service is considered the system being in N condition.

1.4.1. Sub-transmission network

The SA Power Networks sub-transmission network includes transmission connection point substations, sub-transmission lines, zone substations and associated protection systems to ensure the safety and operability of the network.

Transmission connection point substations

SA Power Networks' sub-transmission system is supplied by 47 transmission connection point substations. While there are some exceptions, in most cases these connection point substations are jointly managed by ElectraNet and SA Power Networks and they typically operate at either 275/66kV, 132/66kV or 132/33kV.

Transmission connection points are categorised according to the different levels of reliability and security of supply, specified by ESCOSA within the ETC.

Metropolitan 66kV sub-transmission lines

SA Power Networks' metropolitan 66kV sub-transmission network consists of five 66kV meshed systems supplied from the associated connection point substations, which in turn supply SA Power Networks' metropolitan zone substations. Each of these meshed systems contains multiple connection point substations. The fifth region, the Adelaide Central Region (**ACR**) was most recently created by ESCOSA within the ETC to define the area containing the larger Adelaide Central Business District (**CBD**). The ACR is independently planned even though it is meshed within the larger Metro East region.

The supply capacity of the metropolitan meshed 66kV networks is dependent on the rating of the individual lines and circuit breakers within the network. The network planning criteria for these systems stipulate that no load will be lost for a single 66kV line outage or a single ElectraNet transformer outage (N-1 condition) under 10% Probability of Exceedance (10 **PoE**) conditions. The ETC refers to these connection points as 'category 4' and 'category 5' (for the ACR only) and requires 100% N-1 transmission line and connection point transformer capacity to be continuously available by the transmission network service provider (**TNSP**).

Consequently, SA Power Networks' metropolitan meshed sub-transmission lines are planned such that their emergency rating exceeds the load through the line under contingent conditions at a 10 PoE level of demand. These lines are also planned such that their normal rating exceeds the 10 PoE load under normal conditions (ie all equipment in-service).

The metropolitan sub-transmission network consists primarily of overhead power lines, except for the CBD network which is predominantly supplied by underground cables. In total, around 8% of SA Power Networks' metropolitan sub-transmission system is underground.

Country 66kV and 33kV sub-transmission lines

SA Power Networks' country 66kV and 33kV sub-transmission lines are predominantly radial systems, designed to carry normal loads under 10 PoE conditions. They are generally not designed to N-1 standards as most of these lines are radial in nature and predominantly consist of overhead construction, with a repair time of typically 12 to 24 hours.

Country radial sub-transmission lines are considered for de-radialisation where the load exceeds 30 MVA and / or where the performance of a RIT-D indicates a positive net market benefit.

Meshed 66kV and 33kV sub-transmission lines, which do exist within country regions, are planned to a N-1 standard as per the metropolitan 66kV sub-transmission network.

Zone substations

SA Power Networks' distribution network is supplied by 396 zone substations.

Zone substations are supplied by sub-transmission lines. While there are some exceptions in rural areas, metropolitan zone substations are typically supplied by two (sometimes more) sub-transmission lines that are connected to the substation bus via a series of circuit breakers and disconnectors. Under the NER definitions, zone substations are classified as sub-transmission assets.

SA Power Networks usually receives supply from the ElectraNet transmission connection point at a voltage level that is approximately 100% of the nominal voltage. This voltage then falls as power is distributed along SA Power Networks' 66kV and 33kV sub-transmission lines to its zone substations. The majority of zone substation transformers have on-load tap changers (**OLTC**) that have the ability to raise or lower voltage levels in response to demand changes to maintain nominal voltage. Alternatively, 11kV voltage regulators may be also used to regulate the output voltage where the transformers are not equipped with OLTCs.

SA Power Networks' zone substations are designed to supply the forecast 10 PoE load based on a normal cyclic rating, and 50 PoE load following the worst single substation contingency condition based on the zone substation's emergency cyclic rating.

Sub-transmission protection

SA Power Networks uses best endeavours to coordinate the protection systems across the network to protect our assets, employees and the general public against all credible faults. Protection devices must be set such that network security is maintained or improved and fault clearing times are selected with due consideration to supply security and safety. The integrity of these settings also relies on customers / generators informing SA Power Networks where they wish to alter previously agreed settings.

Sub-transmission protection settings are selected with consideration to future network capacity requirements and fault levels applicable for the normal operation of the network. Generally, SA Power Networks' protection philosophy is to protect the distribution network from faults, not network overloads.

1.4.2. Distribution network

The distribution network typically operates at 19kV single phase in rural and remote locations and at 11kV three phase in higher customer density rural and urban locations. The standard low voltage customer supply voltage is 230 Volts single phase or 400 Volts three phase at 50Hz.

The distribution network consists of overhead and underground assets. The overhead distribution assets are supported by approximately 625,000 poles. These poles are largely constructed in house by SA Power Networks from steel and concrete and are known as Stobie poles.

11kV and 7.6kV feeders

SA Power Networks' 11kV and 7.6kV feeders are largely three-phase radial feeders that provide supply to distribution substations, which transform the voltage down, to either 400V three-phase or 230V single-phase. Feeder capacity may be limited by the zone substation's 11kV or 7.6kV circuit breaker or recloser rating, the feeder's underground cable exit rating or the overhead conductor rating comprising the feeder's backbone.

19kV SWER systems

SA Power Networks' 19kV SWER systems consist of a single-phase conductor that supplies single-phase power to distribution substations. SWER systems typically operating at 19kV have traditionally been used to supply small amounts of load over long distances, such as to supply farms in remote areas. The largest SWER isolating transformer used by SA Power Networks has a capacity of 200kVA.

Distribution substations

Distribution substations convert the voltage from High Voltage (**HV**) to Low Voltage (**LV**) and may be connected to SA Power Networks' network at 33kV, 19kV, 11kV or 7.6kV. The secondary voltage of the distribution substation may (nominally) be either 400V (three-phase), 460V (single phase) or 230V (single-phase) and can supply either a single customer or a LV distribution system from which multiple customers may be connected.

Low voltage network

The LV distribution systems operated by SA Power Networks are either radial three-phase 400V (three-phase) or 460/230V (single-phase) systems used to supply multiple customers from a single distribution substation.

1.4.3. Asset summary

A summary of our assets can be found in the AER's Regulatory Information Notice for SA Power Networks, available on the [AER website via this link](#).

2. Factors impacting our Network and Future Challenges


This section provides details of SA Power Networks’ operating environment and descriptions of factors that are having a material impact on our network as per Schedules 5.8(a)(2), 5.8(b)(5) of the NER and the future challenges we are facing in operating our networks.

2.1. Consumer Energy Resources

Australia’s transition towards a net zero emission economy by 2050 is a key factor influencing consumption and demand forecasts.

Customers are moving more of their energy needs to electricity through the increased use of electric vehicles and the transition away from gas for hot water, heating and cooking. This energy transition can be seen in the below forecast from AEMO which predicts an increase in electricity consumption. However, it is predicted this increase in consumption will be largely offset by the increase of CER such as rooftop solar Photo Voltaic (PV) and household batteries.

Figure 3. Forecast South Australia annual electricity consumption (TWh), Source: AEMO, ESOO 2025



South Australia has high levels of CER in the NEM with around 53% of residential customers having solar PV installed. The strong growth in solar PV installations is expected to continue, and beyond that, other new CERs such as battery storage and Electric Vehicles (EV) will increase. CER is having a material impact on the network which was not designed for complex two-way flows of energy.

We’re transitioning away from our standard 5kW per phase export option for residential customers to flexible exports, allowing customers to export up to 10kW per phase most of the time.

During periods of high solar generation, particularly in spring and summer, when there is low underlying demand, rooftop solar can generate >100% of South Australia’s demand. At a system level, this can pose challenges to overall stability, particularly during transmission outages, like the loss of the Heywood interconnector. At the local level, high reverse flows can encroach on voltage and thermal limits and lesson the effectiveness of critical safety nets like our under-frequency load shedding scheme.

2.1.1. Network hosting capacity

The uptake for rooftop and grid scale solar can encroach on thermal and voltage capacity limits. The first limit to bind is generally voltage, which can result in localised power quality issues. Detailed modelling of our low voltage network suggests that only 1-2kW of exports can be supported per customer before limits start to be exceeded. These issues are increasingly occurring at higher levels of the network as well, with constraints appearing across the high-voltage and sub-transmission networks.

We've developed several strategies that has doubled the amount of solar that can be hosted in the network by 2025 and beyond, compared to our 2020 base. This includes additional monitoring at zone substations, distribution transformers and from smart meters; time of use tariffs that incentivise customers to shift their loads to the middle of that to soak up excess solar; flexible exports to communicate real-time capacity limits to customers' solar inverters; and standard Volt-VAR and Volt-Watt inverter settings.

Achievement of net zero targets is likely to result in increased electricity consumption, as customers electrify their appliances to make the most of renewable energy. Electrification could result in the distribution network supplying up to 60% of South Australia's energy mix, up from 20% today. If managed poorly, significant network investment will be required in response to increasing peak demand. Our Flexible Connections program, enabled by behind the meter interoperability, seeks to encourage customers to shift loads to minimise overall impacts to the network, resulting in the lowest overall cost to all consumers.

2.1.2. Power system security

Rooftop solar is the largest source of generation in South Australia and at times can power the entire state, yet the vast majority has no monitoring or control capability, presenting operational challenges for SA Power Networks, ElectraNet and AEMO. During rare periods of elevated risk system security, for example an outage of Heywood interconnector to Victoria, solar must be curtailed to maintain minimum demand thresholds to avoid the system reaching an insecure state following a credible contingency.

Commencing 2020, in consultation with AEMO, SA Government and the solar industry, a series of initiatives and regulations were launched to ensure South Australia could continue to operate a secure system with very high levels of rooftop solar, including:

1. May 2020: Enhanced Voltage Management including emergency voltage raise as a last resort capability to curtail legacy solar systems.
2. October 2020: Emergency backstop requirements for exporting generators.
3. December 2021: Dynamic arming of our under-frequency load shedding scheme (**UFLS**) to ensure reverse flowing feeders do not exacerbate frequency decline.
4. July 2023: Dynamic Exports requirements for exporting solar systems, enabling the role out of Flexible Exports as a standard option for residential customers.

Maintaining high levels of compliance is a key to supporting system security. In addition to the new standards listed above, systems must be commissioned with AS4777.2:2020 region A settings. These settings ensure solar can ride-through voltage disturbances and do not exacerbate contingency events. SA Power Networks launched an automated compliance program in May 2023 to manage risks to system security.

2.1.3. Transmission voltage levels


It has also been identified that the flow of capacitive reactive power from SA Power Networks is contributing to the occurrence of high voltage levels on SA’s transmission system, especially at times of low state demand. If this trend continues, and there is a critical contingency event (such an outage on the Heywood interconnector), during a low demand period widespread over-voltages on the SA electricity system could occur. SA Power Networks are working with ElectraNet and are currently undertaking a RIT-D to address connection point power factor issues, refer to Section 5.1.2 for further information.

2.2. Asset Age and Condition

SA Power Networks has a high focus on asset management and employs good electricity industry asset management practices. During the forward planning period, we plan to continue working towards the alignment of our asset management practices with the latest asset management industry standard, ISO 55001.

SA Power Networks’ overhead power line network is predominantly situated along the coast, which results in high exposure to a saline environment. This continues to shape how we manage our assets with the asset’s corrosion zone profile identified within our Asset Management Database. Noting corrosion zones extend further inland due to the transfer of airborne salts by the atmosphere. The different corrosion zones are provided in Figure 4.

Figure 4. Atmospheric corrosion zones map in South Australia



We also have one of the oldest distribution networks in the NEM, with a large proportion of our network installed between the 1950s and 1970s. However, we are only in the early stages of replacing many of these assets. Consequently, replacement levels have been increasing recently to offset poor condition due to age and to manage overall network risks.


2.3. Climate Change Risks

The Bureau of Meteorology (**BOM**) has determined Australia’s climate is experiencing the effects of climate change with the average temperature in Australia increasing by 1.5°C since records began in 1910. This is impacting our network through increasing the risk and intensity of bushfires and severe weather events.

2.3.1. Bushfires

Since the 1950s there has been an increase in extreme fire weather and a longer fire season for South Australia evident in the figure below. It is expected the number of dangerous fire weather days, and a longer fire season will continue to increase because of climate change. This is increasing risks to our distribution network which traverses bushfire risk areas where an electrical fault could result in a fire ignition.

Figure 5. Change in the number of dangerous fire weather days since 1950 to 2022, Source: BoM, State of the Climate 2022




The bush fire risk areas in South Australia are:

- High Bush Fire Risk Area - includes the Adelaide Hills, Fleurieu Peninsula, Clare, Lower South East, parts of Kangaroo Island, parts of the Eyre Peninsula and Wirrabara Forest in the Mid North.
- Medium Bush Fire Risk Area - reflects fringe bushland areas across the state.
- Non Bush Fire Risk Areas consists of the metropolitan area, and North West and East Pastoral districts.

We are actively managing the increasing risks faced by bushfires through our bushfire mitigation program which addresses the network infrastructure risks in High Bush Fire Areas.

Figure 6. Bushfire risk areas in South Australia



2.3.2. Severe weather events

The BOM has also predicted severe weather events (**SWE**) will increase as a result of climate change. We have also observed this from our long-term patterns of historical weather-driven reliability outcomes. Currently, SWEs are the major cause of prolonged interruptions to SA Power Networks.

Lightning and high winds cause the most damage, with lightning strikes directly damaging network equipment, whilst high winds can blow limbs or whole trees onto power lines. Power interruptions as a result, can be extended, especially for customers in remote areas where the network is sparser and radial lines are longer.

We are addressing the risk of severe weather events through a range of programs including:

- Targeted capex spend to improve reliability in communities with the worst outcomes; and
- Strengthening the network against increased severe weather including heatwaves through various capex programs.

Further to the risk of bushfires and severe weather events, during the summer of 2024/25 in South Australia, rainfall reached its lowest levels on record. The lack of rain led to an unprecedented build-up of pollution on our powerline insulators, which caused multiple outages across our network.

2.4. Cyber threats to our network

Recent cyber events affecting large corporations have demonstrated the growing importance of cyber security. We have an obligation under the Commonwealth Security of Critical Infrastructure Act 2018 as an operator of critical infrastructure to maintain the cyber security and resilience of the network. We are taking active steps to ensure our network and Information Communication Technology systems are protected in accordance with industry best practices and compliant under the Commonwealth Security of Critical Infrastructure Act 2018.

3. Changes since the previous Distribution Annual Planning Report

Schedule 5.8(a)(5) of the NER requires SA Power Networks to provide analysis and explanation of any aspects of its forecasts and information provided in this DAPR that have changed significantly from previous forecasts and information provided in the preceding year.

3.1. Regulatory Investment Test for Distribution

One RIT-D has been initiated by SA Power Networks since the publication of the 2024 DAPR:

- Hindley Street 66kV Replacement Ensuring Reliable Supply for the Adelaide CBD.

Details about all RIT-Ds currently in progress, as well as projects that SA Power Networks is forecasting as potentially requiring a RIT-D in the future, can be found in Section 5.

3.2. Planning Criteria Review

For the 2025-30 regulatory control period, SA Power Networks adopted a hybrid planning criteria. N constraints have deterministic planning criteria applied, and N-1 constraints have probabilistic planning criteria applied. While this change does not currently impact N constraints, network investment to address N-1 constraints may be deferred until the project is determined economically viable, that is, when the available VCR benefits outweigh the equivalent annual cost of the project. Where this has resulted in the deferral of projects beyond the reporting period, these projects have not been reported in this document.

SA Power Networks is in the process of reviewing and embedding this new planning criteria, and therefore there may be further changes to project timing and inclusion in future years.

4. Forecasts for the forward planning period

4.1. Demand and Capacity Augmentation Forecasts

In accordance with Schedule 5.8(b)(2) and (2A) of the NER, we provide forecasts for the forward planning period. These forecasts comprehensively cover load predictions and the expected utilisation of distribution services by embedded generation units at transmission connection points, sub-transmission lines, and zone substations. The relevant details, where applicable, are made accessible through our [Network Visualisation Portal](#).

A detailed account of the forecasting methodology employed, the sources of input information utilised and the assumptions applied in generating the forecasts are presented in Appendix C – Forecasting Methodology.

4.1.1. Load Forecasts

The maximum demand forecasts provided are designed to offer our customers information for evaluating network conditions during periods of peak demand, which is typically observed during a hot summer evening.

Similarly, the daytime minimum demand forecasts provided are specifically designed to offer our customers information for evaluating network conditions during periods of peak embedded generating unit exports to the distribution network.

Furthermore, SA Power Networks has presented export capacity forecasts for embedded generating units across sub-transmission, connection points, zone substations, and 11kV feeders, encompassing PV, Energy Storage Systems, and non-Inverter Energy System installed capacity.

4.1.2. Future transmission – distribution connection point forecast

ElectraNet and SA Power Networks do not forecast a requirement for the establishment of any new transmission connection point substations in South Australia within the forward planning period. Section 4.4.1 below details augmentation that is proposed to alleviate sub-transmission line constraints within the forward planning period.

4.1.3. Forecasts of performance against the Service Target Performance Incentive Scheme reliability targets

This information is presented in Section 8.1.1 Reliability Performance Forecast.

4.2. Network asset retirements that result in a system limitation

Schedule 5.8(b1) and (b2) of the NER require SA Power Networks to provide information on all asset retirements that would result in a system limitation, in the forward planning period.

The vast majority of our asset replacement (retirement) programs involve assets that have a replacement unit cost of less than \$200,000. Details of these programs are set out below.

For asset replacement projects consisting of assets greater than \$200,000, a system limitation template has been prepared. The system limitation templates can be found in the Network Visualisation Portal.

Conductor replacement program

The overhead line conductor replacement program involves the modern equivalent replacement of conductors that have reached their end of life and cannot be economically maintained or refurbished.

Conductors are replaced when their poor condition presents unacceptable risk to safety, reliability and network security and it is financially prudent to do so. To determine whether a conductor needs to be replaced, a risk-based approach is used, taking into consideration historical performance, routine inspections and impact to service levels.

Conductor replacement activities will be undertaken at various locations in South Australia throughout the forward planning period. Note, conductor replacement may be undertaken during both planned and unplanned works.

Underground cable replacement program

The underground cable replacement program involves the replacement of high voltage and low voltage cables that have been identified as having a high risk of failure. The identification process may consist of performing online inspection (oil filled cables) and offline tests (only for HV cables), or analysis of historical data to determine trends such as the location of failures, type of failures, the date of failure where available as well as local knowledge from various depot personnel.

Poor condition underground cables are replaced based on their historic performance, known risks and when the cable is at the end of its expected life (high level of cable deterioration). The methodology for identifying whether an underground cable needs to be replaced is based on a combination of the following:

- Historical failure;
- Operational inspection by online and offline cable testing;
- Failure trend analysis especially on cable sections that have failed numerous times within a short period of time;
- Cables that have experienced historical high loads; and
- Impact to service levels.

The underground cable replacement program consists of both planned and unplanned works and are undertaken at various locations across South Australia.

In recent years, the network performance in the Adelaide CBD (Adelaide Business Area) has fallen short of the reliability targets set by ESCOSA. This underperformance has been primarily attributed to the increasing failures of ageing paper-insulated lead (PLY) cables, which are reaching the end of their service life. To address this issue, funding was sought and approved by the AER for increased cable replacement expenditure in the 2025-30 RCP. This funding will be used to replace the poorly performing PLY cables in the CBD. In alignment with the regulatory allowance, the replacement of PLY cables in the CBD has been planned for the upcoming forward planning period.

The ACR and Eastern suburbs sub-transmission network is subject to stringent reliability requirements under the ETC, and the Whitmore Square to Magill 66kV oil-filled cable currently supports supply security under N-2 and N-3 contingencies. However, this oil-filled cable is in

poor condition with an ongoing history of oil leaks. In 2020, innovative cable oil leak detection technology was applied to allowed for faster identification of the location of leaks. Due to high ongoing maintenance and repair costs, along with environmental concerns, the Whitmore Square to Magill 66kV cable is well beyond its serviceable life. As a result, network reinforcement works and the decommissioning of the Whitmore Square to Magill 66kV cable are being considered in the forward planning period to ensure continued compliance with ETC reliability requirements and maintain support to ElectraNet during contingency events.

Pole renewal program

The pole renewal program involves the 'like for like' replacement of poles that have reached their end of life and pole plating or re-plating (refurbishment) where the base of the pole can be reinforced with steel plates. Most of the pole renewal program expenditure involves the replacement of Stobie poles. However, the majority of the assets renewed are through the pole plating (refurbishment) program to extend the life of corroded Stobie poles. A Stobie pole consists of a concrete core with two outer steel beams interconnected by bolts to ensure pole strength.

Stobie poles are renewed when they are in poor condition. The failure mode is typically due to ground level corrosion. The methodology for determining whether an individual pole needs to be replaced or refurbished is performed by undertaking a visual condition assessment and measurement of steel corrosion at the base of the pole.

Pole renewal activities are to be undertaken at various locations across South Australia throughout the forward planning period.

Pole top replacement program

The pole top structure program involves the replacement of existing pole top structures that have reached their end of life and cannot be maintained or refurbished with the modern equivalent. Much of the program involves the replacement of overhead insulators, cross arms, tapping arrangements and conductor restraints.

Pole top structures are replaced when their poor condition presents unacceptable risk to safety, reliability and network security and it is financially prudent to do so. Routine inspections determine whether a pole top structure needs to be replaced.

Pole top structure replacement activities will be undertaken at various locations in South Australia throughout the forward planning period. In some instances, when a pattern of poor performance has been identified in a section of network, a specific project will be undertaken to replace pole top structures within the specified section of network.

The replacement of pole top structures (including insulators) is determined through a risk-based approach. Defects identified through the OCI are reviewed and a work value (risk) determined along with an estimated cost to repair/replace. Works are then prioritised based on a risk vs cost approach, and replacements can be undertaken through both planned and unplanned works.

Recloser renewal program

The recloser renewal program involves the replacement or refurbishment of high voltage reclosers ranging from 7.6kV to 33kV, that are obsolete or have reached the end of their expected life. Refurbishments are undertaken where possible, otherwise the reclosers are replaced.

Reclosers are small self-contained circuit breakers that are typically mounted on a pole. They are designed to protect powerlines with more intelligence than fuses. All reclosers can sense different types of faults and are able to open and reclose a circuit in the event of transient faults. Reclosers are typically located in substations and mid-line whilst remote controllable units have been installed more recently at bushfire risk area boundaries.

Reclosers may be replaced for reasons including: poor condition, protection changes and limitations, or no longer being supported by manufacturers. The methodology for identifying whether a recloser needs to be replaced is a combination of the following:

- Operational inspection;
- Recloser counter reading;
- Historic failure rates for unplanned replacements; and
- Risk to network service levels.

We have identified increasing failures of legacy hydraulic reclosers. These assets cannot be recommissioned on site by changing the coil size and therefore present a known risk that cannot be effectively managed by cyclic inspection or counter reading.

Recloser replacement activities will be undertaken at various locations across South Australia throughout the forward planning period.

Voltage regulator replacement program

The voltage regulator replacement program involves the replacement of HV regulators (ranging from 7.6kV to 33kV) that are at the end of their useable life, are obsolete, unable to be refurbished or have failed in service.

Voltage regulators are designed to maintain a constant voltage level along a powerline feeder. They differ from transformers in that the active conductors on either side of the voltage regulator are at the same nominal voltage level. Voltage regulators are mounted on poles or ground mounted and are usually located mid feeder.

The methodology for identifying whether a voltage regulator needs to be replaced is a combination of the following:

- Operational inspections;
- Condition monitoring;
- Monitoring historical failure rates of unplanned replacements; and
- Risk to network service levels.

We have identified increasing failures of existing, legacy voltage regulators. Oil sampling tests on these assets cannot be conducted and therefore these voltage regulators present a known risk that cannot be effectively managed by inspection and condition monitoring.

Voltage regulator replacement activities will be undertaken at various locations across South Australia throughout the forward planning period.

Ground level switchgear renewal program

The ground level switchgear renewal program involves the replacement of medium voltage (7.6kV to 33kV) ground level switchgear that are approaching the end of their expected life and cannot be maintained. However, some types of switchgear are also refurbished using spare parts or availability of new components for specific makes/models.

Switchgear is renewed due to age and deterioration. The failure of switchgear can result in operational restrictions on the network posing an unacceptable risk to the safety, reliability and security of the network. This can occur due to the obsolescence and inability to source spare parts to repair switchgear.

The methodology for determining the renewal of ground level switchgear is based on:

- Condition monitoring through inspection;
- Monitoring of historical performance and known failure rates;
- Reviewing operational restrictions affecting network performance;
- Reviewing how obsolescence will lead to future restrictions; and
- Risk to network service levels.

Ground level switchgear renewal activities are widespread throughout the underground network in South Australia.

33kV and 66kV substation circuit breaker replacement program

Substation circuit breakers provide an essential role within SA Power Networks' network, providing controlled switching and fault isolation for both the high voltage sub-transmission and distribution networks. The safe and reliable operation of these assets is critical to network operation as they provide essential control and protection functionality necessary to maintain public safety and the ongoing reliable supply of electricity to our customers. The consequences of in-service failures of these assets range from wide scale supply interruptions, hazards to the environment and public safety, catastrophic fires and collateral damage to major substation assets.

Replacement of circuit breakers is planned as their performance degrades and they approach the end of their economic life, presenting unacceptable risks to safety and network security. Planned circuit breaker replacements are determined using a risk-based approach that considers age, condition, performance and failure consequences of individual assets. Circuit breaker replacement activities include both planned and unplanned replacement projects undertaken at various locations across South Australia.

The planned and unplanned circuit breaker replacement program is ongoing throughout the forward planning period.

Instrument Transformer replacement program

Current transformers (CTs) and voltage transformers (VTs) are collectively known as instrument transformers. Within substations, they are predominantly used with protection and metering devices to control and monitor the network and detect faults. In this application, they are essential to safe and reliable operation of the electricity supply network.

Replacement of instrument transformers is planned as their condition degrades and they approach the end of their economic life, presenting unacceptable risks to safety and network security.

Planned replacements are determined using a risk-based approach that considers age, condition, performance and failure consequences of individual assets. Instrument transformer replacement activities include both planned and unplanned replacement projects to be undertaken at various locations across South Australia.

Substation Direct Current supplies replacement program

Substation Direct Current (**DC**) systems provide supply to critical substation protection, communications, supervisory control and data acquisition (**SCADA**) and metering equipment that is independent of Alternating Current (**AC**) mains.

These systems are an essential part of SA Power Networks' ability to recover from major storm events and are designed to ensure supply continuity for essential systems for a period sufficient for emergency response and safe restoration of LV AC supply.

All major substations are provided with a DC system, comprising of batteries, chargers, DC distribution panels and supply circuits. Batteries used in SA Power Networks' substations typically have a ten year functional life and are renewed as a scheduled program of works. If replacement intervals are extended beyond these timeframes there is a high risk of in-service failure.

The replacement of chargers and distribution panels is based on asset condition, obsolescence, reliability, and safety to ensure adequate survival times and monitoring capabilities at critical sites. DC supply replacement activities include both planned and unplanned replacement projects to be undertaken at various locations across South Australia.

Substation Alternating Current Auxiliary supplies replacement program

Substation AC auxiliary systems provide supply for critical substation primary plant and systems such as circuit breaker motors, transformer cooling, OLTCs, DC systems, station lighting, air conditioning and general LV AC supply outlets.

These systems consist of a distribution panel in the substation control building, supply transformers, and associated low voltage distribution circuits.

The partial or whole replacement of the AC Auxiliary system is planned as their condition degrades or if the system is unable to provide a level of supply security that ensures safe and secure network performance. AC supply replacement activities include both planned and unplanned replacement projects and will be undertaken at various locations across South Australia.

Substation disconnecter replacement program

Airbreak disconnectors are simple mechanical switches that provide essential network reconfiguration and isolation points to allow maintenance, supply restoration or repairs of the high voltage network.

These devices are fundamentally mechanical equipment, with moving parts, springs and contacts exposed to the elements, corrosion and mechanical wear. Ageing, deterioration, operational duty and obsolescence all influence reliability, performance and end of life renewal.

Due to practical difficulty of isolating, accessing and upgrading them, many substation disconnectors suffer from age related failure modes that pose significant risks to operators (who are directly below devices when switching) and impose operational restrictions on network operations.

A significant increase in age related substation disconnector failures has recently been observed and increasing rates of planned and unplanned renewal projects are consequently being undertaken at various locations across South Australia.

Pipework Switchyard replacement program

Pipework style substation switchyard construction was popular within many small rural substations from the 1940's through to the early 1990's. Whilst meeting the minimum construction standards of the time, this style of construction is plagued with safety, reliability and operational issues that cannot be adequately managed without significant site remediation works.

This program was initiated in 2015 to address inherent safety, reliability and operational issues of this type of small country substation and improve service delivery outcomes for rural customers. Replacement activities include planned replacement projects at various locations across South Australia and it is planned to upgrade approximately two sites per year in the forward planning period.

Protection replacement (planned and unplanned)

The relay replacement program involves the replacement of existing relays with their modern equivalent.

Relays are replaced owing to their poor performance, limited functionality or where they are no longer supported by the manufacturer.

The methodology for determining whether a relay needs to be replaced is based on the risk calculated by our Risk Cost Model. The Risk Cost Model for protection relays uses age, expected relay life, failure rates and known failure modes for specific relay types to develop a relay health index and in turn a probability of failure. The total risk depends on the safety, bushfire start, and financial consequences associated with such relay failure.

Protection relays replacement activities are to be undertaken at various substations across the South Australian network throughout the forward planning period.

Rural Feeder Protection Program

The rural feeder protection program involves the installation of fault clearing devices to address identified inadequacies on the rural 19kV network. Typically, this may include the installation of fuses and reclosers. Without adequate backup and overreach protection, there is a risk should the primary protection device fail. Under fault conditions, clearing times would otherwise be excessive.

4.3. System limitations resulting from asset de-ratings

Schedule 5.8(b1) and (b2) of the NER requires SA Power Networks to provide information on all asset de-ratings that would result in a system limitation, for the forward planning period.

SA Power Networks does not forecast any asset de-ratings that would result in a system limitation in the forward planning period.

4.4. System limitations for sub-transmission lines and zone substations

Schedule 5.8(c) of the NER requires SA Power Networks to provide information on system limitations for sub-transmission lines and zone substations for the forward planning period. As noted in section 3.2, system limitations have been included below where the corresponding solution expenditure is planned in the forward planning period.

4.4.1. System limitations for sub-transmission lines

SA Power Networks' sub-transmission line system limitations forecast for the forward planning period are outlined below. Where the anticipated solution expenditure is greater than \$200,000 corresponding system limitation templates¹ are available via the [network visualisation portal](#).

Dynamic Time of Day ratings for sub-transmission lines

To assist in the assessment of deferral options for projects required to remediate identified constraints on sub-transmission lines, time of day ratings are considered. These bespoke ratings may be applied in cases where peak load consistently coincides with more favourable weather conditions, such as evening non-solar hours, resulting in a higher rating for the asset. Careful consideration is given to selecting these ratings, ensuring that N or N-1 risks are appropriately managed.

An * is used in this section to indicate ratings that, following the application of a dynamic time-of-day rating, lead to project deferral. This information is based on currently available data and is intended solely for determining the timing of required projects.

Consumer Energy Resource Management, Load transfers and Monitoring Program

SA Power Networks considers it prudent and efficient to monitor and, where possible, perform minor load transfers to defer the need for major upgrades to the network. The unit costs for such works are less than \$200,000. SA Power Networks does not have any sub-transmission line constraints that are able to be deferred via load transfers in the forward planning period.

For constraints due to export flows during periods of minimum demand, SA Power Networks will attempt to mitigate all overloads by implementing export limits on any existing embedded generation that has SCADA control. In locations where these constraints are driven by CER <200kW, which do not have SCADA control capability, SA Power Networks has introduced reduced fixed export limits and flexible export limits for all CER <200kW. Where there is sufficient curtailable export generation for CER <200kW, fixed export limits will cap the contribution of these systems to reverse constraints, and flexible exports will provide the capability for SA Power Networks to reduce exports at times when the network is constrained. These new connection arrangements are described further in Section 6.5.

¹ System limitation templates have not been provided for projects >\$200,000 that are committed.

Port Noarlunga to Seaford and Seaford to Aldinga 66kV sub-transmission lines

The Port Noarlunga to Seaford and Seaford to Aldinga 66kV sub-transmission lines form part of the meshed 66kV sub-transmission network that supplies the southern suburbs and Fleurieu Peninsula. These sub-transmission lines are forecast to be overloaded following a N-1 event (loss of the Morphett Vale East to McLaren Flat to Willunga 66kV line) under 10 PoE conditions.

Recent forecasts and monitoring have indicated that these lines are already significantly overloaded and in breach of the planning criteria. In 2021, SA Power Networks commenced initial design works to investigate possible network solutions and obtain construction estimates for these solution options. These works were performed in preparation for the RIT-D process, to consider the network and non-network solutions to address the identified constraint. The RIT-D evaluation was initiated in 2022, with the publication of an OSR, a Draft Project Assessment Report (**DPAR**) and a Final Project Assessment Report (**FPAR**), all now complete.

The regulatory investment test concluded the preferred option was to replace all of the underrated conductor sections within the Southern Outer Metropolitan (**SOM**) loop, with a higher capacity High Temperature Low Sag (**HTLS**) conductor. Upon completion of the detailed design and field checks, it was deemed beneficial to combine this solution with an alternative solution using All Aluminium Alloy Composite (**AAAC**) conductor for the final construction solution.

The upgrade of the Port Noarlunga to Seaford line section is planned for completion in 2026 and the Seaford to Aldinga 66kV line section is planned for completion from 2027 and beyond. In the interim period, SA Power Networks will consider the use of other post contingent measures to mitigate the severity of the overload, such as the use of SA Power Networks' 8MW power station on Kangaroo Island to reduce load supplied by this line under contingent conditions. The forecast overloads are outlined in the following table.

Table 1. Limitation for the Port Noarlunga to Seaford & Seaford to Aldinga 66kV sub-transmission lines

66kV sub-transmission line	N-1 Rating (MVA)	2025/26 N-1 Overload (MVA)	2026/27 N-1 Overload (MVA)	2027/28 N-1 Overload (MVA)	2028/29 N-1 Overload (MVA)	2029/30 N-1 Overload (MVA)
Port Noarlunga to Seaford	93.0	23.1	27.1	31.0	34.9	38.8
Seaford to Aldinga	93.0	11.7	14.9	18.1	21.4	24.6

McLaren Flat to Willunga 66kV sub-transmission line

The McLaren Flat to Willunga 66kV sub-transmission line is part of the meshed 66kV sub-transmission network that supplies the southern suburbs and the Fleurieu Peninsula. This sub-transmission line is forecast to be overloaded following a N-1 event (loss of Port Noarlunga to Seaford to Aldinga 66kV line), under 10 PoE conditions.

This line constraint is directly linked to the Port Noarlunga to Seaford and Seaford to Aldinga line constraints, as these lines form opposite sides of the same loop within the meshed system. Consequently, the loss of one section imposes constraints on the other.

Recent forecasts and monitoring have indicated that these lines are already significantly overloaded and in breach of the planning criteria. In 2021, SA Power Networks commenced initial design works to investigate possible network solutions and obtain construction estimates for these options. These works were performed in preparation for the RIT-D process, to consider network and non-network solutions to address the identified constraint. The RIT-D evaluation was initiated in 2022 and is now complete.

The regulatory investment test concluded the preferred option is to replace all SOM loop underrated conductor sections with a higher capacity HTLS conductor, where upon completion of detailed final design and field checks, it was deemed beneficial to combine this solution with an alternative solution using AAAC conductor for the final construction solution.

The upgrade of the Morphett Vale East to McLaren Flat 66kV line section commenced in July 2024 and was completed in 2025. The upgrade of the McLaren Flat to Willunga 66kV line section is planned for completion from 2027 and beyond.

In the interim period, until the resolution of this constraint, SA Power Networks will consider the use of other post contingent measures to mitigate the severity of the overload such as the use of SA Power Networks' 8MW power station on Kangaroo Island to reduce load supplied by this line under contingent conditions.

The forecast overload is outlined in Table 2 below.

Table 2. Limitation for the McLaren Flat to Willunga 66kV sub-transmission line

66kV sub-transmission line	N-1 Rating (MVA)	2025/26 N-1 Overload (MVA)	2026/27 N-1 Overload (MVA)	2027/28 N-1 Overload (MVA)	2028/29 N-1 Overload (MVA)	2029/30 N-1 Overload (MVA)
McLaren Flat to Willunga	92.0	9.5	12.1	14.7	17.4	20.0

Templers – Gawler Belt 33kV sub-transmission line

The Templers–Gawler Belt 33kV sub-transmission line provides critical connection to the Gawler Belt region. While there is currently a sub-transmission tie point to the Evanston Substation, this tie is scheduled for decommissioning in 2026 to enable the replacement of the Evanston substation switchboard and due to the ageing condition of the 33/11kV transformer that supplies the tie.

Additionally, a section of the sub-transmission line between Templers and Gawler Belt operates as a radial cable. In the event of a fault on this section, significant load would be at risk under 50 PoE conditions, as restoration options would be limited to local 11kV ties.

A project to duplicate the existing 33kV radial sub-transmission cable is planned for design and construction in 2026 to address the system limitation.

The proposed solution for this sub-transmission line is estimated to be less than \$7 million, and therefore a RIT-D is not planned for this project. However, we will consider non-network options to address this system limitation in addition to the proposed network solution outlined above.

The forecast overload (and load reduction required to defer the limitation) is outlined in the following table. Note that the overload arises in 2026/27, following the retirement of the tie point in 2026.

Table 3. Limitation for the Templers to Gawler Belt 66kV sub-transmission line

33kV sub-transmission line	N-1 Rating (MVA)	2025/26 N-1 Overload (MVA)	2026/27 N-1 Overload (MVA)	2027/28 N-1 Overload (MVA)	2028/29 N-1 Overload (MVA)	2029/30 N-1 Overload (MVA)
Templers to Gawler Belt	0	0	2.96	3.38	3.80	4.15

North Unley to Whitmore Square Tee 66kV sub-transmission line

The North Unley to Whitmore Square Tee 66kV sub-transmission line is part of the meshed 66kV sub-transmission network that supplies the inner loop of the Southern Suburbs. The overhead sub-transmission line consisting of Aluminium Conductor Steel Reinforced (ACSR) 54/7/0.139 is forecasted to be overloaded following an N-1 event (loss of Keswick – Plympton 66kV line) under 10 PoE conditions.

In 2026, a project is proposed to uprate approximately 2.9km of the existing overhead line from an operating temperature of 80°C to 100°C. The proposed solution for this sub-transmission line is estimated to be less than \$7 million², and therefore a RIT-D is not expected for this project.

In the interim period, until the resolution of this constraint, SA Power Networks will consider the use of other post contingent measure to mitigate the overload such as conducting 11kV feeder transfers to distribute load within the network.

The forecast overload is outlined in the following table.

Table 4. Limitation for the North Unley to Whitmore Square Tee 66kV sub-transmission line

66kV sub-transmission line	N-1 Rating (MVA)	2025/26 N-1 Overload (MVA)	2026/27 N-1 Overload (MVA)	2027/28 N-1 Overload (MVA)	2028/29 N-1 Overload (MVA)	2029/30 N-1 Overload (MVA)
North Unley to Whitmore Square Tee	109	2.0	9.8	15.6	17.5	19.4

New Osborne to Glanville 66kV sub-transmission line

The New Osborne to Glanville 66kV sub-transmission line forms part of the meshed 66kV sub-transmission network that supplies the Western Suburbs. This sub-transmission line consists of a combination of 54/7/3.5 ACSR/GZ designed for operation up to a temperature of 100°C (T100) and double circuit 0.25 in² Cu designed for operation at a temperature of 80°C (T80). Based on the most recent forecast this line is proposed to be overloaded following a N-1 event under 10 PoE conditions.

Given the meshed nature of the network, the level of load reduction required to mitigate the constraint, is not simply equivalent to the level of overload in MVA. Therefore,

² The RIT-D threshold has increased from \$6 million to \$7 million 1 January 2025.

although the 10 PoE load exceeds the rating of the New Osborne to Glanville line by 3.1MVA, closer to 12MVA of load will need to be shed to sufficiently reduce the load to within the line rating. The level of overload is also highly contingent on the output of three 66kV connected power stations in the region, namely OCPL, Dry Creek and Quarantine. Whilst officially connected to ElectraNet’s transmission network, they have a direct influence on 66kV line power flows within SA Power Networks’ sub-transmission network.

This line constraint places a high operational burden on SA Power Networks. Both the ability to remove assets from service for maintenance as well as connecting future load and generation in the region is severely inhibited. The 2024 forecast continues to show positive growth in this region.

A project to construct a new 66kV sub-transmission line between the Athol Park and Woodville substations is planned to commence design and procurement in 2030, with construction scheduled for 2031/32. This project aims to address the identified system limitation in the area.

As the estimated cost of the network solution exceeds \$15 million, SA Power Networks will undertake the formal Regulatory Investment Test for Distribution (RIT-D) process prior to any augmentation. The RIT-D process is planned to begin in 2028.

In the interim, SA Power Networks will explore the use of post-contingent measures to reduce the severity of overloads, including post-contingency switching.

The forecast overloads are outlined in the following table. The OCPL closure is reflected in these figures from 2027/28 onwards.

Table 5. Limitation for the New Osborne to Glanville 66kV sub-transmission lines

66kV sub-transmission line	N-1 Rating (MVA)	2025/26 N-1 Overload (MVA)	2026/27 N-1 Overload (MVA)	2027/28 N-1 Overload (MVA)	2028/29 N-1 Overload (MVA)	2029/30 N-1 Overload (MVA)
New Osborne to Glanville	144.0	5.2	7.2	1.3	4.6	5.0

Elizabeth Downs to Smithfield West 66kV sub-transmission line

The Elizabeth Downs to Smithfield West 66kV sub-transmission line is part of the meshed 66kV sub-transmission network that supplies the Northern Suburbs. This sub-transmission line is designed for operation at its ultimate operating temperature of 100°C and is forecast to be overloaded following a N-1 event under 10 PoE conditions.

In 2021, as part of a customer connection project, a new section of 66kV line was constructed between Virginia and Angle Vale substations. Whilst not meshed, this new 66kV line can provide some support to relieve the Elizabeth Downs to Smithfield West line under contingent conditions and will enable mitigation of this constraint following manual restoration.

Despite construction of this 66kV line, it is forecasted that there will be an increasing load at risk on the Elizabeth Downs to Smithfield West 66kV line. SA Power Networks proposes to alleviate this constraint in 2025/26 by installing new 66kV switchgear at the ends of the 66kV line at Virginia and Angle Vale substation respectively to enable the line to become permanently meshed. The proposed solution for this sub-transmission line is estimated to be less than \$7 million, and therefore a RIT-D is not planned for this

project. However, we will consider non-network options to address this system limitation in addition to the proposed network solution outlined above.

In the interim period, SA Power Networks will consider the use of other post contingent measures to mitigate the severity of the overload, including post-contingency switching.

The forecast overload is outlined in the following table.

Table 6. Limitation for the Elizabeth Downs to Smithfield West 66kV sub-transmission line

66kV sub-transmission line	N-1 Rating (MVA)	2025/26 N-1 Overload (MVA)	2026/27 N-1 Overload (MVA)	2027/28 N-1 Overload (MVA)	2028/29 N-1 Overload (MVA)	2029/30 N-1 Overload (MVA)
Elizabeth Downs to Smithfield West	92.0	10.0	12.2	16.1	20.1	24.0

Munno Para to Evanston 66kV sub-transmission line

The Munno Para to Evanston 66kV sub-transmission line is part of the meshed 66kV sub-transmission network that supplies the Northern Suburbs. This sub-transmission line is designed for operation at its ultimate operating temperature of 100°C and is forecast to be overloaded following a N-1 event under 10 PoE conditions.

SA Power Networks proposes to alleviate this constraint in 2025/26 by installing new 66kV switchgear at the ends of the 66kV line at Virginia and Angle Vale substations respectively, enabling the line to become permanently meshed. This is the same project as the Elizabeth Downs – Smithfield West 66kV line constraint. The proposed solution for this sub-transmission line is estimated to be less than \$7 million, and therefore a RIT-D is not planned for this project. However, we will consider non-network options to address this system limitation in addition to the proposed network solution.

In the interim period, SA Power Networks will consider the use of other post contingent measures to mitigate the severity of the overload, including post-contingency switching.

Table 7. Limitation for the Munno Para – Evanston 66kV sub-transmission line

66kV sub-transmission line	N-1 Rating (MVA)	2025/26 N-1 Overload (MVA)	2026/27 N-1 Overload (MVA)	2027/28 N-1 Overload (MVA)	2028/29 N-1 Overload (MVA)	2029/30 N-1 Overload (MVA)
Munno Para to Evanston	91.0	0	12.8	16.7	20.5	24.3

Freeling North Tee to Kapunda Rural 33kV sub-transmission line

Kapunda zone substation is supplied by a 33kV sub-transmission line from the Templers Connection Point. This sub-transmission line is designed for operation up to a temperature of 50°C and it is forecast to be overloaded under 10 PoE conditions in 2025/26.

There are no available tie points that would offer a suitable alternate option to supply Kapunda zone substation. A project is proposed to thermally uprate Freeling North Tee to Kapunda Rural from its present operating temperature of 50°C to 60°C. The timing of this project may be deferred beyond 2029/30 by application of a dynamic time of day rating, subject to further assessment of the rating. As such, the timing of the network augmentation is deferred indefinitely.

The proposed solution for this sub-transmission line is estimated to be less than \$7 million, and therefore a RIT-D is not planned for this project. However, we will consider non-network options to address this system limitation in addition to the proposed network solution outlined above.

The forecast overload (and load reduction required to defer the limitation) is outlined in the following table. Note that this reflects the overload before the application of a dynamic time of day rating.

Table 8. Limitation for the Freeling North Tee to Kapunda Tee Rural 33kV sub-transmission line

33kV sub-transmission line	N Rating (MVA)	2025/26 N Overload (MVA)	2026/27 N Overload (MVA)	2027/28 N Overload (MVA)	2028/29 N Overload (MVA)	2029/30 N Overload (MVA)
Freeling North Tee to Kapunda Rural	7.00*	0.37	0.54	0.70	0.87	1.08

Waterloo – Riverton Tee 33kV sub-transmission line

Riverton and Auburn zone substations are supplied by a common 33kV sub-transmission line from the Waterloo Connection Point. This sub-transmission line is designed for operation up to a temperature of 50°C and it is forecast to be overloaded under 10 PoE conditions in 2025/26.

There are no available tie points that would offer a suitable alternate option to supply the Riverton and Auburn zone substations. A project is proposed to thermally uprate this line from its present operating temperature of 50°C to 60°C. The timing of this project may be deferred beyond 2029/30 by application of a dynamic time of day rating, subject to further assessment of the rating. As such, the timing of the network augmentation is deferred indefinitely.

The proposed solution for this sub-transmission line is estimated to be less than \$7 million, and therefore a RIT-D is not planned for this project. However, we will consider non-network options to address this system limitation in addition to the proposed network solution.

The forecast overload is outlined in the following table. Note that this reflects the overload before the application of a dynamic time of day rating.

Table 8. Limitation for the Waterloo to Riverton Tee 33kV sub-transmission line

33kV sub-transmission line	N Rating (MVA)	2025/26 N Overload (MVA)	2026/27 N Overload (MVA)	2027/28 N Overload (MVA)	2028/29 N Overload (MVA)	2029/30 N Overload (MVA)
Waterloo to Riverton Tee	6.17*	0.06	0.19	0.32	0.45	0.59

Penola Tee – Glenroy Rural 33kV sub-transmission line

The Penola zone substation is supplied by 33kV sub-transmission line section from Penola West Connection Point. This sub-transmission line consists of ACSR 6/0.186-7/0.062 conductor designed for operation up to a temperature of 50°C and it is forecast to be overloaded under 10 PoE conditions in 2025/26.

There are no available tie points that would offer a suitable alternate option to supply Penola Zone Substation. A project is proposed to thermally uprate this line from its

present operating temperature of 50°C to 60°C. The timing of this project may be deferred beyond 2029/30 by application of a dynamic time of day rating, subject to further assessment of the rating. As such, the timing of the network augmentation is deferred indefinitely.

The proposed solution for this sub-transmission line is estimated to be less than \$7 million, and therefore a RIT-D is not planned for this project.

The forecast overload is outlined in the following table. Note that this reflects the overload before the application of a dynamic time of day rating.

Table 9. Limitation for the Penola Tee to Glenroy Rural 33kV sub-transmission line

33kV sub-transmission line	N Rating (MVA)	2025/26 N Overload (MVA)	2026/27 N Overload (MVA)	2027/28 N Overload (MVA)	2028/29 N Overload (MVA)	2029/30 N Overload (MVA)
Penola Tee to Glenroy Rural	6.17*	0.49	0.66	0.83	1.00	1.17

Paringa to Murtho 33kV sub-transmission line

The Paringa to Murtho 33kV sub-transmission line supplies the Murtho area and a bulk supply to Powercor over the Victorian border. The 33kV line is designed for operation up to a temperature of 80°C (T80) and it is forecast to be overloaded under 10PoE conditions in 2027/28.

A customer project is proposed to upgrade the Paringa to Murtho 33kV line by duplicating the first 3.3km of the line using 7/4.75 AAA conductor in 2026.

The proposed solution for this sub-transmission line is expected to be less than \$7 million, and therefore a RIT-D is not expected for this project. The forecast overload is outlined in the following table.

Table 10: Limitation for Paringa to Murtho 33kV sub-transmission line

33kV sub-transmission line	N Rating (MVA)	2025/26 N Overload (MVA)	2026/27 N Overload (MVA)	2027/28 N Overload (MVA)	2028/29 N Overload (MVA)	2028/29 N Overload (MVA)
Paringa to Murtho	15.00	0.00	0.00	0.16	0.32	0.48

Dorrien to Nuriootpa Tee 33kV sub-transmission line

The Nuriootpa and Stockwell Substations are supplied from Dorrien via a radial 33kV sub-transmission line. The Dorrien to Nuriootpa Tee 33kV line is designed to operate at temperatures up to 80°C, but is forecast to be overloaded under 10PoE conditions in 2027/28.

There are no available tie points that provide a suitable alternative supply for the affected 33kV line section. Additionally, as the line is already designed for 80°C operation, further thermal upgrading is not feasible.

To address this limitation, a project is proposed to extend the 11kV network from Dorrien Substation and transfer load away from Nuriootpa Substation, thereby reducing the load on the 33kV line. The timing of this project may be deferred beyond 2029/30 through the application of a dynamic time-of-day rating, subject to further assessment

of the rating. Consequently, the timing of the network augmentation is deferred indefinitely.

The proposed solution is expected to cost less than \$7 million, meaning a RIT-D process is not required for this project. The forecast overload is summarised in the table below, noting that this reflects the overload prior to the application of a dynamic time-of-day rating.

Table 11: Limitation for Dorrien to Nuriootpa Tee 33kV sub-transmission line

33kV sub-transmission line	N Rating (MVA)	2025/26 N Overload (MVA)	2026/27 N Overload (MVA)	2027/28 N Overload (MVA)	2028/29 N Overload (MVA)	2029/30 N Overload (MVA)
Dorrien to Nuriootpa Tee	20.3*	0.00	0.00	0.38	0.83	1.35

American River to Kingscote Tee 33kV sub-transmission line

The Kingscote and MacGillivray Zone Substations are supplied by a 33kV sub-transmission line connected to the meshed Metro South Connection Point region. This line is designed to operate at temperatures up to 50°C but is forecast to be overloaded under 10PoE conditions in 2025/26.

There are no available tie points that provide a suitable alternative supply for the Kingscote and MacGillivray Zone Substations. To address this limitation, a project is proposed to thermally uprate an 8.2km section of the American River to Kingscote Tee 33kV line, increasing its operating temperature from 50°C to 60°C. The timing of this project may be deferred beyond 2029/30 through the application of a dynamic time-of-day rating, subject to further assessment of the rating. Consequently, the timing of the network augmentation is deferred indefinitely.

The proposed solution for this sub-transmission line is expected to cost less than \$7 million, meaning a RIT-D process is not required for this project. However, SA Power Networks will also consider non-network options to address this system limitation alongside the proposed network solution.

The forecast overload is summarised in the table below, noting that this reflects the overload prior to the application of a dynamic time-of-day rating.

Table 12. Limitation for the American River to Kingscote Tee 33kV sub-transmission line

33kV sub-transmission line	N Rating (MVA)	2025/26 N Overload (MVA)	2026/27 N Overload (MVA)	2027/28 N Overload (MVA)	2028/29 N Overload (MVA)	2029/30 N Overload (MVA)
American River to Kingscote Tee	6.17*	0.15	0.43	0.71	0.99	1.17

4.4.2. System limitations for zone substations

SA Power Networks’ zone substation system limitations forecast for the forward planning period are outlined below. Where the anticipated solution expenditure is

greater than \$200,000 a corresponding system limitation template³ is available via the [network visualisation portal](#).

It should be noted that SA Power Networks considers available load transfers in its planning criteria for zone substation N-1 constraints. A zone substation will be considered constrained under N-1 conditions when the N-1 rating of the substation, plus available load transfers is less than the 50PoE forecast of that zone substation. The N-1 ratings listed in the overload tables below only consider the N-1 transformer rating at the zone substation. Information regarding available load transfers is detailed in the corresponding system limitation templates.

Note that in previous years, as part of the historic deterministic planning criteria, 3MVA acceptable load at risk was added to the available load transfers which formed the N-1 constraint threshold. As part of the shift to a probabilistic planning criteria, detailed in Section 3.2, this load at risk is no longer considered and is not considered in the overload tables below, as was in previous years. Under the new planning criteria, timing of projects to address N-1 system limitations are determined using their optimal economic timing.

Consumer Energy Resource Management

For constraints due to export flows during periods of minimum demand, SA Power Networks will attempt to mitigate all overloads by implementing export limits on any existing embedded generation that has SCADA control. In locations where these constraints are driven by CER <200kW, which do not have SCADA control capability, SA Power Networks has commenced the introduction of reduced fixed export limits and flexible export limits for all CER <200kW. In substations, where there is sufficient curtailable export generation for CER <200kW, fixed export limits will cap the contribution of these systems to reverse constraints, and flexible exports will provide the capability for SA Power Networks to reduce exports at times when the network is constrained. These new connection arrangements are described further in Section 6.5.

In some instances, the export rating of SA Power Networks' zone substation transformers is limited due to the OLTC's design such that the import and export ratings vary significantly. Where constraints in the reverse direction are driven by these OLTC limitations, SA Power Networks will look to implement revised OLTC settings which will increase the export rating by essentially bypassing the OLTC. SA Power Networks refers to this program as "OLTC Blocking" which is described further in the following section.

Embedded generation proponents are strongly encouraged to view the connection point and zone substation minimum demand forecasts. Where a proponent's proposal will result in a reverse constraint, that proponent will be responsible for funding either appropriate protection schemes (i.e. run-back) or network upgrades.

On Load Tap Changer Blocking Program

Some of SA Power Networks' zone substation transformers have OLTCs which, due to the nature of their design, limits the amount of power which can be accommodated by them whilst operating in the reverse direction. This limitation therefore becomes the inherent restriction in the rating of the transformer when power is being exported to

³ System limitation templates have not been provided for projects >\$200,000 that are committed.

the network. This restriction is often much less than the unit’s nameplate rating when operating in the forward direction. Therefore, many of the sites containing these transformers are forecast to become constrained in the forward planning period.

Where possible (based on the capability of the existing OLTC control relay), we propose to remove the effects of the OLTC from the circuit. This will be done by temporarily locking the OLTC in its present tap position and preventing it from operating whenever power flows near the export rating. It will only be enacted at times of high reverse power flow as the OLTC is required to regulate voltage. OLTC blocking increases the export rating significantly (at the expense of voltage control) and thereby mitigates the constraint in the short term. There are currently no projects to incorporate OLTC tap blocking at any zone substation in the year 2026. In future, OLTC blocking will be considered as part of the CER Integration program, described further in 6.5.3.

Line Drop Compensation for zone substations

CERs can face a reduction in the flexible export limit determined by SA Power Networks’ Constraint Engine due to recorded or modelled high voltages at one or more Customer’s smart meters. High levels of CER export into the local low voltage distribution network can raise the voltage experienced by customers to outside that of the acceptable levels as prescribed in AS60038.

We propose to invest in further improvements to network voltage management to reduce daytime voltage rise in high solar areas. This includes the installation of dynamic voltage control (Line Drop Compensation, or LDC) equipment at 25 zone substations and regulators, continuing from the rollout undertaken for our 2020-25 Enhanced Voltage Management (EVM) program.

SA Power Networks has currently identified the following list of 25 zone substations/regulators for LDC setting implementation in 2026. Augmentation at the proposed sites ranges from setting changes to voltage control relay upgrades to achieve the dynamic voltage control capability.

Table 13. Zone substation regulation upgrades

Zone substation/regulator
Nildottie 11kV
Balaklava 7.6kV
Jervois 11kV
Wilmington 11kV
Riverton 11kV
Brinkworth Town 11kV
Hawker 11kV
Plympton 11kV
Hughes Gap Regulator
Auburn 11kV
Port Augusta
Mt Schank Substation 11kV
Quorn 11kV
Ninnes 11kV
Keith 11kV
Kongorong 11kV
Hatherleigh 33kV Regulator
Naracoorte East 11kV
Marion Bay 11kV
Spalding 11kV
Woods Point 11kV

Sherlock 11kV
Telowie 11kV
Padthaway 11kV
Teal Flat 11kV

Smithfield West Substation Upgrade

Smithfield West Zone Substation consists of a single 32MVA 66/11kV transformer supplying approximately 11,000 customers in the surrounding suburbs of Munno Para, Munno Para West, Andrews Farm and Smithfield Plains. The area is experiencing significant load growth from land re-zoning and the connection of large residential developments. Under 50% PoE conditions, if the single transformer at Smithfield West substation is lost, supply cannot be restored to all customers after performing the available load transfers. A deferral solution was constructed in 2023, creating a new feeder tie point to Angle Vale substation to increase load transfer capability for the substation.

Post completion of the deferral solution, there still remains an emerging risk of unserved energy triggering the need for the upgrade of the Smithfield West substation. SA Power Networks proposes to undertake a project to install a second 32MVA 66/11kV power transformer. The project to alleviate this constraint is planned for construction in 2028/29 when the project becomes economically feasible.

The proposed solution for this substation is expected to be less than \$7 million, and therefore a RIT-D is not expected for this project.

The forecast overload is outlined in the following table.

Table 14. Smithfield West N-1 overload

Substation	N-1 Rating (MVA)	2025/26 N-1 Overload (MVA)	2026/27 N-1 Overload (MVA)	2027/28 N-1 Overload (MVA)	2028/29 N-1 Overload (MVA)	2029/30 N-1 Overload (MVA)
Smithfield West 11kV	0.00	6.07	7.29	8.80	10.68	12.12

Salisbury Substation Upgrade

Salisbury Zone Substation consists of two 21MVA and one 24MVA 66/11kV transformers, supplying 19,000 customers in the surrounding suburbs Salisbury, Brahma Lodge and Salisbury Heights. The area is experiencing significant load growth from the connection of several commercial and industrial loads, as well as residential infill. Based on the latest substation forecast, the zone substation is expected to be overloaded in the summer of 2028/29 under N conditions.

In 2028/29, SA Power Networks proposes to construct a new Salisbury South substation with a new 32MVA 66/11kV transformer, associated switchgear, protection, control and control building, and a new Para to Salisbury South 66kV sub-transmission line.

The proposed network augmentation to alleviate the substation constraint is estimated to breach the RIT-D threshold of \$7 million therefore, SA Power Networks plans to initiate the RIT-D evaluation process in early 2027.

Table 15. Salisbury N overload

Substation	N Rating (MVA)	2025/26 N Overload (MVA)	2026/27 N Overload (MVA)	2027/28 N Overload (MVA)	2028/29 N Overload (MVA)	2029/30 N Overload (MVA)
Salisbury 11kV	71.32	0.00	0.00	0.00	0.64	2.34

McLaren Vale Vineyard Substation Reconfiguration

McLaren Vale Vineyard substation is 33/11kV 150kVA pole top transformer supplied from the Willunga – McLaren Vale 33kV line. The substation supplies a single feeder with five customers. The McLaren Vale substation has been decommissioned as part of an asset replacement program to remove the aged Willunga 66/33kV and McLaren Vale 33/11kV substations. The McLaren Vale Vineyard substation will be reconfigured as part of an existing 11kV distribution feeder post 2026.

Ascot Park Substation

Ascot Park Zone substation consists of a single 66/11kV 21MVA transformer that supplies over 9,000 customers in the surrounding suburbs of Ascot Park, Park Holme, Plympton Park and Edwardstown. Based on the latest substation forecast, the zone substation is expected to be overloaded in the summer of 2027/28 under N conditions and N-1 conditions in 2025/26.

To defer the substation capacity upgrades, in 2027 SA Power Networks proposes to build a new 11kV feeder out of the Morphettville Zone substation that will alleviate the load constraint out of the Ascot Park substation and also provide additional load transfer capability. The new Morphettville substation 11kV feeder will also assist in addressing the Glenelg East 11kV feeder N constraint detailed in section 4.5.1.

The forecast overload is outlined in the following tables.

Table 16. Ascot Park N overload

Substation	N Rating (MVA)	2025/26 N Overload (MVA)	2026/27 N Overload (MVA)	2027/28 N Overload (MVA)	2028/29 N Overload (MVA)	2029/30 N Overload (MVA)
Ascot Park 11kV	23.9	0.00	0.00	0.43	0.83	1.20

Table 17. Ascot Park N-1 overload

Substation	N-1 Rating (MVA)	2025/26 N-1 Overload (MVA)	2026/27 N-1 Overload (MVA)	2027/28 N-1 Overload (MVA)	2028/29 N-1 Overload (MVA)	2029/30 N-1 Overload (MVA)
Ascot Park 11kV	0.00	1.63	2.77	3.98	4.32	4.69

Mount Burr Substation

The Mount Burr substation is a single 0.3MVA pole top 33kV/11kV transformer supplied from the Snuggery to Kalangadoo 33kV sub-transmission line located in the South East region. According to the latest 10% PoE substation forecast, the substation was forecasted for risk of overload in the summer of 2024/25.

The lack of SCADA monitoring at this substation increases the complexity of producing a 10% PoE substation forecast. SA Power Networks has installed portable measurement

equipment to monitor the load over the summer of 2025/26. If the forecast proves accurate, SA Power Networks proposes to upgrade the substation capacity by replacing the existing transformer with a new 33/11kV 0.5MVA pole top transformer in 2026/27.

The forecast overload is outlined in the following table.

Table 18. Mount Burr N overload

Substation	N Rating (MVA)	2025/26 N Overload (MVA)	2026/27 N Overload (MVA)	2027/28 N Overload (MVA)	2029/29 N Overload (MVA)	2029/30 N Overload (MVA)
Mount Burr 11kV	0.36	0.02	0.03	0.04	0.06	0.07

Two Wells Substation Upgrade

The Two Wells substation consists of a single 12.5MVA 66/11kV transformer, and three 11kV feeders that supply approximately 2,000 customers within the township. The Two Wells area is experiencing significant load growth from land re-zoning and the connection of large residential developments. Under 50% PoE conditions (when excluding non-redundant major customer load), if the single transformer at Two Wells substation is lost, supply cannot be restored to all customers after performing the available load transfers.

SA Power Networks proposes to undertake a project to install a second 12.5MVA 66/11kV power transformer. The project to alleviate this constraint is planned for construction in 2028/29 when the project becomes economically feasible.

The proposed solution for this substation is estimated to be less than \$7 million, and therefore a RIT-D is not expected for this project.

Table 19. Two Wells N-1 overload

Substation	N-1 Rating (MVA)	2025/26 N-1 Overload (MVA)	2026/27 N-1 Overload (MVA)	2027/28 N-1 Overload (MVA)	2028/29 N-1 Overload (MVA)	2029/30 N-1 Overload (MVA)
Two Wells 11kV	0	2.25	2.41	2.64	2.88	3.12

Lameroo 11kV Voltage Regulator Upgrade

The Lameroo Zone substation consists of two 1MVA 33/11kV transformers, one 11kV voltage regulator, and an 11kV feeder that supplies approximately 500 customers within the township. Forecasted demand under 10PoE conditions is expected to exceed the N rating of the voltage regulator.

SA Power Networks proposes to upgrade the existing 11kV voltage regulator to 200A rating in 2026. There are no available tie points that would offer a suitable alternative option.

The proposed network augmentation to alleviate the substation constraint is estimated to be less than the RIT-D threshold of \$7 million.

Table 20. Lameroo 11kV Voltage Regulator N overload

Substation	N Rating (MVA)	2025/26 N Overload (MVA)	2026/27 N Overload (MVA)	2027/28 N Overload (MVA)	2028/29 N Overload (MVA)	2029/30 N Overload (MVA)
Lameroo 11kV Voltage Regulator	1.3	0.05	0.07	0.09	0.14	0.16

4.5. Overloads and System Limitations for Primary Feeders

4.5.1. Overloaded primary distribution feeders

Schedule 5.8(d) of the NER requires SA Power Networks to provide details of any primary distribution feeders for which it has prepared forecasts of maximum demands under clause 5.13.1(d)(1)(iii) and which are currently experiencing an overload or are forecast to experience an overload in the next two years. As noted in section 3.2, system limitations have been included below where the corresponding solution expenditure is planned in the forward planning period.

SA Power Networks has several primary distribution feeders that are forecast to be overloaded and for which augmentation works are proposed to address the constraint in the forward planning period. In addition, there are several feeders that are forecast to be marginally overloaded in the next two years. SA Power Networks considers it prudent and efficient to monitor and perform minor load transfers prior to summer to defer the need for major upgrades on these feeders. All overloads stated would need to be mitigated prior to November of the summer stated.

Mount Barker 11kV feeder

The Mount Barker 11kV feeder supplied from the Mount Barker Distribution substation is forecast to be overloaded by 1.52MVA, under N conditions in the 2025/26 summer, according to the 10 PoE forecast. SA Power Networks is planning to construct a new 11kV feeder in 2026 transferring load from the Mount Barker 11kV feeder.

Bugle Ranges 11kV feeder

The Bugle Ranges 11kV feeder supplied from the Mount Barker Distribution substation is forecast to be overloaded by 1.09MVA, under N conditions in the 2025/26 summer, according to the 10 PoE forecast. SA Power Networks is planning to construct a new 11kV feeder in 2026 transferring load from the Bugle Ranges 11kV feeder.

Strathalbyn West 11kV Feeder

The Strathalbyn West 11kV feeder supplied from Strathalbyn zone substation is forecast to be overloaded by 0.36MVA under N conditions in the 2025/26 summer, according to the 10PoE forecast.

A customer project is proposed to upgrade 0.83km of overhead conductor to alleviate the constraint and increase the feeder exit rating of the Strathalbyn West 11kV feeder. The proposed works will increase also increase the N-1 transfer capacity of Strathalbyn East 11kV feeder to Strathalbyn West 11kV feeder.

Strathalbyn East 11kV Feeder

The Strathalbyn East 11kV feeder supplied from Strathalbyn zone substation is forecast to be overloaded by 0.019MVA under N conditions in the 2027/28 summer, according to the 10PoE forecast. Multiple sections of backbone conductor on the Strathalbyn East 11kV feeder are forecast to be overloaded under N-1 conditions during transfers in the 2025-26 summer, according to the 50POE forecast.

SA Power Networks is planning to construct a new 11kV feeder in 2027 supplied from Strathalbyn East zone substation transferring load to the new feeder from the Strathalbyn East 11kV feeder and Strathalbyn West 11kV feeder. The proposed works will also increase the N-1 transfer capacity of both Strathalbyn East and Strathalbyn West 11kV feeders.

Glenelg East 11kV Feeder

The Glenelg East 11kV feeder supplied from the Morphettville zone substation is forecast to be overloaded by 0.28MVA, in the 2025/26 summer, based on the latest 10 PoE forecast. As the forecast indicates continued growth and there are no suitable feeder ties, SA Power Networks proposes to construct a new 11kV feeder, approximately 1.2km long from the Morphettville substation using 630sqmm Al XLPE cable with feeder ties to surrounding feeders. This will facilitate a load transfer from the Glenelg East 11kV feeder to alleviate this constraint. The new Morphettville Sub 11kV feeder will also assist in addressing the Ascot Park Substation N and N-1 constraints.

Although the Glenelg East 11kV feeder N constraint is forecast in 2025/26, the project to alleviate this constraint is planned for construction in 2027. This project deferral has been determined based on a sensitivity test which considers the likelihood of an estimated delay in load uptake from new major customers.

Trott Park 11kV Feeder

One section of the Trott Park 11kV feeder backbone supplied from the Sheidow Park zone substation, is forecast to be overloaded by 0.16MVA, under N conditions in the summer of 2027/28. As the forecast indicates continued growth and there are no suitable feeder ties, SA Power Networks is planning to restring approximately 1.3km of overhead conductor in 2027/28 with a higher capacity conductor.

Munno Para West 11kV Feeder

The Munno Para West 11kV feeder supplied from the Smithfield West substation is forecast to be overloaded under N conditions by 1.18MVA in the 2026/27 summer, according to the 10 PoE forecast. SA Power Networks is planning to construct a new 11kV feeder in 2027, utilising a spare circuit breaker at Smithfield West substation and installing approximately 900m of underground cable. Load will be transferred to the new feeder from the Munno Para West 11kV feeder and other Smithfield West feeders. SA Power Networks will monitor the load uptake prior to the construction of the new feeder and will consider the use of temporary load transfers or application of a temporary rating as appropriate to manage overload risk.

Andrews Farm 11kV Feeder

The Andrews Farm 11kV feeder supplied from the Smithfield West Substation is forecast to be overloaded under N conditions by 0.57MVA in the 2026/27 summer, according to the 10 PoE forecast. SA Power Networks is planning to construct a new 11kV feeder in

2027, utilising a spare circuit breaker at Smithfield West substation and installing approximately 900m of underground cable. Load will be transferred to the new feeder from the Andrews Farm 11kV feeder and other Smithfield West feeders. SA Power Networks will monitor the load uptake prior to the construction of the new feeder and will consider the use of temporary load transfers or application of a temporary rating as appropriate to manage overload risk.

Minor 11kV Feeder constraints

Table 21 lists primary distribution feeders with forecast constraints that require minor remediation.

Table 21. Primary distribution feeders N-1 constraints with minor remediation (<\$200,000) list

Constrained Asset	Region	Limitation	Constraint (MVA)	Year of Constraint
Urimbirra and Inman Valley 11kV	Metro South	N-1 Overload	0.61	2025/26
Port Broughton 11kV	Upper North	N Overload	0.15	2024/25

4.6. Primary distribution feeders experiencing a system limitation from embedded generation

Schedule 5.8(d1) of the NER requires SA Power Networks to provide details of any primary distribution feeders for which it has prepared forecasts of demand for distribution services by embedded generating units under clause 5.13.1(d1)(3) and which are currently experiencing a system limitation or are forecast to experience a system limitation in the next two years.

SA Power Networks does not have any 11kV distribution feeder system limitations caused by export flows during periods of daytime minimum demand, in the forward planning period.

SA Power Networks’ strategy to mitigate system limitations caused by export flows includes implementing export limits on any existing embedded generation that has SCADA control. In locations where these constraints are driven by CER <200kW, which do not have SCADA control capability, SA Power Networks has commenced the introduction of reduced fixed export limits and flexible export limits for all CER <200kW. Fixed export limits will cap the contribution of these systems to reverse constraints, and flexible exports will provide the capability for SA Power Networks to reduce exports at times when the network is constrained.

4.7. System limitations with the potential for a regulated Stand Alone Power System

Schedule 5.8(d2) of the NER requires SA Power Networks to provide details of any system limitations in the forward planning period for which a potential solution is a regulated SAPS and to include at least the following information;

- 1) estimates of the location and timing (month(s) and year) of the system limitation; and
- 2) a brief discussion of the types of potential SAPS that may address the system limitation;

For the upcoming forward planning period, SA Power Networks does not have any system limitations that can potentially be resolved by a regulated SAPS solution.

5. Network Investment

5.1. Regulatory Investment Test for Distribution projects

This section provides details of SA Power Networks' RIT-D projects that have been completed in the preceding year or which are in progress.

Schedule 5.8(e) of the NER requires SA Power Networks to provide a high-level summary of each RIT-D project for which the regulatory investment test for distribution has been completed in the preceding year, or is in progress, including:

- 1) if the regulatory investment test for distribution is in progress, the current stage in the process;
- 2) a brief description of the identified need;
- 3) a list of the credible options assessed or being assessed (to the extent reasonably practicable);
- 4) if the regulatory investment test for distribution has been completed, a brief description of the conclusion, including:
 - a. the net economic benefit of each credible option;
 - b. the estimated capital cost of the preferred option; and
- 5) the estimated construction timetable and commissioning date (where relevant) of the preferred option; and
- 6) any impacts on Network Users, including any potential material impacts on connection charges and distribution use of system charges that have been estimated.

5.1.1. Preceding year RIT-D projects

SA Power Networks has 3 RIT-D projects which were completed in 2024 or are still ongoing.

Northfield Gas Insulated Switchgear Replacement

Northfield substation's 66kV gas insulated switchgear (**GIS**) was installed in the late 1980s, it is in poor mechanical condition and is exhibiting accelerated ageing with significant external corrosion – specifically flanges and SF6 gas sealing – after 35 years of continuous service in an outdoor environment.

Reflecting its age, the condition of the Northfield GIS has deteriorated to the extent that there is a material risk of asset failure. Failure of the GIS installation has the potential to lead to significant levels of unserved energy to customers in Adelaide's eastern suburbs.

SA Power Networks previously identified two credible network options to alleviate the network constraint that arises during contingent events, including:

- Option 1 – construct a new outdoor Northfield 66kV Air Insulated Switchgear (AIS) immediately south of the existing Northfield Substation; and

- Option 2 – construct a new indoor Northfield 66kV GIS in a climate-controlled building in the North-East corner of the Northfield substation.

SA Power Networks has determined that there is unlikely to be a non-network option or SAPS option that could form a potential credible option on a standalone basis, or as a significant part of a potential credible option as outlined in 4.7.

The summary of net market benefit of each credible option in NPV terms is in the following table.

Table 22. Summary of Net Market Benefits for Northfield GIS

Credible Options	Weighted PV of costs	Weighted PV of gross benefits	Weighted NPV	Ranking
Option 1: New Outdoor AIS	-25.7	1,246.0	1,220.3	1
Option 2: New Indoor GIS	-29.1	1,246.0	1,216.9	2

The regulatory investment test concluded that the preferred option is to construct a new Northfield 66kV outdoor AIS which satisfies the RIT-D. Delivery of this option is currently in progress, involving the construction of a new 66kV outdoor AIS immediately south of the existing Northfield substation site. The new AIS 66kV equipment consists of three 66kV bus sections to supply the seven 66kV lines and two 66/11kV transformers. The total estimated capital cost of the preferred option is expected to be \$45.5 million, including approximately \$15 million in transmission expenditure funded by ElectraNet.

Construction of the new AIS commenced in 2024 with commissioning expected to be completed in 2027. For more information, refer to the [Ensuring Reliable Supply for Adelaide's Eastern Suburbs - Northfield GIS FPAR](#).

Southern Outer Metro 66kV Line Upgrades

The SOM 66kV loop is the 66kV line source for the McLaren Flat, Willunga, Aldinga and Seaford substations within the Metro South region. From Willunga, it also supplies the Fleurieu radial 66kV network including the regions of Goolwa, Victor Harbor, Yankalilla and Kangaroo Island.

SA Power Networks has identified that components of the SOM loop are overloaded following an outage of the other (i.e. under N-1 conditions) during 10 PoE conditions. SA Power Networks has identified four credible network options to alleviate the network constraint that arises during N-1 contingency events, including:

- Option 1 – replace all SOM loop underrated 66kV conductor sections with a higher capacity All Aluminium Alloy Composite (**AAAC**) conductor;
- Option 2 – replace all SOM loop underrated 66kV conductor sections with a higher capacity High Temperature Low Sag (**HTLS**) conductor;
- Option 3 – replace all Port Noarlunga to Seaford to Aldinga underrated 66kV conductor with a higher capacity AAAC conductor. Install a second 66kV circuit between Port Noarlunga and Aldinga using the same AAAC conductor and augment the Port Noarlunga and Aldinga substations to accommodate second circuit; and
- Option 4 – replace all Port Noarlunga to Seaford to Aldinga underrated 66kV conductor with a higher capacity HTLS conductor. Install a second 66kV circuit

between Port Noarlunga and Aldinga using the same HTLS conductor and augment the Port Noarlunga and Aldinga substations to accommodate the second circuit.

The regulatory investment test concluded that the option with the highest NPV and hence the preferred option was Option 1, replace all of the SOM loop underrated conductor sections with a higher capacity HTLS conductor which satisfies the RIT-D.

However, upon completion of the detailed design, it was deemed beneficial to combine Option 1 and Option 2 for the final construction solution. The following factors were assessed and considered so that the project can be delivered in an overall efficient manner:

- Time of year site access – avoid wet weather months for steep terrain areas between Morphett Vale East and Willunga, avoid properties with grapevines within the 66kV line easement during vintage season.
- Limitations with Option 2 HTLS conductor – conductors left in stringing blocks for long period of time can result in damage, sharp angles within the existing 66kV line route and high pulling tensions can result in damage.
- Materials procurement – possible unusual very long lead times and shortages.

The total estimated capital cost of this combined option is expected to be \$27.7M with a weighted NPV of \$135.9M.

A summary of the in-progress conductor replacement project is as follows:

- Upgrade of the Morphett Vale East to McLaren Flat 66kV line section utilising Option 2 commenced in July 2024 and was completed in 2025.
- Upgrade of the Port Noarlunga to Seaford line section utilising Option 1 is planned for completion in 2026.
- Upgrade of the McLaren Flat to Willunga 66kV line and the Seaford to Aldinga 66kV line sections utilising Option 1 is planned for completion from 2027 and beyond.

Voltage Management and Under Frequency Load Shedding Emergency Standards

The Voltage Management (**VM**) and Under Frequency Load Shedding (**UFLS**) Emergency Standards prescribe investment required by SA Power Networks to address power system issues associated with CER. The standards include implementing enhanced voltage management and installing or enhancing the capability of UFLS protection. SA Power Networks therefore considers the identified need for this investment to be a 'reliability corrective action' under the RIT-D because investment is required to comply with an applicable regulatory instrument.

Due to there being only one credible option to meet the identified need, SA Power Networks considers no categories of market benefit to be material to the outcome of this RIT-D because they will not change the ranking of the credible options. In addition, quantification of the market benefit is not required in the context of an identified need

that is a reliability corrective action because such investments are permitted to have negative net economic benefits.⁴

The regulatory investment test concluded that the preferred and only option is to implement the voltage management services and amendment or installation of prescriptive UFLS infrastructure which satisfies the RIT-D. The total estimated capital cost of this option is approximately \$35 million comprising:

- \$10.0 million for the first stage of enhanced voltage management works and emergency UFLS commissioning for works completed before 31 March 2021;
- \$23.4 million for upgrade of UFLS systems to enable activation based on directional flow of power, taking place from 2022 to 2024; and
- \$1.6 million for expansion of UFLS to areas of the network that do not currently have this capability.

5.1.2. Current RIT-D projects

Addressing Power Factor Non-Compliance at ElectraNet Connection Points


SA Power Networks has been actively working to address the issue of power factor non-compliance at ElectraNet connection points. The flow of capacitive reactive power from the distribution system into the transmission system has been identified as a significant contributor to voltage control and system security risk on the SA transmission system, particularly during periods of low demand.

In the past year, we have commenced a RIT-D to address this issue. The identified need for this RIT-D is to rectify the trend of increasing capacitive power flows at transmission connection points, which has been compromising system security by limiting ElectraNet's ability to use their Static VAR Compensators (**SVCS**) to maintain dynamic voltage stability during critical contingencies. This is in line with our obligations under the TCA between ElectraNet and SA Power Networks, and our responsibility to ensure the reliable and efficient delivery of electricity to consumers, in compliance with industry standards and regulatory obligations.

Our preliminary investigations have confirmed a steady historic trend of increasing capacitive reactive flows at times of low demand, as shown in Figure 7. This trend is forecast to continue for the foreseeable future.

⁴ AER, Application guidelines - Regulatory investment test for distribution, December 2018, page 33.

Figure 7. Example peak capacitive reactive export forecast



To bring transmission connection points within compliance of the TCA, we are planning a program of 66kV and 11kV shunt reactor installations throughout 2025-30. This program is subject to the completion of the RIT-D. The Options Screening Report (**OSR**) and Draft Preliminary Assessment Report (**DPAR**) has been produced. We are continuing our process in evaluating the most cost-effective and efficient solutions to address this issue.

We are committed to maintaining the stability and reliability of the SA power system and will continue to work closely with ElectraNet to address these challenges and ensure compliance with the TCA.

Hindley Street 66kV Replacement Ensuring Reliable Supply for Adelaide CBD

Hindley Street substation is one of four critical zone substations supplying the Adelaide Central Business District (CBD) and is part of the meshed 66kV metropolitan east network. It is supplied via two 66kV cables, one from Whitmore Square and one from North Adelaide / Croydon. The existing outdoor 66kV yard at Hindley Street is extremely congested, with overhead pipework structures, strung bus and three aged bulk oil Circuit Breakers (CBs) manufactured in 1954. These are the only three of this type of CB remaining in the network.

The age and condition of the existing switchgear poses a significant reliability and safety risk to both SA Power Networks’ (SAPN) personnel and the public, with thousands of pedestrians passing every day within a few metres of deteriorated CB bushings and cable terminations. Catastrophic equipment failure, or failure with an explosion or fire, is likely to result in an extended substation outage with approximately 43MW of CBD load at risk. Only 21MW of the 11kV load can be tied away to other CBD feeders. Catastrophic failure is also a significant safety risk from an oil fire and porcelain debris.

To mitigate this risk, the Hindley Street Substation 66kV yard is planned to be replaced. The OSR has been published, with the Assessment Reports to be published in 2026.

5.1.3. Future RIT-D projects

Schedule 5.8(f) of the NER requires that we provide, for each identified system limitation which SA Power Networks has determined will require a RIT-D, an estimate of the month and year when the test is expected to commence.

SA Power Networks' forecast RIT-D projects for the forward planning period are shown in the following table.

Table 23. Forecast RIT-D projects for the forward planning period

Project Name	Forecast RIT-D Commencement Date
Coonalpyn – Meningie 33kV Line Replacement	2029
Tarlton – Ceduna 66kV line Replacement	2027
Salisbury South New Substation	2027
Athol Park – Woodville New 66kV line	2028
Mount Barker East New Substation	2028
Concordia New Substation	2030

5.2. Committed urgent and unforeseen investments

Schedule 5.8(g)(1) of the NER requires SA Power Networks to provide a summary of all committed investments to be carried out within the forward planning period with an estimated capital cost of \$2 million or more (as varied by a cost threshold determination) that are to address an urgent and unforeseen network issue.

At the time of publication, SA Power Networks does not have any unforeseen network investment with an estimated capital cost of more than \$2 million.

5.3. Interactions between frequency control, protection, and control systems

Schedule 5.8(o) of the NER requires SA Power Networks to provide an analysis of the known and potential interactions between:

1. any emergency frequency control schemes, or emergency controls in place under clause S5.1.8, on its network: and
2. protection systems or control systems of plant connected to its network (including consideration of whether the settings of those systems are fit for purpose for the future operation of its network),
3. undertaken under clause 5.13.1(d)(6), including a description of proposed actions to be undertaken to address any adverse interactions.

The Voltage Management and Under Frequency Load Shedding Emergency Standard RIT-D as discussed above in Section 5.1.1 is seeking to address these requirements through implementing voltage management services and the amendment or installation of prescriptive UFLS infrastructure.

6. Demand Management and Non-Network Opportunities

Schedule 5.8(l) requires SA Power Networks to provide information on our demand management activities and activities relating to embedded generating units.

SA Power Networks trials and evaluates emerging demand management technologies. We identify economically viable opportunities to improve the levels of network security and reliability provided to customers and to reduce the costs of providing standard control services. The technologies investigated include the use of smart meter data and services, transformer monitoring, energy storage, dynamic voltage management and direct communication with customer devices such as air conditioners, electric vehicle chargers, smart hot water systems, solar and battery inverters and home energy management systems (**HEMS**).

6.1. Demand management non-network options

Schedule 5.8(l)(1)(i) requires SA Power Networks to provide information on non-network options that have been considered in the past year, including generation from embedded generating units.

For projects surpassing the RIT-D threshold, where SA Power Networks determines a non-network option (including SAPS solutions) as a potential resolution for a specific system limitation, an OSR is published. This report invites comments and proposals for solutions to the identified system limitation from all market participants, interested parties and those parties registered on SA Power Networks' Industry Engagement Register (**IER**).

As part of our ongoing commitment to the efficient management of the distribution network, SA Power Networks expanded the scope of RIT-D process of engaging non-network solution providers to also include network investments less than \$7 million and address network constraints to defer network augmentation.

In 2023, SA Power Networks issued an Expression of Interest (**EOI**) seeking non-network solutions for three different constraints within the Tailem Bend, Bordertown and Robe regions, receiving several submissions for each constraint. SA Power Networks actively collaborated with the non-network service providers regarding their service offerings but was unsuccessful at identifying a commercially viable solution to pursue. Assessment of non-network service provider offerings concluded in April 2024.

Although no non-network service offering was successful, SA Power Networks negotiated a NSSA with a major customer in 2023 for the constraint identified in the Tailem Bend region to defer network augmentation. SA Power Networks negotiated a renewal of the NSSA with an existing service provider to defer network augmentation in the Bordertown region. SA Power Networks and ARENA are funding a community battery to address a constraint on the 33kV sub-transmission network to Robe.

SA Power Networks has not published any EOIs in 2025.

SA Power Networks published an OSR in May 2024 to address the issue of power factor non-compliance at ElectraNet connection points in line with our obligations under the TCA. The increased flow of capacitive reactive power from the distribution system into the transmission system has been identified as a significant contributor to voltage control and system security issues on the SA transmission system. The network solution to address the issue is to install approximately 270 MVAR of reactors at several connection points to meet TCA compliance requirements by 2030. SA Power Networks sought credible non-network options from the

market to be available on a standalone basis or a significant part of a credible option to address the issue. No submissions were received by close in August 2024.

SA Power Networks continues to investigate additional demand management non-network options in regions where emerging constraints have been identified. SA Power Networks was successful in the 2024/25 funding round for community batteries administered by ARENA. The submission included a portfolio of HV support, EV support, and resilience batteries use cases. The integration of community batteries for HV support is to assist with network constraints and will be located in the Tailem Bend region at Lameroo and in the South East region at Robe. HV support batteries mitigate the risk of unserved energy (load shedding) and the need for more costly traditional network upgrades, aligning with funding objectives. In addition, this opportunity allows SA Power Networks to gain industry/market knowledge to drive innovation and delivery methods to deploy community batteries in partnership with ARENA. It will build SA Power Networks' internal capabilities to deploy battery solutions that will be vital in the future to address network constraints in a cost-effective manner as standard network solutions.

6.2. Key issues arising from applications to connect embedded generation

Schedule 5.8(l)(1)(ii) requires SA Power Networks to describe its key issues arising from applications to connect embedded generating units received in the past year.

South Australia is at the forefront of the energy transformation with world-leading levels of renewable generation relative to demand. The increasing penetration of rooftop solar PV has seen periods in the middle of the day reach record levels of minimum demand. We are working with ElectraNet to analyse the challenges presented by a declining minimum demand.

Excessive voltage levels across the network at times of low demand and 'reverse power flows' through zone substations have been seen. Real time SCADA monitoring and controls are required for some exporting generating systems to prevent high voltage levels and exceeding equipment ratings during normal network conditions or after an outage of any single line, transformer, or temporary network reconfiguration.

SA Power Networks receives an extensive number of connection enquiries under the Chapter 5 and Chapter 5A process and an increasing number of informal enquiries to connect large exporting embedded generators.

In the past year, we have processed the following negotiated connections under Chapter 5A of the NER.

Table 24. Embedded generation connection enquiries and applications

2024/25 Embedded Generation	Quantity
Applications to connect received (30kW and under)	32,931
Connection enquiries received (applicable only for above 30kW, under 500kW)	141
New applications to connect received (above 500kW)	142
The average time take to complete applications to connect (above 500kW)	32 days

For further information on the impacts of CER refer to Section 8.2.6.

6.3. Actions taken to promote non-network proposals

Schedule 5.8(l)(1)(iii) requires SA Power Networks to describe its actions taken to promote non-network proposals (including SAPS solutions) in the preceding year, including generation from embedded generating units.

SA Power Networks revised and published its Industry Engagement Document (**IED**) in December 2025 following changes to the requirements and as part of the 3 yearly update cycle. This document provides a guide for third parties to explain how we will consider and assess the viability of non-network or SAPS solutions.

The RIT-D process requires augmentation investments of more than \$7 million, to undergo a Screening Test in accordance with Section 5.17.4 of the NER. Further details of our non-network option engagement strategy can be found on [our website here](#).

As outlined in Section 6.1, SA Power Networks actively engaged proponents to encourage and advance non-network proposals through our EOI activities. In a continued effort to foster the implementation of non-network proposals on our network we will continue to collaborate with potential applicants capable of offering successful alternative options to infrastructure upgrades. In cases where there are multiple EOIs that have been received in the same region, SA Power Networks is open to collaborating with multiple proponents to determine an optimal solution for the network and best outcomes for consumers.

SA Power Networks takes this opportunity to emphasise the potential benefits of non-network proposals in enhancing network resilience in regions served by radial sub-transmission lines or feeders. As the establishment of EV charging infrastructure continues, the integration of non-network demand management solutions provides an opportunity to deliver cost-effective solutions for customers.

6.3.1. Demand Management Opportunities for Customer Connection Requests

SA Power Networks receives customer connection requests that sometimes result in a network constraint and hence the requirement for network augmentation. In areas where the forecast load growth is low, these customer connections can significantly accelerate the timing and level of the augmentation required for the network.

SA Power Networks will assess the duration and frequency of peak load conditions pertaining to any forecast constraint. Where considered prudent and efficient to do so, SA Power Networks offers customers an opportunity to enter a demand management agreement to defer the required augmentation works.

6.4. Future plans for demand management and embedded generation

Schedule 5.8(l)(1)(iv) of the NER requires SA Power Networks to detail its plans for demand management and generation from embedded generating units over the forward planning period.

SA Power Networks recognises that alternatives to network solutions may exist which deliver either a lower cost solution or provide greater benefits to the electricity market (including electricity consumers) as a whole. The methods by which non-network solutions may achieve this include, but are not limited to:

- the use of embedded generation or storage to reduce demand on the network;
- shifting consumption to a period outside the peak period;
- increasing customers' energy efficiency; and
- curtailing demand at peak periods, with the agreement of the relevant customer(s).

SA Power Networks evaluates all options, both network and non-network, using identical criteria that reflect both the regulatory requirements under the RIT-D process and our desire to implement the least cost solution to resolve the identified need.

This process is set out in more detail in clause 3.4 of the IED. A copy of the IED can be found on our website at: [Industry Engagement Document \(sapowernetworks.com.au\)](https://sapowernetworks.com.au)

A substantial surge in demand, propelled by macro factors such as electrification, especially in the business, transport, and residential sectors, the increased adoption of EVs, renewable energy targets, and localised factors like in-fill housing, residential developments, and commercial and industrial loads, serves as the fundamental driver for the escalation of capacity-driven network augmentation. SA Power Networks is steadfast in its commitment to thoroughly explore and evaluate the potential of non-network solutions and flexible load connections to effectively manage this growing demand.

SA Power Networks has proposed to introduce the concept of ‘firm and flexible connections’ in our Connections Policy for the 2025-30 RCP. A flexible connection is a new offer where a customer keeps demand at their site within specified network limits in return for a cheaper, faster connection⁵. The AER has approved our Connection Policy⁶, which will come into effect from July 1, 2025. The draft response from the AER can be found [here](#).

Flexible connections are managed through Dynamic Operating Envelopes (DOEs). Unlike static limits, DOEs are adjusted at regular intervals based on the measured limits of the network capacity. DOE limits will vary due to conditions such as but not limited to, weather, active customer connections, generation limits, load limits, planned and unplanned outages, loss of system control and directions from electricity authorities. Operating envelopes can be reduced to zero under certain network operating conditions.

To be eligible for a flexible connection, the customer must have remote monitoring and controls that can receive and respond to DOE limits from SA Power Networks’ energy management platforms. Any flexible import or export from the customer’s site, including wholesale market and ancillary services operations, must remain within the DOE.

6.5. Consumer Energy Resources Enablement Program

In response to the emerging challenges of unmanaged CER systems as described in Section 2.1, SA Power Networks has introduced a range of measures to increase network hosting capacity to support the continued growth of CER in South Australia, including but not limited to:

- Implementation of enhanced voltage management at 147 zone substations (described further in Section 8.2.7);
- Introduction of a solar sponge tariff to encourage higher consumption during sunlight hours;
- Introducing a compliance program to ensure that all new PV installations apply the Volt-VAR and Volt-Watt power-quality response mode settings; and

⁵ The time and cost of negotiated connections varies and will be described in the customer offer letter.

⁶ In our Revised Proposal we resubmitted our Connection Policy with a minor amendment proposed to the payment terms threshold. The AER is due to make a final determination on our Revised Proposal in early 2025.

- Introduction of OLTC tap block to increase power transformer ratings limited by the tap changer associated with reverse power flow.

Even with all these measures in place, constraints related to reverse power flow continue to emerge, including:

- Zone substation reverse N and N-1 constraints that cannot be cost effectively mitigated through network augmentation. These are detailed in Section 4.4.2.
- Network Quality of Supply (**QoS**) related issues as detailed in Section 8.2.6.

The continued emergence of these constraints indicates that a static 5kW per phase export limit is unsustainable.

6.5.1. Changes to static export limits

To help address these challenges, SA Power Networks has introduced reduced fixed export limits of 1.5kW per phase, with a staged rollout of these limits beginning in the most highly constrained areas of the networks. Since 2022, reduced fixed export limits have been progressively rolled out to other parts of the network, in parallel with our Flexible Exports rollout. Where a reduced fixed export limit applies, customers have the option to take up a flexible export connection instead, as described in section 6.5.2 below. Areas not yet eligible for Flexible Exports continue to have access to the existing 5kW/phase export limit.

The eligibility of a given network area for a fixed 1.5kW or 5kW or flexible export limit is identified through our Eligibility Checker portal, forming part of the small embedded generation (**SEG**) application process for systems less than 30kW. This portal will enable customers and installers to enter a specific National Metering Identifier (**NMI**) or address to identify the export options available to a customer.

Connections for medium embedded generation systems will continue to be assessed on a case-by-case basis as part of the standard connection application process.

6.5.2. Flexible Export Limits

SA Power Networks is continuing to progressively roll out the Flexible Exports connection option to mitigate against these emerging challenges with high CERs. Unlike reduced fixed export limits that constrain customer exports all year round, flexible exports offer access to higher export limits at times when the network has adequate capacity by allowing us to reduce export limits only at the times and locations when the network is constrained. This capability is enabled in compatible internet connected smart inverters that download export limits from SA Power Networks which reflect the real-time capacity of the network where the inverter is located. The Flexible Export connection option will also be available for medium embedded generators with total export capacity less than 200kVA.

6.5.3. CER Integration

Our 2025-30 Regulatory Proposal introduced a new CER integration program to enable an export service that aligned to the expectations of our customers and the quantified market benefits of the program (using the AER's Customer Export Curtailment Value methodology).

In 2026, SA Power Networks intends to upgrade the voltage control capability of 25 additional zone substations and voltage regulators by lowering 11kV bus set points and implementing Line Drop Compensation. Providing dynamic voltage control in which the substation OLTC relay autonomously adjusts voltage according to a droop curve dependent on substation load. This capability will allow for additional export into the network before curtailment via Flexible Exports.

Furthermore, SA Power Networks intends to strategically invest in parts of the low voltage network where customers are experiencing frequent curtailment via Flexible Exports. The model in which we prioritise sites for upgrade is still in refinement and will evolve over 2026. Solutions are likely to consist of local distribution transformer upgrades and infills.

To find out more about Flexible Exports, visit [Solar Flexible Exports | SA Power Networks](#).

6.5.4. Flexible Exports standard connection offering

The Government of South Australia, as part of the [Smarter Homes Program](#), has introduced [Dynamic Export Requirements](#), requiring most new and upgrade exporting solar generation systems installed from 1 July 2023 to be capable of remotely updating their export limits.

In conjunction with this new Regulation, we have rolled out the Flexible Exports connection option to most areas across the State.

To find out more on the rollout, visit the Dynamic Export section on [our website](#).

6.6. Demand management connection enquiries and applications to connect

Schedule 5.8(I)(2) requires SA Power Networks to provide a quantitative summary of:

- I. connection enquiries received under clause 5.3A.5 and of the total, the number for non-registered embedded generators
- II. applications to connect received under clause 5.3A.9 and of the total, the number for non-registered embedded generators
- III. the average time taken to complete applications to connect;

The below table provides a summary of embedded generation enquires and applications received since the publication of last year's DAPR.

Table 25. Embedded generation connection enquiries and applications under clause 5.3A

2024/25 Embedded Generation	Quantity
Connection enquiries received under clause 5.3A.5	8
Enquiries for non-registered embedded generators (included above)	3
Application to connect received under clause 5.3A.9	1
Applications for non-registered embedded generators (included above)	0
The average time taken to complete applications to connect.	24 months

6.7. Micro embedded generators and non-registered embedded generators connection enquiries and applications to connect

Schedule 5.8(I)(3) requires SA Power Networks to provide a quantitative summary of:

- I. enquiries received under clause 5A.D.2 in relation to the connection of micro embedded generators or non-registered embedded generators

- II. applications for a connection service under clause 5A.D.3 in relation to the connection of micro embedded generators or non-registered embedded generators;

The below table provides a summary of embedded generation enquires and applications received since publication of last year’s DAPR.

Table 26. Embedded generation connection enquiries and applications under clause 5A.D

2024/25 Embedded Generation	Quantity
Connection enquiries received under clause 5A.D.2	166
Applications to connect received under clause 5A.D.3	140

6.8. Activities in relation to Regulated Stand Alone Power Systems

Schedule 5.8(p) of the NER requires SA Power Networks, if a SAPS enabled network, to provide information on our activities in relation to DNSP-led SAPS projects including;

1. opportunities to develop DNSP-led SAPS projects that have been considered in the past year;
2. committed projects to implement a regulated SAPS of the forward planning period; and
3. a quantitative summary of:
 - a. the total number of regulated SAPS in the network, and
 - b. the total number of premises of retail customers supplied by means of those regulated SAPS.

SA Power Networks do not have any SAPS in its network.

SA Power Networks will continue to evaluate SAPS opportunities. A few potential sites are being investigated to assess the financial viability of installing DNSP-managed SAPS systems. The driver for considering SAPS systems at these sites is typically due to long lengths of overhead conductor (typically SWER) supplying these sites being in poor condition/reaching the end of their useful life.

7. Asset Management

7.1. Asset Management Approach

Schedule 5.8(k) of the NER requires SA Power Networks to provide information on its asset management approach.

Our Asset Management is informed by our recently developed Asset Management 2035 Vision aligned with our corporate Strategic Directions 2035.

We focus on what our customers and stakeholders value. The outcomes we seek to deliver through our assets reflect the needs of our customers and stakeholders. We combine this with evidence-based decision making to inform our response and develop optimal works planning and delivery.

We achieve this through an aligned organisation and by continually innovating and adapting how we do things by empowering our people, investing in our asset management system, and piloting and trialling new technologies and concepts.

SA Power Networks' asset management practices are set up to deliver sustainable network investments and performance that are cost efficient, consistent with prudent risk management approaches that maximise customer value.

A key feature of SA Power Networks' asset management practices is the asset management decision making process based on return on investment. The value framework considers not only the monetised risks addressed by an asset intervention, but also the other benefits generated by this. This enables SA Power Networks to select the optimum maintenance and replacement strategy for each asset sub-class that is technically feasible, economically viable, and delivers an acceptable residual risk against SA Power Networks' risk strategy measure while delivering customer value.

SA Power Networks' asset management approach ensures that the organisation maximises opportunities, while not exposing the business and its customers (community) to unacceptable levels of risk.

Different assets within the network have different characteristics. Therefore, SA Power Networks' asset management practices and strategies consider asset groups, asset classes and sub-classes. This enables SA Power Networks to balance its capital and operational expenditure appropriately and optimally on assets based on the performance and customer services provided. The features of SA Power Networks' asset management approach, include:

- The development and delivery of levels of service that are supported by comprehensive customer and key stakeholder engagement;
- The translation of levels of service and risk into operational asset management decision making processes;
- The development and maintenance of the asset information systems and standards to ensure compliance with regulations, industry standards and to enable effective asset management decision making;
- The determination of optimum spares holdings required to deliver the regulated standards and customer expectations;

- The integration with augmentation projects (such as customer connections), including optimal scheduling and bundling of inspection, maintenance and replacement of assets;
- The long-term planning for the management of each asset-class (or sub-class), allowing for factors such as the age profile and expected end of life, performance history, condition information, and industry experience; and
- The achievement of continuous improvement.

7.2. Asset management strategies

Schedule 5.8(k)(1) of the NER requires SA Power Networks to provide a summary of its asset management strategies.

SA Power Networks is continually improving its asset management practices and systems. A major part of that improvement has been the continuation of the transition from a replace-on-fail approach to a replace-based-on-value approach for assets. This approach requires good asset condition data and the use of improved analytical techniques that allow us to assess the risks of asset failure and facilitate prudent asset lifecycle decisions.

SA Power Networks has undertaken several initiatives to improve its understanding of asset risk, including:

- requiring all asset inspectors to be accredited to UET20612 Certificate II in Electricity Supply Industry — Asset Inspection standard;
- taking targeted steps to improve our overhead line inspections by increasing the frequency of asset inspections, particularly, of those assets in high corrosion zones and high bushfire risk areas;
- implementing mobile data capture technology to enable inspectors to update asset information in the field and collect timely defect and asset condition information linked directly to the specific asset in the asset information system;
- determining the value of addressing defects from this information collected by inspectors and using it in operational asset management decisions;
- applying an increased level of diligence, prudence and foresight to the auditing of our asset inspection activities to achieve consistency of inspections; and
- implementing condition-based asset risk assessment software that uses actual asset data to quantify current and predict future asset risks.

SA Power Networks' inspection and condition monitoring practices include:

- GCI – these visual inspections assess in detail the assets at ground level. In particular, condition of poles and footings including an assessment of mechanical integrity and the level of corrosion of channels on the pole.
- OCI – these visual inspections (using binoculars) assess in detail, components of assets above ground level that GCI does not cover. For example, all other components on the pole, including conductors (conductor, fittings, tie wires, joints, services etc) and overhead equipment (switchgear, transformers, regulators, bushings, fuses, public lighting etc).

- Aerial Inspections – SA Power Networks has contracts for outsourced aerial inspection and patrol services using helicopters. These are primarily utilised for annual pre-bushfire patrols but are also utilised for emergency patrols, typically for storm related events.
- Heli-drone Inspections (Unmanned Aeronautical Vehicles) – SA Power Networks engages aerial photography specialists to undertake remote controlled aerial surveillance and photography using state of the art micro Unmanned Aeronautical Vehicles. These are used in areas that cannot usually be accessed by full size helicopters where the top of the pole inspection is required and cannot be assessed visually from the ground (e.g. some suspension construction on 66kV lines).
- Aerial LIDAR Inspections – SA Power Networks is currently trialling the use of LIDAR technology to assess the benefits of assisting with vegetation scoping, vegetation auditing and asset inspection.
- Thermographic Inspections – use of thermographic cameras to provide thermal imagery, to identify those components that have deteriorated due to a combination of corrosion and/or high load current to the extent that failure is likely by detecting hot spots within the inspected assets. These inspections are conducted on overhead assets, in substations and selected switchgear.
- Substation Inspections – substations are inspected using a combination of visual and thermographic inspection. Inspections include a check of the overall condition of assets (e.g. transformer, circuit breakers and switchgear), the condition of all structural elements, the integrity of insulators and bushings, equipment gas pressures, security of the site (e.g. fencing), oil levels in oil-insulated equipment, earthing connections, counter readings (for circuit breakers, reclosers).
- Substation Switchgear Condition Monitoring – specialist switchgear inspections are conducted to assess the condition and performance of switchgear components to identify hazards and component deterioration. A combination of radio frequency and ultrasonic detection, thermographic and visual inspections is used with non-intrusive electrical testing techniques to assess asset condition.
- Substation Transformer Condition Monitoring – routine oil physical/chemical tests are performed on transformer main and switch tanks. Specialist diagnostic and condition tests include thermographic inspection, Sweep Frequency Response Analysis (**SFRA**), Dynamic Frequency Response (**DFR**), Double Insulation testing (power factor, capacitance).
- Manhole inspections – Inspections of manholes to identify defects in aged cable joints and cable supports.
- 66 & 33kV cable inspection and testing – offline sheath testing of sub-transmission cable assets is undertaken. For oil filled cables this includes 6 monthly visual inspections and alarm testing and 1 yearly oil sampling.

The frequency of inspections and monitoring practices differs between assets and locations, based upon various factors such as:

- the environment the asset operates within; i.e. how fast we expect the condition of an asset to deteriorate between inspections;

- the safety risk (i.e. likelihood and consequence), particularly with regard to the potential of starting bushfires or injuring the public or our personnel; and
- the performance of the asset in an area.

The asset assessment strategies, including inspection and maintenance cycles, are documented in SA Power Networks' Network Maintenance Manual (Manual 12), Line Inspection Manual (Manual 11) and Substation Inspection Manual (Manual 19). The replacement strategies are discussed in detail within SA Power Networks' Asset Management Plans.

7.3. Asset life-cycle strategies

Table 27 summarises our inspection and replacement strategies for various asset classes.

Table 27. Asset class and life-cycle strategies

Asset Class	Inspection Strategy	Replacement Strategy
Poles	Inspection cycle: routine cycle of 5 years in bushfire risk areas(BFRA) and 10 years in non bush fire risk areas (NBFRA). Critical inspection: OCI and GCI.	A return on investment based replacement/refurbishment strategy is applied for poles, considering the value (risk reduction plus other benefits) of replacement/refurbishment.
Overhead Conductors (including insulators / connectors)	Inspection cycle: routine cycle of 5 years (inspected at the same time as poles). (Bush fire risk area) 10 years (non bushfire risk area) Critical inspection: Pre-bushfire patrols, OCI and thermographic.	A return on investment based replacement/refurbishment strategy is applied for conductors, considering the value (risk reduction plus other benefits) of replacement/refurbishment.
Underground Cables	Visible portions of cables and terminations are visually inspected every 5 years (BFRA) or 10 years (NBFRA) cycle. Oil filled cables are inspected every 6 months for integrity of the oil pressure system. Oil samples are taken yearly where possible. Sheath resistance testing every 5 years on 66kV.	A return on investment based replacement/refurbishment strategy is applied for cables, considering the value (risk reduction plus other benefits) of replacement/refurbishment.
LV Services	Not routinely inspected.	Replace-on-fail
Distribution Transformers	Pole mounted Inspection cycle: routine cycle every 5 years(at the same time as poles). Critical inspections: OCI and thermographic. Ground mounted Inspection cycle: routine cycle 5 years for distribution substation transformers Critical inspections: GCI and substation inspections.	A return on investment based replacement/refurbishment strategy is applied for distribution transformers, considering the value (risk reduction plus other benefits) of replacement/refurbishment.
Zone Substation Transformers	Inspection / testing cycle: routine cycle every six months.	Comprehensive analysis is undertaken to determine appropriate replacement/refurbishment strategies for individual

	Critical inspections: Dissolved gas oil analysis, substation inspection and thermographic, routine diagnostic testing.	substation transformers. This includes an assessment of both the likelihood of the asset failing and the resulting consequences including safety, reliability, financial and environmental impacts.
Distribution Switchgear	Line switchgear Inspection cycle: routine cycle every year Critical inspections: OCI and thermographic. Ground/indoor switchgear Inspection cycle: routine cycle every year Critical inspections: OCI, substation inspections and switchgear inspections.	A return on investment based replacement/refurbishment strategy is applied for distribution switchgear, considering the value (risk reduction plus other benefits) of replacement/refurbishment.
Substation Switchgear	Inspection / testing cycle: routine cycle from six months to a year. Critical inspections: substation inspections, routine diagnostic testing, inspections and thermographic surveys.	Comprehensive analysis is undertaken to determine appropriate replacement/refurbishment strategies for substation switchgear. This includes an assessment of both the likelihood of the asset failing and the resulting consequences including safety, reliability and financial impacts.
Protection Relays	Inspection / testing cycle: routine cycle every six months Critical inspections: substation inspections and diagnostic routine testing.	Comprehensive analysis is undertaken to determine appropriate replacement/refurbishment strategies for protection relays. This includes an assessment of both the likelihood of the asset failing and the resulting consequences including safety, reliability and financial impacts.
SCADA, Network Control	Critical inspections: substation inspections and remote monitoring.	Replace-on-fail, and when no longer supported by vendor.
Telecommunications	Critical inspections: Aerial fibre cable and Radio Communications tower inspections and remote monitoring by Telecommunication management systems.	Replace-on-fail, and when no longer supported by vendor.

7.4. Planned Strategic Improvements

7.4.1. Asset class replacement programs

SA Power Networks has some of the oldest assets in the NEM and the lowest rate of replacement. As the network deteriorates, we risk an increasing number of electricity assets failing in-service resulting in power outages, safety incidents and bushfires. This risk will be made worse in coming decades by climate change with the impact of more severe weather.

To continue to deliver the level of service our customers and community expect will require increased investment in asset replacement as well as an increased sophistication in our approach to Asset Management.

The below table summarises the key asset replacement programs that are being undertaken.

Table 28. Key asset class replacement programs

Asset class	Program
Poles	<p>Pole replacement and refurbishments volumes have risen in recent years due to the ageing asset population.</p> <p>It is anticipated that pole replacements (and refurbishments) will need to increase over the longer term as our network continues to age.</p>
Overhead Conductors	It is forecast that conductor replacement levels will continue to increase to prevent the further decline in the performance of this asset class.
Distribution Line Switchgear	The replacement of distribution line switchgear has increased as a result of finding a greater than anticipated number of defective switches and fuses. During the current RCP, we have focused on replacing switchgear and fuses on our older single phase high voltage circuits and some low voltage types. Focus has been given to upgrading some switch types to remotely controlled, electronic, switches to manage reliability, bushfire and safety risks.
Ground Level Switchgear	The volumes of ground level switchgear replacements have increased since 2008 as we moved from a replace-on-fail replacement strategy to a planned replace-before-fail strategy for certain types of switchgear. In particular, we have replaced a large number of switches that had restrictions on live switching due to their poor condition or safety risk. Our focus to date has been in CBD locations where we consider the risks and costs to be the highest.
Telecommunication	<p>Communications asset replacements are being driven by areas such as cyber security and changes in network protection system applications that are carried over the network and require connective prioritising Internet Protocol.</p> <p>Protection system applications based around smarter devices in the network, are driving a need for larger amounts of data being carried over the network therefore driving network capacity increases and technology changes to cater for these data increases.</p>
Substation Switchgear	Substation circuit breaker replacements focus on poor condition oil filled switchgear types, both 11kV indoor and 66/33kV outdoor, which carry significant safety, reliability, environmental and financial consequence. These targeted renewal programs are used to address areas of risk as large populations of legacy switchgear continue to age and deteriorate in service.
Substation Power Transformers	Substation transformer replacements are identified through ongoing maintenance and condition monitoring programs to detect the on-set of transformer failure and intervene prior to it impacting customer service and network performance.
Pipework Style Substation Switchyards	To address multiple, interrelated safety, environmental and security issues inherent to substations of pipework construction, a targeted replacement program has commenced and will continue through the forward planning period.
Substation Earthing	Since 2008, SA Power Networks has instituted a formal risk-based earth grid management strategy to substation earth grids, prioritising substation sites and remediation works by the safety risk posed by earth grid condition. The management of substation earth grids through the forward planning period represents a continuation of this established monitoring and remediation regime with each site planned for testing and inspection every 15 years.
Substation Security	In 2006 the Energy Networks Association released the 'National Guidelines for Prevention of Unauthorised Access to Electricity Infrastructure'. SA Power Networks has subsequently adopted a risk-based approach conforming to the guidelines and continues to maintain this to address security concerns of all high and medium risk substations.
Substation Environmental (Oil Containment)	All substations are subjected to ongoing audits and risk assessment as part of SA Power Networks' environmental management policies. This strategy continues throughout the forward planning period to complete high risk and medium risk sites.
Protection Systems	Substation protection systems are replaced based on condition, risk and performance (e.g. type of failure and defect history).
SCADA, Network Control	Substation SCADA systems are replaced on failure, or when vendor support is no longer available. SA Power Networks' strategy is to expand remote

control and monitoring to those substations without SCADA to enable monitoring and regulatory reporting.

7.5. Distribution losses

Schedule 5.8(k)(1A) of the NER requires SA Power Networks to provide an explanation of how it takes into account the cost of electricity distribution losses when developing and implementing its asset management and investment strategy.

Losses incurred across the distribution network represent the difference between energy sourced from the transmission network and delivered to end customers. The cost of the energy lost in transporting power through the distribution network is paid by customers via their retailer, using an averaging formula.

As these losses represent a cost to all consumers of electricity, SA Power Networks seeks to minimise these costs wherever practical. In accordance with the NER and the AER's RIT-D guidelines, where deemed material to the outcome of the RIT-D evaluation, SA Power Networks considers the change in the cost of losses for each network and non-network solution considered to resolve the identified network constraint(s). Details of how SA Power Networks conducts and performs RIT-D evaluations can be found within our Industry Engagement Document on [our website](#).

Minimisation of distribution losses is considered by SA Power Networks when managing and augmenting the network through the use of:

- low-loss zone substation transformers, which are encouraged by the use of a purchasing evaluation formula which penalises high loss designs (i.e. whole of life losses are considered);
- distribution transformers which meet the requirements of the minimum energy performance standards⁷;
- power factor improvement solutions that maximise network utilisation by reducing line/feeder current for the same load, in turn reducing losses for the same load at peak load times; and
- capacity upgrade projects, where losses for loads are reduced by using higher voltages (i.e. reduced current), larger conductors or additional transformers, and shorter lines and feeders through the insertion of new connection point and zone substations.

SA Power Networks does not implement projects specifically designed for the purpose of reducing distribution losses.

7.6. Asset management issues that may impact system limitations

Schedule 5.8(k)(2) of the NER requires SA Power Networks to provide a summary of any issues that may impact on the system limitations identified in the DAPR that have been identified through carrying out its asset management practices.

⁷ Distribution transformers are categorised based on factors such as location, insulation type, number of phases and voltage classes. Source: [Distribution transformers | Energy Rating](#)

SA Power Networks does not foresee any asset management related issues or practices that will impact on the system limitations identified in this DAPR.

7.7. Asset management further information

As required by Schedule 5.8(k)(3) of the NER, further information on SA Power Networks' asset management strategies and methodologies may be obtained by contacting the following Network Manager:

Head of Asset Investment: Mark Pynn

Email: mark.pynn@sapowernetworks.com.au

8. Network Performance

8.1. Reliability performance

Schedule 5.8(j) of the NER requires SA Power Networks to provide information on the performance of its network. This section sets out a summary of SA Power Networks' reliability measures and standards and our performance against these measures and standards. Our reliability performance report '[Annual Public Performance Report for the 2024/25](#)' can be accessed via our website. This report provides detailed information on our performance over 2024/25, for the four EDC feeder categories and the 10 regions across South Australia. A summary of our 2024/25 reliability performance is provided below.

8.1.1. Reliability performance forecast

Reliability STPIS performance forecast targets often differ slightly (on average by about 4%), to the jurisdictional reliability targets determined by the ESCOSA as defined in its EDC, refer to Section 8.1.2.

Reliability performance is influenced by a combination of factors, including adverse weather conditions, targeted reliability improvement projects, asset condition, and enhanced operational practices (e.g., emergency response procedures). As weather conditions cannot be accurately predicted, and given the complex interaction of the other factors mentioned, forecasting future reliability performance is inherently challenging.

To comply with Schedule 5.8(b)(4) of the NER, SA Power Networks has developed the following reliability performance forecast, as shown in the table below.

Table 29. SA Power Networks' STPIS feeder category reliability performance forecast

Reliability Measures	2025/26	2026/27	2027/28	2028/29	2029/30
USAIDIn (minutes)⁸					
CBD	17	17	16	16	16
Urban	94	94	94	94	94
Rural Short	165	162	160	157	154
Rural Long	310	308	306	304	302
USAIFIn (interruptions)⁹					
CBD	0.16	0.16	0.16	0.16	0.15
Urban	0.82	0.82	0.82	0.82	0.82
Rural Short	1.13	1.14	1.15	1.15	1.16
Rural Long	1.47	1.46	1.45	1.44	1.44

The forecast set out in the table above is based on the following assumptions:

- Includes the additional reliability funding accepted in the AER's Final Decision for the 2025-30 RCP.

⁸ USAIDIn is defined as 'Unplanned System Average Interruption Duration Index' normalised to exclude Major Event Days.

⁹ USAIFIn is defined as 'Unplanned System Average Interruption Frequency Index' normalised to exclude Major Event Days.

- The forecast is based on the five-year average historical trends
- The forecast assumes similar average weather trends; and
- The forecast excludes the performance on Major Event Days (**MED**) as permitted under the Service Target Performance Incentive Scheme (**STPIS**) regime.

8.1.2. Reliability measures and standards

Schedule 5.8(j)(1) of the NER requires SA Power Networks to provide a summary description of the reliability measures and standards that SA Power Networks must comply with. Under the Council of Australian Governments' Australian Energy Market Agreement, the South Australian Government has retained the responsibility for determining local (jurisdictional) distribution network reliability standards. The Government subsequently assigned that responsibility to ESCOSA.

A summary of the reliability measures and standards is provided in this section. For more details refer to SA Power Networks' Annual [Public Performance Report](#).

ESCOSA establishes the service standard framework for SA Power Networks, via a public consultation process prior to the commencement of each RCP. The reliability standards are published in the EDC and come into effect at the commencement of a new RCP, e.g. 1 July 2025. SA Power Networks' compliance with the EDC is a requirement of its distribution licence issued by ESCOSA.

The reliability measures used by the ESCOSA and the AER to monitor our performance are:

- **USAIDIn** (unplanned system average interruption duration index) — a measure of how long on average each customer is without supply in minutes for the period (typically a year) and is normalised by excluding interruptions that start on MEDs;
- **USAIFIn** (unplanned system average interruption frequency index) — a measure of how many times on average each customer is interrupted for the period (typically a year) and is normalised by excluding interruptions that start on MEDs; and
- In addition, ESCOSA uses two customer restoration of supply (**CRoS**) targets for each feeder category. These measure the percentage of the customers supplied by that feeder category who have an unplanned interruption exceeding a specified number of hours.

To enable regulators to be able to assess whether a distributor is maintaining the network to cope with normal weather events amongst other outage causes (e.g. animals), MEDs are excluded from the reliability measures they monitor. However, it is important to monitor the performance on MEDs to ascertain if distributors are still maintaining their ability to effectively respond to the effects of MEDs on their distribution system.

The EDC requires the use of “best endeavours¹⁰” to achieve the reliability service standard targets for each year ending 30 June. The best endeavours requirement means that where a reliability standard’s target is not achieved, SA Power Networks is still able to comply with that standard, provided it can demonstrate the use of best endeavours.

The reliability standards which apply for the new 2025-30 RCP (i.e. 1 July 2025 to 30 June 2030) are documented in the current version of the [EDC](#) (version EDC/14.1) clause 2.2.1.

8.1.3. Our reliability performance

Schedule 5.8(j)(3) of the NER requires SA Power Networks to provide a summary description of its reliability performance for its distribution network against the measures and standards described under Schedule 5.8(j)(1) for the preceding year.

Comprehensive reliability performance reporting is provided annually to ESCOSA. This section summarises our performance for the year ending June 2025. For the detailed analysis and outcomes on our performance, refer to our [Public Performance Report](#).

SA Power Networks achieved ten of the sixteen normalised reliability targets, for the four feeder categories, specified in the South Australian EDC, for the year ending 30 June 2025¹¹. For the six targets not achieved, CBD CRoS_n >1hr, Long Rural USAID_{In}, CRoS_n > 4hrs and CRoS_n >7hrs exceeded the reporting threshold.

Table 30 below details each of the four feeder category targets and actual normalised performance for the year ending 30 June 2025.

Table 30. Feeder category normalised reliability performance

EDC Feeder Category	USAID _{In}		USAIF _{In}	
	TARGET	2024/25	TARGET	2024/25
CBD	≥ 15	19.8	≥ 0.15	0.18
Urban	≥ 110	92.1	≥ 1.15	0.76
Short Rural (SR)	≥ 200	142.6	≥ 1.65	1.09
Long Rural (LR)	≥ 290	388.9	≥ 1.75	1.71
Overall Distribution System¹²	≥ 150	143.0	≥ 1.30	0.94

¹⁰ In the EDC best endeavours, “means to act in good faith and use all reasonable efforts, skill and resources”.

¹¹ The targets exclude the reliability contribution from interruptions starting on MED's.

¹² The ESCOSA reliability service standards do not include an overall distribution system target. These figures are the implied equivalent targets using the individual feeder category targets and the number of customers supplied from each feeder category.

Table 31. Restoration of supply performance (CRoS_n)

EDC Feeder Category	Duration of Interruption (Hrs)	Target(%)	Actual (%)
CBD	≥ 1	11	15.5
	> 2	4	3.1
Urban	> 2	27	23.5
	> 3	11	10.6
SR	> 3	27	21.8
	> 5	8	6.8
LR	> 4	30	44.0
	> 7	10	17.5

Non-achievement of the EDC reliability targets, when it occurs, is often due to one-off events or interruptions on a few non-MED days resulting from localised SWEs that are verified by the BOM.

In the year 2024/25 there were five MEDs.

Table 32. 2024/25 MEDs, contribution to reliability and MED category

Event #	MED Category	Dates	USAIDI	USAIFI	UCAIDI	Comment
1	Cat 1	19 Jul 24	5.78	0.0278	208	Severe weather event
2	Cat 1	17 Oct 24	8.44	0.0181	467	Severe weather event
3	Cat 1	10 Mar 25	5.36	0.0084	642	Severe weather event
4	Cat 1	26 May 25	6.55	0.0396	165	Severe weather event
5	Cat 1	7 Jun 25	4.93	0.0255	193	Severe weather event
Total		5 days	31.06	0.1194		

SA Power Networks monitors three key metrics (among others) to ensure that we are maintaining the distribution system to reliably transport electricity to customers under normal weather conditions. The three metrics are:

- The contribution to USAIDIn of equipment failure-caused interruptions. This monitors our performance in maintaining the distribution system under normal operating conditions;

- The contribution to USAIDIn of weather¹³ related caused interruptions; and
- The percentage of USAIDI resulting from equipment failure-caused interruptions on MEDs. This monitors the ability of the distribution system to cope with SWEs.

We monitor the resilience of the distribution system to cope with BOM SWEs by determining the average overall daily USAIDI on SWE days which do not result in the day being classified as a MED.

8.1.4. Regional reliability performance

SA Power Networks is also required to report the reliability of ten regions: nine distinct regions and another segmentation of feeders in a Major Regional Centres as defined in ESCOSA's Guideline No.1.

The annual regional reliability performance varies from year to year, both positive (better) and negative (poorer) than the long-term historical average (i.e. 15-year period ending 30 June 2020). SA Power Networks monitors the regional reliability using the measures USAIDIn and USAIFIn, to determine if historic performance of any region has declined.

In 2024/25 there was no notable decline in any of the 10 region's reliability performance. The poorer than historic performance for the 'South East' and 'Barossa, Mid-North and Yorke Peninsula' regions was mostly due to one-off equipment failures, SWEs and insulator pollution. However, a systemic issue has been identified concerning rural long feeders where sectionalisers are failing to operate under high solar generation scenarios. For further information refer to SA Power Networks' Annual [Public Performance Report](#).

8.1.5. Reliability corrective actions

SA Power Networks has several programs to manage reliability, including:

- A recurrent program to 'Maintain underlying reliability' on the network to maintain historic performance (i.e. this does not allow for additional upgrades to improve reliability).
- A 'Low reliability feeders improvement program' with remediations for specific low reliability feeders (mainly in rural and remote areas) that experience repeatedly poorer reliability, more than double their regional average. Customers on these feeders are our 'worst served customers'.
- A 'Regional reliability improvement program' to bring performance for worst served regions more in line with similar regions via remediations specific to the outage causes on feeders most impacting those regions – either to address current outage causes or reduce the customer numbers interrupted when outages occur.
- A 'Rural long feeders supply restoration improvement program' to make efficient and prudent progress to meeting SA EDC targets for rural long feeders.

¹³ Weather related includes unknown and vegetation, as the contribution from these causes is higher during SWE.

targeting rural long feeders where it is efficient to improve supply restoration times.

- 8.1.6. SA Power Networks is also required to prepare an annual [Monitoring, Evaluation and Compliance Strategy](#) (MECS), which explains how we plan to meet the service standards defined in Clauses 2.1 to 2.4 of the EDC. Processes to ensure compliance with the reliability measures and standards.

Schedule 5.8(j)(5) of the NER requires SA Power Networks to provide a summary description of the processes it has undertaken to ensure compliance with the reliability measures and standards described under subparagraph 5.8(j)(1).

SA Power Networks prepares a Reliability Management Plan annually, with the aim of maintaining reliability performance. This plan details the initiatives that SA Power Networks undertakes to maintain reliability performance when cost effective. Further it aims to minimise reliability Guaranteed Service Level payments.

SA Power Networks has an Operational Reliability Group which:

- Prepares and issues the Reliability Management Plan;
- Reviews previous interruptions to identify areas of poor performance or potential systemic causes of interruptions to initiate actions to remedy where warranted; and
- Annually prepares reliability improvement projects for the following calendar year.

The reliability improvement actions contribute to one basic outcome which is:

- Reducing the number of interruptions experienced by customers by:

Installing mid-line reclosers and sectionalisers to reduce the number of customers affected by a fault;

- Installing spur fuses to reduce the number of customers affected by a fault;
- Undertaking “no cause found” patrols for interruptions affecting more than 500 customers to reduce the likelihood of the same fault occurring (repeating) in the future; and
- Undertaking “reclose” patrols for switchgear reclose events affecting more than 1,000 customers to reduce the likelihood of a sustained fault occurring in the future.

8.2. Quality of supply performance

This section outlines the QoS standards applicable to SA Power Networks and our performance against those standards.

8.2.1. Applicable quality of supply standards

In accordance with Schedule 5.8(j)(2) of the NER, SA Power Networks is required to provide a summary description of the QoS standards it must adhere to, including the relevant codes, standards and guidelines.

The Electricity Act 1996 and the Electricity (General) Regulations 2012, provides a framework for supplying electricity to customers on the South Australian electricity distribution network. SA Power Networks' internal Power Quality Manual (Manual 24) sets out SA Power Networks' standards for the QoS customers can expect.

There are a number of parameters that contribute to power QoS including (but not limited to):

- Supply voltage;
- Power factor;
- Harmonics; and
- Flicker.

SA Power Networks is not accountable for, nor can it influence, the Alternating Current Frequency of electricity supplied through its network. AEMO establishes the standards governing frequency control and regulates the frequency on the national grid. If SA Power Networks becomes aware of frequency excursions outside of AEMO's standards, SA Power Networks notifies AEMO.

8.2.2. Range of supply voltage

Supply voltage is the voltage, measured either from phase to neutral or phase to phase, for electricity that is supplied at a customers' service point. It is important to maintain a steady state supply voltage within acceptable upper and lower limits to ensure customers' appliances and equipment are not damaged. In the event SA Power Networks' steady state supply voltage is outside of the tolerance specified in the relevant codes, standards and guidelines, SA Power Networks undertakes remedial works to improve the quality of supply.

SA Power Networks' low voltage network operates nominally at 230V single phase or 400V three phase. The high voltage distribution network typically operates at 7.6kV, 11kV and 19kV. Some major businesses are supplied at 3.3kV, 6.6kV, 11kV, 33kV or 66kV.

Low voltage network

The nominal voltage for the low voltage network is 230V, phase to neutral, and 400V phase to phase. Australian Standard, AS 61000.3.100 has specified a tolerance of +10%/-6% to allow for voltage regulation on the mains between distribution transformers and customers' service points. Therefore, under normal operating conditions the lowest limit of voltage that can be experienced on SA Power Networks' low voltage network at a customers' service point is 216V (230 - 6%) and the highest limit is 253V (230 + 10%).

High voltage network

SA Power Networks' high voltage distribution network operates at several voltage ranges as discussed above. Prospective high voltage customers should seek advice from

SA Power Networks on the available supply voltage at their location before proceeding with any project expenditure or commitments.

SA Power Networks applies the following standards and guidelines when setting and assessing network voltage performance for its low voltage and high voltage networks:

- SA Power Networks' Power Quality Manual (Manual 24);
- SA Power Networks' Service and Installation Rules;
- Australian Standards: AS/NZS 60038 and AS 61000.3.100; and
- NER S5.1a.4 – Power Frequency Voltage.

8.2.3. Harmonic content of voltage and current waveforms

Harmonic current and voltage distortion results from the operation of appliances or equipment that draw non-sinusoidal currents from the network by presenting a variable impedance during the voltage cycle. Such distortion can cause the supply voltage to depart from a sine wave in a repetitive manner. The resultant distorted wave is made up of multiple 'pure' sine waves of varying magnitudes, having frequencies that are integer multiples of the fundamental frequency (50 Hz). Maintaining waveform distortion within acceptable limits is important because it can otherwise cause interference and damage to sensitive customer and network equipment. This form of distortion can also cause light flicker, incorrect operation of computers, audible noise in television, radio and audio equipment and vibration in induction motors.

SA Power Networks relies on the following standards and/or guidelines when limiting and assessing harmonic performance:

- Power Quality Manual 24 (September 2015);
- Australian Standards: IEC 61000.3.6:2012;
- Standards Australia Handbook for power quality HB264;
- NER S5.1a.6 – Voltage Waveform Distortion; and
- SA Power Networks Service and Installation Rules.

8.2.4. Voltage Fluctuations (Flicker)

Voltage fluctuations are short-term repetitive, regular or irregular changes in the voltage level. Voltage levels change in response to changes in the load on the network, so that as the current drawn from the network increases, the voltage level drops. Similarly, when load is switched off or embedded generation exports, the voltage level rises. Voltage fluctuations can cause lighting to flicker and in severe cases it can lead to malfunctions in sensitive electronic equipment.

SA Power Networks relies on the following standards and/or guidelines when limiting and assessing flicker (voltage fluctuations) performance:

- SA Power Networks Power Quality Manual (Manual 24);
- Australian Standards: IEC 61000.3.6:2012;

- NER S5.1a.5 – Voltage Fluctuations; and
- SA Power Networks Service and Installation Rules.

8.2.5. Load unbalance

Unbalanced voltages can result from unbalanced network impedance, unbalanced loads or unbalanced embedded generation. Balanced impedances under normal operating conditions are achievable by appropriate design and construction practices and consequently, the means of controlling unbalance is the balancing of three phase loads and the even distribution of single-phase loads. Control of unbalance in three phase networks is important to avoid damage to certain types of three phase motors. Voltage unbalance can also result in distribution network faults such as inadvertent operation of protection relays and voltage regulation equipment.

SA Power Networks relies on the following standards and/or guidelines when limiting and assessing Voltage Unbalance performance:

- Power Quality Manual (Manual 24);
- Australian Standards: IEC 61000.3.6:2012; and
- NER S5.1a.7 – Voltage Unbalance.

8.2.6. Quality of Supply performance

Schedule 5.8(j)(3) of the NER requires SA Power Networks to provide a summary description of its QoS performance for its distribution network against the measures and standards described under Schedule 5.8(j)(2) for the preceding year.

SA Power Networks undertakes power quality (**PQ**) testing and monitoring using a number of methods including:

- short term PQ tests in response to customers' enquiries at supply transformers and at customer service points;
- customer load modelling and data from survey tests at transformers to determine their loading; and
- smart meter data where accessible;

In addition, since 2009, SA Power Networks has participated in the Quality of Supply Assurance Program conducted annually by the University of Wollongong – Power Quality Australia. SA Power Networks collected power quality voltage, harmonics and flicker data from monitored distribution transformers.

The sites were evaluated for compliance against the following standards:

- Range of Supply Voltage – AS 61000.3.100;
- Voltage Unbalance – IEC 61000.3.6:2012; and
- Harmonic Content of the Voltage Waveform IEC 61000.3.6:2012.

Power Quality Australia made the following observations based on the data SA Power Networks provided for 2023/24:

- Overall LV Compliance performance is much better than the national average.
- Results indicate [supply] voltage is being very well managed.
- No significant issues for other disturbances.
- Flicker is the disturbance of most concern[however].... Performance is better than national average.
- National results indicate significant levels of non-compliance for... flicker at LV.
- National results show an upward trend for flicker non-compliance for medium voltages.

SA Power Networks is also required to provide information on quality of supply complaints, to the AER in its annual Regulatory Information Notice. The Regulatory Information Order which will replace the Regulatory Information Notice from 2024-25 will shift the focus on complaints to overvoltage and export service issues rather than all quality of supply issues. A complaint is defined as an expression of dissatisfaction made to an organisation related to its products or the complaints handling process itself, where a response or resolution is explicitly or implicitly expected. The following tables detail the percentage of QoS related complaints from customers, by category and cause.

Table 33. QoS number of complaints in 2024/25

Complaint- technical quality of supply	Number
Complaints - technical quality of supply	25

Table 34. QoS Percentage of Complaints by Category

Complaints by category	Percentage (%)
Low voltage supply	20
Voltage dips	8
Voltage swell	0
Voltage spike (impulsive transient)	3
Waveform distortion	3
TV or radio interference	3
Solar related	16
Noise from appliances	0
Other	56

Table 35. QoS Percentage of Complaints by Likely Cause


Complaints by Likely Cause	Percentage (%)
Network equipment faulty	12
Network interference by NSP equipment	0

Complaints by Likely Cause	Percentage (%)
Network interference by another customer	6
Network limitation	20
Customer internal problem	24
No problem identified	0
Environmental	8
Other	36

Since 2016/17, quality of supply related complaints had risen each year due to increasing levels of consumer energy resources significantly impacting the voltages on the LV network. Voltage excursions outside of mandated limits became more prevalent, significantly increasing the number of quality of supply enquiries and complaints. According to the table, solar related enquiries continue to be the largest contributor to complaints. However, in 2020/21 the number of complaints has reduced by more than half of the previous year (108 complaints in 2019/20). In 2021/22, a further 20% reduction in overall complaints was achieved and had remained at this level for 2022/23 and 2023/24. The number of complaints made in 2024/25 has reduced by 30%.

All customer enquiries and complaints are lodged with our Customer Care team who monitor the progress of these complaints and enquiries and report on them as part of the service standards referred to in the Distribution Code. An enquiry refers to a request for information (which requires further investigation) received from a customer or their representative via nominated enquiry channels. The below figure shows the volume of customer enquires received by SA Power Networks per month since January 2020.

Figure 8. QoS customer enquiries per month since January 2020




The recent uplift in the number of QoS customer enquiries from November 2024 is due to a change in classification of enquiries made by customers. Prior to this change only customer enquiries with quality of supply related issues and subsequently flagged by attending field personnel for follow-up investigation by the PQ team, were reported and classified as a QoS Customer Enquiry. The new classification process also represents enquiries that have not yet been investigated and determined to be related to a QoS issue.

SA Power Networks will continue with the new process in which all relevant customer enquiries are flagged for investigation by default.

The following figure shows that PV related over voltage enquiries have continued to trend downwards since June 2020 despite continued growth in CER uptake.

Figure 9. PV related over-voltage customer enquiries since January 2015 until July 2024



In 2020 SA Power Networks commenced a project to implement enhanced voltage management capabilities at substations to improve system security and increase the network hosting capacity for distributed energy resources. This has significantly improved customer supply voltages and reduced the number of PV-related over voltage enquiries since mid-2020, supporting increased hosting capacity for CER. Volumes of enquiries are returning to manageable levels; however, many substations are reaching the limit of their ability to adequately control network voltages.

After experiencing substantial increases in customer enquiries in 2016 and 2017, SA Power Networks began a program in 2017 to install approximately 1,900 power quality monitoring devices at distribution transformers in areas with high solar PV penetration. This program was completed in 2024 and will provide greater visibility of power quality issues on our network, enabling a more proactive remediation approach.

In 2022/23, SA Power Networks established and operationalised a Network Visibility and Modelling program to accurately and efficiently identify thermal load constraints across LV networks and prioritise investment to reduce transformer failures and fuse operations. Furthermore, in 2023 data analytics packages of smart meter voltage data were operationalised to identify areas of the low voltage network that experience non-compliant voltages due to the existing levels of CER uptake.

Uptake of battery energy storage systems, growth of aggregated CER controlled Virtual Power Plants and future uptake of electric vehicles also pose new sources of power quality issues. Greater visibility of the LV network will play an essential role in managing the impacts of these new technologies and enable SA Power Networks to proactively address constraints or voltage compliance issues.

8.2.7. Quality of Supply corrective actions

Where the measures and standards described under Schedule 5.8(j)(2) were not met in the preceding year, Schedule 5.8(j)(4) requires SA Power Networks to provide

information on the QoS corrective actions that have been taken or are planned to be taken.

SA Power Networks allocates an annual capital budget to address QoS enquiries based on historic expenditure. These enquiries are investigated, and where required, corrective action is taken to resolve the QoS issue. SA Power Networks undertakes reactive actions to resolve these QoS related enquiries which include:

- Distribution transformer tap adjustments;
- Installation of an additional distribution transformer and dividing the local LV network between these transformers;
- Upgrading a distribution transformer with a higher capacity transformer;
- Upgrading LV and/or HV conductor with a higher capacity conductor;
- Phase balancing;
- Installation of low voltage regulation devices and STATCOM devices.

In addition to our reactive approach addressing individual QoS issues, SA Power Networks has undertaken the following activities to lower excess voltages levels on selected zone substations with very high solar PV penetration and high customer enquiries, to deliver overall network functional compliance:

- Implemented enhanced voltage management capabilities at 147 zone substations, lowering 11kV bus set points and implementing Line Drop Compensation where feasible. Line Drop Compensation provides dynamic voltage control in which the substation OLTC relay autonomously adjusts voltage according to a droop curve dependent on substation load.

However, some targeted metropolitan zone substation transformers have insufficient buck taps (voltage reduction) to effectively implement this level of control. This is common in many of our zone substation transformers, with older transformers being of particular concern which will require remedial action in the forward planning period;

- Change of distribution transformer tap settings to deliver the correct 99th percentile voltage (to AS61000.3.100:2011). Distribution transformer tap setting adjustments are performed in conjunction with customer enquiries where voltage testing for over or under voltages reveals voltages that are outside the prescribed limits;
- LV Monitoring has been deployed since the 2017-18 summer to selected distribution transformers across metropolitan Adelaide. By 2024, SA Power Networks will have a sufficient volume of monitored locations to establish a sufficiently sized sample of sites to be statistically representative of its overall low voltage network. PQ data is remotely retrieved from the monitors on a daily basis and will continue to assist in the development of electrical models of LV circuits to better predict overloads and power quality issues, and trends in behaviour over time;

- Smart meter data has been procured from meter data providers in order to proactively detect areas within LV networks that are experiencing voltages that breach AS61000.3.100:2011;
- Smart meter analytical tools are being developed to support detection of inverter system compliance to AS4777.2 power quality response modes in order to assist customers and electricians in correcting settings, avoiding excessive voltage rise and retaining inverter operation.

Modelling performed under the SA Power Networks' LV Management Strategy shows that even with these measures in place, certain parts of the distribution network with high penetrations of solar PV will continue to experience QoS issues.

To address this, SA Power Networks has introduced two connection options for all new residential CER systems (less than 200kW), those being:

- a fixed export limit, typically 1.5kW per phase; or
- a Flexible Export connection, up to 10kW per phase.

These measures will reduce the impact of new residential CER systems on the network. Changes to export limit arrangements are further discussed in Section 6.5.

Even with flexible exports we cannot fully prevent issues such as voltage exceedances from occurring in the long term. This is because even when exports are curtailed, rooftop solar generation continues to erode the underlying demand through self-consumption behind the meter. Thus, some level of ongoing export capacity augmentation is unavoidable as solar uptake grows.

8.2.8. Processes to ensure compliance with the Quality of Supply measures and standards

Schedule 5.8(j)(5) of the NER requires SA Power Networks to provide a summary description of the processes it has undertaken to ensure compliance with the QoS measures and standards described under subparagraph 5.8(j)(2).

Under the Standard Form Customer Connection Contract with SA Power Networks, low voltage network customers are required to comply with the requirements of the Service and Installation Rules and any other reasonable requirement of SA Power Networks. Consistent with those Rules and our rights under the Contract, SA Power Networks requires customers to ensure that:

- their electrical installation does not adversely affect SA Power Networks' network or other customers' installations; and
- that any audible or electronic noise generated by their electrical installation does not breach relevant laws or adversely affect others. If disturbances on the network are caused by more than one customer, SA Power Networks will establish overall limits for the interference by each customer, and customers who exceed their limits are required to rectify the situation.

SA Power Networks' network modelling process includes checks for voltage compliance on the high voltage network and our internal standards specify compliance requirements for the low voltage network. Customer QoS enquiries are reviewed, and corrective action is taken where required.

The process for managing power quality emission limits for major customer connections is generally dictated by the NER requirements for connection agreements. SA Power Networks is required to provide a 20-business day turnaround on responses to connection enquiries under the NER. Limits for automatic and minimum access standards for power quality are included in SA Power Networks' response to such connection enquiries.

There are different rules which apply to network customers and registered generators. However, generally the allocation of emission limits for customers and generators are defined in NER clauses S5.1.5-5.1.7. Power quality requirements for connections are based around the following access standards:

- Automatic Access Standards;
- Minimum Access Standards; and
- Negotiated Access Standards.

For generators, allocation limits are defined according to NER Clauses S5.2.5.2. For network customers, allocation limits are defined according to NER Clauses S5.3.7 and S5.3.8.

For both generators and customers, harmonic and flicker allocations are based on the AS/NZ 61000.3 series of documents. For voltage unbalance the proposed approach within SA Power Networks is to follow SA/NZ 61000.3.13:2012, which mirrors the Stages 1-3 approach of the harmonic and flicker Standards.

The process for achieving compliance with the prescribed power quality allocation limits is an iterative process, with consideration given to alternative connection points, or mitigation measures, should initial investigations indicate non-compliance. Where necessary this may involve a reassessment of limits, or the acceptance of a negotiated access.

Clauses are included in SA Power Networks' connection agreements to ensure compliance with power quality allocation limits.. It should be noted that the NER provides scope for SA Power Networks to subsequently enforce automatic access standards where network conditions change.

8.3. Service Target Performance Incentive Scheme information

Schedule 5.8(j)(6) of the NER requires SA Power Networks to provide an outline of the information contained in its most recent submission to the AER under the STPIS regime.

SA Power Networks is incentivised by the AER's STPIS regime to meet annual targets based on its:

- STPIS feeder category reliability performance which measures the average number of interruptions per customer and the average total time a customer is without electricity supply annually because of unplanned interruptions; and
- Telephone call responsiveness expressed as the percentage of calls answered in 30 seconds.

Under the STPIS regime improved performance is rewarded and declining performance is penalised (noting that rewards and penalties are both capped). The STPIS regime and the targets

are detailed in Chapter 10 of the AER’s ‘Final Decision SA Power Networks final determination 2020 to 2025 – Attachment 10, June 2020’. Note, new targets haven been established for the 2025-30 RCP which came into effect 1 July 2025.

The unplanned reliability performance measured under the STPIS excludes:

- MEDs; and
- events resulting from:
 - Transmission failures;
 - Police, Fire, Emergency Services isolations;
 - Generation failures;
 - Emergency disconnections; and
 - Single customer faults (where the fault is in the customer’s electrical installation).

Accordingly, the reliability targets for SA Power Networks exclude “excluded event caused interruptions” and interruptions on MEDs. These exclusions each relate to extraordinary circumstances over which SA Power Networks has limited or no ability to mitigate the interruption to customer supply.

The following tables provide details of our STPIS feeder category performance for the regulatory year ending 30 June 2025.

Table 36. Unplanned minutes off supply (USAIDI)

USAIDI	Feeder Category	Target	2024/25
Total sustained minutes off supply	CBD	-	19.8
	Urban	-	92.1
	Short rural	-	142.6
	Long rural	-	388.9
	Whole Network	-	
Total minutes of excluded events	CBD		
	Urban		
	Short rural		
	Long rural		
	Whole Network	-	
Total sustained minutes off supply after removing excluded events (ie normalised)	CBD	22.5	
	Urban	105.1	
	Short rural	181.9	
	Long rural	277.8	
	Whole Network	-	

Table 37. Unplanned interruptions to supply (USAIFI)

USAIFI	Feeder Category	Target	2024/25
Total sustained interruption to supply	CBD		
	Urban	-	
	Short rural	-	
	Long rural	-	
	Whole Network	-	
Total interruptions to supply of excluded events	CBD	-	
	Urban	-	
	Short rural	-	
	Long rural	-	
	Whole Network	-	
Total sustained interruptions to supply after removing excluded events (ie normalised)	CBD	0.185	
	Urban	1.057	
	Short rural	1.427	
	Long rural	1.526	
	Whole Network		

The below table details the submission to the AER on the STPIS telephone response performance (or Grade of Service) for the regulatory year ending 30 June 2024.

Table 38. SA Power Networks telephone response performance

Faults and Emergency telephone calls	2024/25
Total number of calls (includes automated and Agent)	248,940
Number of calls after removing excluded events	59,399
Number of calls answered by Agent within 30 seconds	54,603
Percentage of calls answered within 30 seconds	91%

9. Information and Communications Technology Systems Investments

Schedule 5.8(m) requires SA Power Networks to provide information on its investments in information technology and communications systems which occurred in the preceding year, and planned investments in information technology and communications systems related to management of network assets in the forward planning period.

Below is a list of key IT projects undertaken in the past year and within the forward planning period.

9.1. 2024/25 Investment focus

9.1.1. Flexible Exports

Flexible Export has been scaled substantially to support the statewide release of the service and customer offer. This has meant that we have more than doubled the number of CER customers connected to the SAPN systems since the previous financial year. We have also uplifted the underlying cyber security capabilities for the whole of system and increased the integration with the core network optimisation and modelling to improve operational network management.

9.1.2. Market Active Solar Trials

Enabled the commencement of trials for managing retailer and DNSP constraints impacting on customers at the same time, leveraging SA Power Network's CER communication channels.

9.1.3. CER Operational Uplift

The CER management capability has been implemented and proved over the last few years based on proofs of concept and trails e.g. Flexible Exports. Going forward we will make these capabilities more scalable, available and secure, and a standard for all CER connections.

9.1.4. Smarter Homes Automation

Currently responding to load management events is a manual process requiring phone calls to turn off inverters. This is not a practical nor scalable solution as the number of systems that are to be managed increases. SAPN commenced the process of automating the load management process using system to system calls.

9.1.5. Cyber Security

Cyber threats continue to evolve and increase in prevalence and sophistication. The energy sector has fallen under increasing attention, evidenced by sophisticated cyberattacks against critical infrastructure in several global jurisdictions.

During the 2024/25 period we continued the program to uplift our cyber security maturity in order to mitigate these risks. This included an increased focus on integration of threat intelligence, automation, increasing the security of cloud services and uplifts in awareness across the organisation. Supporting programs of work that focus on high risk areas of our operational technology environment were also delivered, decreasing likelihood of significant incidents. .

9.1.6. Asset Management Transformation Program

The Asset Management Transformation Program aims to improve our understanding of the value our customers receive from the network and realign our asset management practices to maximise customer value. This includes understanding the basis of risk and performance, making better investment decisions about the assets we replace and better targeting the efforts of our people. This requires an uplift in the capability of our skills, systems, data and processes across the business. This Program spans multiple regulatory control periods.

The key investments in 2024/25 related to the Asset Management Transformation Program include:

Network demand forecasting planning

Implementation of new demand forecasting capability, with a focus on the HV network initially, then the Low Voltage network. The system needs to account for demand peaks occurring at various times of the year, and in both forward and reverse directions. This will increase forecasting ability utilising scenario modelling to inform value-based decision making resulting in more efficient and effective network investment.

In 2024-25 we implemented a new HV forecasting solution, which was used to support the RIO submission.

Improved Portfolio Management

Extension of the capability of our portfolio management systems to better plan the network capital program – leading to efficiency in delivery of work.

In 2024-25 we established portfolio management framework and developed an initial portfolio optimisation capability.

Extend Risk Cost Modelling

Extension of our Risk Cost Modelling for use in network upgrades/augmentation in relation to reliability and bushfire risk management, which currently rely on manual processes. This enables more efficient risk analysis building on work undertaken to improve our asset replacement planning.

In 2024-25 we evolved the risk cost model to monetise risk by asset.

Fault Visualisation Tool

Established new graphical solution to show network fault locations and causes that allows trend analysis and informs investment decisions and work planning.

Improved Digital Engineering

Improving our engineering design systems and processes, reducing the effort associated with design and streamlining update to our operational systems.

In 2024-25 we developed a digital engineering strategy and commenced an asset class library.

Next Generation Data Collection

Testing and implementing new technologies to reduce cost of asset data collection (eg. Lidar, thermography, HD Video).

In 2024-25 we developed Lidar standards based on best practice.

Digital work delivery

Leveraging technology replacement activities to improve asset data collection and underpin efficient asset decision making and work delivery.

In 2024-25 we commenced consolidation of field crew mobile apps to make it easier for crews to supply reliable, quality data regarding assets and associated activities.

9.1.7. Data Governance and Analytics Uplift Program

The quality and timeliness of both network operational data and asset related data has become more critical to our service operations and underpins the quality of the network and assets decisions being made. SA Power Networks has implemented a program to significantly uplift our data management and governance capabilities and toolsets. This will enable us to ensure we are only collecting the data we need to collect, at the most efficient point for it to be collected and maximise our usage of that data across the organisation and for customer.

In 2024/25 the data governance structures continued to evolve, with AI now being included as a governed capability. We developed an AI strategy and directive. We continued to build governed and shared enterprise data sets, improving decision making using clean and trusted data.

9.1.8. Geographic Information System (GIS) Consolidation

Understanding the location of the network assets and customers connected to them allows us to understand the impacts on our customers from activities on those assets. Geographic Information System underpins the delivery of customer, network and outage management services as well as supporting the management of the real time capacity of the network. Over the past decade, the need for these capabilities has grown dramatically.

In 2024-25 we completed the consolidation of our systems onto a single GIS platform, reducing the risk to our outage management responses and minimising the issues associated with double handling the data and inconsistency errors.

9.1.9. Satellite Communications

We completed a rollout of new satellite communications capability for both day-to-day operations and to improve safety during disasters and incidents.

9.1.10. Connections Portal Remediation

Continued to remediate the Registered Electricians Portal (REX) to improve the cyber security controls related to identity and access management, taking into account the wider Customer Technology planned for the 2025-30 RCP.

9.2. 2026 to 2030 Investment Focus

9.2.1. CER Operational Uplift

The CER management capability has been implemented and proved over the last few years based on proofs of concept and trails e.g. Flexible Exports. Going forward we will make these capabilities more scalable, available and secure, and a standard for all CER connections.

9.2.2. Smarter Homes Automation

SAPN is in the process of automating the load management process using system to system calls. We will also connect the execution of load management signals from the core operational systems to enable minimum demand and localised network constraints to be managed over the coming months. Uplifting Capability and Compliance Testing for Flexible Export Devices

As the management of the operational network becomes more reliant on the quality and security of customer devices there is need to ensure those devices have the correct capabilities and comply with network requirements. We will be uplifting our technical capabilities to support ongoing testing of new device types.

9.2.3. LV Network Visibility

An important part of our long-term CER integration strategy is to improve our visibility of reverse power flows and voltage variation across our network. We will continue to develop our network visibility and modelling program, scaling up to make use of the new 'basic power quality data' dataset that we expect to begin to receive from all smart meters from mid-2026 onwards.

9.2.4. Cyber Security Uplift

This cybersecurity uplift program is designed to safeguard the security and reliability of the network, protect customers and the organisation, reduce cyber risks, enhance IT resilience, and secure digital identities. This critical investment addresses the growing threat landscape and ensures a secure, customer-focused, and interconnected future. In 2026, the program builds on the foundations laid in 2025, with a focus on high-impact initiatives to proactively mitigate risks and strengthen our defences.

9.2.5. Asset Management Transformation Program

Key focus areas for the Asset Management Transformation include:

Network demand forecasting planning

Work will continue into 2026 to complete implementation of the HV solution. The LV forecasting capability will be considered as part of roadmap over the next few years.

Improved Portfolio Management

Enhance the portfolio optimisation capability, with automation and integration into enterprise systems.

Extend Risk Cost Modelling

Continue to enhance the sophistication of the monetised risk model and its use in investment decision making.

Improved Digital Engineering

Develop roadmap and deliver on prioritised initiatives, to achieve strategy. Commence the next iteration of the network digital twin capability (inc. LiDAR capture) to facilitate electricity network management and decision making.

Next Generation Data Collection

Develop a proof of concept with a digital twin solution to understand the value for SA Power Networks.

Digital Work Delivery

Complete the consolidation of the mobile apps.

9.2.6. Data Governance and Analytics Uplift Program (continued)

Continue to grow the number of governed datasets and enable self-service reporting and insights. Commence implementation of strategic AI initiatives to ensure governed and efficient use of AI.

9.2.7. Customer Technology Program

In our Regulatory submission we have proposed a large program of replacements and improvements to our customer systems to enable easy to use, secure and cost-effective customer services during the energy transition. This program will run out past 2030 and significantly improve our customer experience.

10. Planning

10.1. Joint planning undertaken with ElectraNet

Schedule 5.8(h) requires SA Power Networks to provide the results of any joint planning undertaken with a Transmission Network Service Provider in the preceding year, including:

- 7) a summary of the process and methodology used by the Distribution Network Service Provider and relevant Transmission Network Service Providers to undertake joint planning;
- 8) a brief description of any investments that have been planned through this process, including the estimated capital costs of the investment and an estimate of the timing (month and year) of the investment; and
- 9) where additional information on the investments may be obtained.

SA Power Networks and ElectraNet undertake regular joint planning meetings on a bi-monthly basis to review system limitations and future projects that affect both the distribution and transmission networks. These joint planning sessions address the following issues:

- Load Forecasts for connection points;
- Asset replacement projects;
- Capacity driven augmentation projects;
- Voltage management issues;
- Major customer (including generator) connections that may impact both the transmission and distribution networks; and
- Non-network solutions.

Subsequent to these regular planning sessions, SA Power Networks and ElectraNet jointly manage a Connection Point Management Plan which outlines expected projects that affect transmission connection point substations within the forward planning period.

In addition, we have enhanced collaboration through an executive working group with ElectraNet to facilitate alignment across the businesses' respective strategies.

In general, works undertaken by ElectraNet at transmission connection point substations, whether augmentation or asset replacement, will affect SA Power Networks' assets and require expenditure by SA Power Networks. Such works are coordinated between the parties through a common notification process.

Investments that have been planned through this process and are expected to impact on SA Power Networks' expenditure within the forward planning period are summarised in the table below.

Table 39. Major joint investments in forward planning period

Project	Timing	Anticipated Cost (SA Power Networks only)
Mannum 132/33kV TF1 Transformer Replacement	2026	\$0.15 million. SA Power Networks' proposes to install relay interface panels between SA Power Networks and ElectraNet.
Northfield GIS	2026	\$45.5 million. SA Power Networks proposes to replace the existing 66kV GIS to an outdoor air insulated switchgear. Refer to 5.1.1 Preceding year RIT-D projects for more information.

Further details of ElectraNet's planned projects during the forward planning period can be found in their [Transmission Annual Planning Report](#).

Voltage management is a significant issue due to the emergence and rapid uptake of CER within South Australia. Since 2016, in addition to the joint planning meetings, SA Power Networks and ElectraNet have also convened a Voltage Control Working Group looking specifically at managing voltage levels on both networks. This working group typically meets bi-monthly in alternate months to those in which joint planning meetings occur.

We are actively engaged in collaboration with ElectraNet through joint planning activities associated with their Transmission Network Voltage Control Project, which aims to address reactive power and voltage control needs. Complementing this work are joint planning activities specifically focused on understanding and addressing SA Power Networks' obligation to meet Connection Point power factor requirements outlined in the TCA. This collaborative effort and shared priorities ensure that the identified needs are accurately defined, with comprehensive consideration given to a range of transmission and distribution solutions, encompassing both network and non-network options.

Our enduring relationship and continuous Joint Planning activities establish an effective mechanism to collaboratively address voltage control and system security issues in response to the evolving energy needs of our customers.

10.2. Joint planning undertaken with other Distribution Network Service Providers

Schedule 5.8(i) of the NER requires SA Power Networks to provide the results of any joint planning undertaken with other Distribution Network Service Providers in the preceding year.

Given SA Power Networks is the only DNSP in South Australia, it has no requirement to undertake joint planning activities with other DNSPs. Nor has any Victorian DNSP (e.g. Powercor) to which SA Power Networks provides supply (e.g. at Murtho and Nelson), initiated any regular joint planning discussions with SA Power Networks over the preceding 12 months.

Our commitment is to consistently make every effort to collaborate with Powercor in addressing issues that may arise, including changes in demand, power quality, or harmonic concerns, ensuring a timely and efficient resolution.

10.3. Regional development plans

Schedule 5.8(n) of the NER requires SA Power Networks to provide a regional development plan consisting of a map of our network as a whole, or maps by regions, in accordance with our

planning methodology or as required under any regulatory obligation or requirement, identifying:

- 1) sub-transmission lines, zone substations and transmission-distribution connection points; and
- 2) any system limitations that have been forecast to occur in the forward planning period. Including, where they have been identified, overloaded primary distribution feeders.

The system limitations for each region are now available on our network visualisation portal ([Annual network plans - SA Power Networks](#)).

Most of our customers are supplied via primary high voltage distribution feeders (typically at 11kV), which are connected to zone substations. These feeders are extended and upgraded as required to meet customer demand, customer connection requests and to maintain quality of supply. Large customer projects may require a zone substation upgrade as well as feeder or sub-transmission line modifications. Therefore, SA Power Networks should be notified as early as possible during the planning stages of a project so that customer connection requirements can be met.

SA Power Networks regional development plans are found in Appendix D – Regional Overviews.

Glossary

Abbreviation	Definition or description
AAAC	All Aluminium Alloy Composite conductor
AC	Alternating Current
ACSR	Aluminium Conductor Steel Reinforced
ACR	Adelaide Central Region as defined in the ETC
AEMC	Australian Energy Market Commission
AEMO	Australian Energy Market Operator
AER	Australian Energy Regulator
AIS	Air Insulated Switchgear
ARENA	Australian Renewable Energy Agency
BOM	Bureau of Meteorology
CBD	Central Business District
CER	Consumer Energy Resources, (e.g., solar PV systems, batteries).
CRoS	Customer restoration of supply – percentage of total customers who have an interruption exceeding a specific number of hours
CT	Current Transformer
DAPR	Distribution Annual Planning Report
DC	Direct Current
DFR	Dynamic Frequency Response
Distribution Network	Has the meaning defined within Chapter 10 of the NER
Distribution System	Has the meaning defined within Chapter 10 of the NER
DNSP	Distribution Network Service Provider as defined in Chapter 10 of the NER
DOE	Dynamic Operating Envelope
DPAR	Draft Project Assessment Report. A report we prepare and publish in accordance with clauses 5.17.4 (i) – (n) of the NER
EDC	Electricity Distribution Code as published by ESCOSA
ElectraNet	The company which owns and operates the transmission system in South Australia and is registered with AEMO as the transmission network service provider for the South Australian transmission system
Embedded Generation	The generation of electricity by a generating unit connected within a distribution network and not having direct connection to the transmission network
EOI	Expression of Interest
ESCOSA	The Essential Services Commission of South Australia. The jurisdictional service standards regulator of electricity distribution in South Australia
ETC	Electricity Transmission Code as published by ESCOSA
EV	Electric Vehicle
FPAR	Final Project Assessment Report. A report we prepare and publish in accordance with NER clause 5.17.4(o) – (s)
GCI	Ground Component Inspections
GIS	Gas Insulated Switchgear

HEMS	Home Energy Management System
HTLS Conductor	High Temperature Low Sag Conductor
HV	High Voltage. A voltage greater than 1000V
IED	Industry Engagement Document
kV	kilovolt (= 1000 Volts)
LR	Long Rural
LV	Low Voltage. A voltage less than 1000V
MED	Major Event Day. A day on which the cumulative System Average Interruption Duration Index exceeds a designated threshold, for which the reliability impact occurring on that day is excluded from the STPIS results
Meshed Sub-Transmission	A sub-transmission line that has a source of supply available from both ends
MVA	Mega Volt Ampere
N	The capacity of a sub-transmission line, primary distribution feeder or zone substation with all plant and equipment in service. The design life of the sub-transmission line, zone substation and distribution feeder assets (typically 30 years) will be reduced if the peak cyclic load exceeds this value
N-1	The term used to describe the state of the distribution network when any one major item of plant (N-1) is out of service, with the rest of the network remaining intact.
NEL	National Electricity Law
NEM	National Electricity Market
NEO	National Electricity Objective
NER	National Electricity Rules
NSSA	Network Support Service Agreement
OCI	Overhead Component Inspections
OLTC	On-Load Tap Changer on power transformers
OSR	Options Screening Report. This is the term used in the NER to describe a report that outlines broad range of options such as embedded generation, voluntary load curtailment, alternative sources of energy and direct load control that may be used to delay or resolve an identified need. These solutions may be delivered by groups other than SA Power Networks
OTR	Office of the Technical Regulator
PoE	Probability of Exceedance
Primary Distribution Feeder	Means a distribution line connecting a sub-transmission asset to either other distribution lines that are not sub-transmission lines, or to distribution assets that are not sub-transmission assets. The term “feeder” shall be construed accordingly.
PQ	Power Quality
PV	Photo Voltaic
QoS	Quality of Supply
Radial Sub-transmission	Sub-transmission line that has a single source of supply
RCP	Regulatory Control Period
REX	Registered Electricians Portal

RIT-D	Regulatory Investment Test for Distribution
RT	Reporting threshold
SAPS	Stand-Alone Power System
SCADA	Supervisory Control and Data Acquisition. A technology enabling remote control and real-time monitoring of devices connected to the distribution network
SFRA	Sweep Frequency Response Analysis
SOM	Southern Outer Metropolitan
SR	Short Rural
STATCOM	Static Synchronous Compensator. A regulating device used to either source or sink reactive power in the network.
STPIS	Service Target Performance Incentive Scheme.
Sub-transmission Line	For SA Power Networks’ purposes, an overhead conductor or underground cable energised at 33kV or 66kV that supplies a zone substation. The term “line” shall be construed accordingly.
SWE	Severe Weather Event as defined and verified by the BOM
SWER	Single Wire Earth Return. A powerline consisting of a single wire to convey electricity to customers utilising the earth to act as the return current path. SA Power Networks’ SWER systems operate at 19kV and 6.35kV
System Limitation	A limitation identified by a DNSP under clause 5.13.1(d)(2) of the NER
SVC	Static VAr Compensator
TCA	Transmission Connection Agreement
TNSP	Transmission Network Service Provider
Transmission Connection Point	A substation shared with ElectraNet, at which electrical power is injected from the ElectraNet transmission network into SA Power Networks’ distribution network
Transmission Network	Has the meaning defined within Chapter 10 of the NER
UFLS	Under-Frequency Load Shedding
USAIDI	Unplanned System Average Interruption Duration Index
USAIFI	Unplanned System Average Interruption Frequency Index
VT	Voltage Transformer
Zone Substation	A substation for the purpose of connecting a high voltage distribution network to a sub-transmission network

Appendix A – SA Power Networks Contacts

For any queries relating to the information presented in this DAPR please contact the following Network Managers.

Edward Senneck

Connections Development Manager - Major Connections (incl Embedded Generation)

Email Edward.senneck@sapowernetworks.com.au

Sally Silz

Connections Development Manager - South

Email Sally.Silz@sapowernetworks.com.au

Ntuthuko Tshuma

Connections Development Manager - North

Email Ntuthuko.Tshuma@sapowernetworks.com.au

Appendix B – Compliance Statement

NER schedule 5.8	Document reference
(a) information regarding the <i>Distribution Network Service Provider</i> and its <i>network</i> , including:	
(1) a description of its <i>network</i> ;	Section 1
(2) a description of its operating environment;	Section 1 and 2
(3) the number and types of its distribution assets;	Section 1
(4) methodologies used in preparing the <i>Distribution Annual Planning Report</i> , including methodologies used to identify system limitations and any assumptions applied; and	Section 4 and Appendix C
(5) analysis and explanation of any aspects of forecasts and information provided in the <i>Distribution Annual Planning Report</i> that have changed significantly from previous forecasts and information provided in the preceding year;	Section 4
(b) forecasts for the forward planning period, including at least: a description of the forecasting methodology used, sources of input information, and the assumptions provided	Appendix C
(2) <i>load</i> forecasts: <ul style="list-style-type: none"> (i) at the transmission-distribution connection points; (ii) for sub-transmission lines; and (iii) for zone substations, including, where applicable, for each item specified above: (iv) total capacity; (v) firm delivery capacity for summer periods and winter periods; (vi) <i>peak load</i> (summer or winter and an estimate of the number of hours per year that 95% of <i>peak load</i> is expected to be reached); (vii) <i>power factor</i> at time of <i>peak load</i>; (viii) load transfer capacities; and (ix) generation capacity of known <i>embedded generating units</i>; 	Section 4.1.1 Attachments A1 to A4 Network Visualisation Portal
(2A) forecast use of <i>distribution services</i> by <i>embedded generating units</i> : <ul style="list-style-type: none"> (i) at the <i>transmission-distribution connection points</i>; (ii) for <i>sub-transmission lines</i>; and (iii) for <i>zone substations</i>, including, where applicable, for each item specified above: 	Section 4 Attachments A1 to A4

NER schedule 5.8	Document reference
<p>(iv) <i>total capacity</i> to accept <i>supply</i> from <i>embedded generating units</i>; (v) <i>firm delivery capacity</i> for each period during the year; (vi) <i>peak supply</i> into the <i>distribution network</i> from <i>embedded generating units</i> (at any time during the year) and an estimate of the number of hours per year that 95% of the peak is expected to be reached; and (vii) <i>power factor</i> at time of <i>peak supply</i> into the <i>distribution network</i>;</p>	Network Visualisation Portal
<p>(3) forecasts of future transmission-distribution connection points (and any associated <i>connection assets</i>), sub-transmission lines and zone substations, including for each future transmission-distribution connection point and zone substation: (i) location; (ii) future <i>loading level</i>; and (iii) proposed commissioning time (estimate of month and year);</p>	Section 4.1.2 Attachments A1 to A4 Network Visualisation Portal
<p>(4) forecasts for the <i>Distribution Network Service Provider's</i> performance against any reliability targets in a <i>service target performance incentive scheme</i>; and</p>	Section 4.1.3
<p>(5) a description of any factors that may have a material impact on its <i>network</i>, including factors affecting; (i) fault levels; (ii) <i>voltage</i> levels; (iii) other <i>power system security requirements</i>; (iv) the quality of <i>supply</i> to other <i>Network Users</i> (where relevant); and (v) ageing and potentially unreliable assets;</p>	Section 2
<p>(b1) for all <i>network</i> asset retirements, and for all <i>network</i> asset de-ratings that would result in a system limitation, that are planned over the forward planning period, the following information in sufficient detail relative to the size or significance of the asset: (1) a description of the <i>network</i> asset, including location; (2) the reasons, including methodologies and assumptions used by the <i>Distribution Network Service Provider</i>, for deciding that it is necessary or prudent for the <i>network</i> asset to be retired or de-rated, taking into account factors such as the condition of the <i>network</i> asset; (3) the date from which the <i>Distribution Network Service Provider</i> proposes that the <i>network</i> asset will be retired or de-rated; and (4) if the date to retire or de-rate the <i>network</i> asset has changed since the previous <i>Distribution Annual Planning Report</i>, an explanation of why this has occurred;</p>	Section 4.2, 4.3 Attachments B1 to B5
<p>(b2) for the purposes of subparagraph (b1), where two or more <i>network</i> assets are: (1) of the same type; (2) to be retired or de-rated across more than one location; (3) to be retired or de-rated in the same calendar year; and (4) each expected to have a replacement cost less than \$200,000 (as varied by a cost threshold determination), those assets can be reported together by setting out in the <i>Distribution Annual Planning Report</i>: (5) a description of the <i>network</i> assets, including a summarised</p>	Section 4.2, 4.3

NER schedule 5.8	Document reference
<p>description of their locations;</p> <p>(6) the reasons, including methodologies and assumptions used by the <i>Distribution Network Service Provider</i>, for deciding that it is necessary or prudent for the <i>network</i> assets to be retired or de-rated, taking into account factors such as the condition of the <i>network</i> assets;</p> <p>(7) the date from which the <i>Distribution Network Service Provider</i> proposes that the <i>network</i> assets will be retired or de-rated; and</p> <p>(8) if the calendar year to retire or de-rate the <i>network</i> assets has changed since the previous <i>Distribution Annual Planning Report</i>, an explanation of why this has occurred.</p>	
<p>(c) information on system limitations for sub-transmission lines and zone substations, including at least:</p> <p>(1) estimates of the location and timing (month(s) and year) of the system limitation;</p> <p>(2) analysis of any potential for load transfer capacity between <i>supply</i> points that may decrease the impact of the system limitation or defer the requirement for investment;</p> <p>(3) impact of the system limitation, if any, on the capacity at transmission-distribution connection points;</p> <p>(4) a brief discussion of the types of potential solutions that may address the system limitation in the forward planning period, if a solution is required; and</p> <p>(5) where an estimated change in forecast <i>load</i> or forecast <i>generation</i> from <i>embedded generating units</i> would defer a forecast <i>system limitation</i> for a period of at least 12 months, include:</p> <p>(i) an estimate of the month and year in which a <i>system limitation</i> is forecast to occur as required under subparagraph (1);</p> <p>(ii) the relevant <i>connection points</i> at which the estimated change in forecast <i>load</i> or forecast <i>generation</i> may occur; and</p> <p>(iii) the estimated change in forecast <i>load</i> or forecast <i>generation</i> in MW or improvements in <i>power factor</i> needed to defer the forecast <i>system limitation</i>;</p>	<p>Section 4.4 Attachments B1 to B5 Network Visualisation Portal</p>
<p>(d) for any primary distribution feeders for which a <i>Distribution Network Service Provider</i> has prepared forecasts of <i>maximum demands</i> under clause 5.13.1(d)(1)(iii) and which are currently experiencing an overload, or are forecast to experience an overload in the next two years <i>the Distribution Network Service Provider</i> must set out:</p> <p>(1) the location of the primary distribution feeder;</p> <p>(2) the extent to which load exceeds, or is forecast to exceed, 100% (or lower utilisation factor, as appropriate) of the normal cyclic rating under normal conditions (in summer periods or winter periods);</p> <p>(3) the types of potential solutions that may address the overload or forecast overload; and</p> <p>(4) where an estimated reduction in forecast <i>load</i> would defer a forecast overload for a period of 12 months, include:</p> <p>(i) estimate of the month and year in which the overload is forecast to occur;</p>	<p>Section 4.5</p>

NER schedule 5.8	Document reference
<ul style="list-style-type: none"> (ii) a summary of the location of relevant <i>connection points</i> at which the estimated reduction in forecast <i>load</i> would defer the overload; (iii) the estimated reduction in forecast load in MW needed to defer the forecast system limitation; 	
<p>(d1) for any <i>primary distribution feeders</i> for which a <i>Distribution Network Service Provider</i> has prepared forecasts of demand for <i>distribution services</i> by <i>embedded generating units</i> under clause 5.13.1(d1)(3) and which are currently experiencing a <i>system limitation</i>, or are forecast to experience a <i>system limitation</i> in the next two years, the <i>Distribution Network Service Provider</i> must set out:</p> <ul style="list-style-type: none"> (1) the location of the <i>primary distribution feeder</i>; (2) the extent to which demand for <i>distribution services</i> by <i>embedded generating units</i> exceeds, or is forecast to exceed, 100% (or lower utilisation factor, as appropriate) of the normal capacity to provide those <i>distribution services</i> under normal conditions; (3) the types of potential solutions that may address the <i>system limitation</i> or forecast <i>system limitation</i>; (4) where an estimated reduction in demand for <i>distribution services</i> by <i>embedded generating units</i> would defer a forecast <i>system limitation</i> for a period of 12 months, include: <ul style="list-style-type: none"> (i) an estimate of the month and year in which the <i>system limitation</i> is forecast to occur; (ii) a summary of the location of relevant <i>connection points</i> at which the estimated reduction in demand for <i>distribution services</i> by <i>embedded generating units</i> would defer the <i>system limitation</i>; and (iii) the estimated reduction in demand for <i>distribution services</i> by <i>embedded generating units</i> in MW needed to defer the forecast <i>system limitation</i>; 	Section 4.6
<p>(d2) for a <i>SAPS enabled network</i>, information on <i>system limitations</i> in the <i>forward planning period</i> for which a potential solution is a <i>regulated SAPS</i>, including at least:</p> <ul style="list-style-type: none"> (1) estimates of the location and timing (month(s) and year) of the <i>system limitation</i>; and (2) a brief discussion of the types of potential <i>stand-alone power systems</i> that may address the <i>system limitation</i>; 	Section 4.7
<p>(e) a high level summary of each RIT-D project for which the <i>regulatory investment test for distribution</i> has been completed in the preceding year or is in progress; including:</p> <ul style="list-style-type: none"> (1) if the <i>regulatory investment test for distribution</i> is in progress, the current stage in the process; (2) a brief description of the <i>identified need</i>; (3) a list of the credible options assessed or being assessed (to the extent reasonably practicable); (4) if the <i>regulatory investment test for distribution</i> has been completed a brief description of the conclusion, including: <ul style="list-style-type: none"> (i) the net economic benefit of each credible option; (ii) the estimated capital cost of the preferred option; and (iii) the estimated construction timetable and commissioning date (where relevant) of the preferred option; and 	Section 5.1.1 and 5.1.2

NER schedule 5.8	Document reference
(5) any impacts on <i>Network Users</i> , including any potential material impacts on <i>connection charges</i> and <i>distribution use of system charges</i> that have been estimated;	
(f) for each identified system limitation which a <i>Distribution Network Service Provider</i> has determined will require a <i>regulatory investment test for distribution</i> , provide an estimate of the month and year when the test is expected to commence;	Section 5.1.3
(g) a summary of all committed investments to be carried out within the forward planning period with an estimated capital cost of \$2 million or more (as varied by the cost threshold determination) that are to address an urgent and unforeseen network issue in clause 5.17.3.(a)(1), including:	Section 5.2
<ul style="list-style-type: none"> (1) a brief description of the investment, including its purpose, its location, the estimated capital cost of the investment and an estimate of the date (month and year) the investment is expected to become operational; (2) a brief description of the alternative options considered by the <i>Distribution Network Service Provider</i> in deciding on the preferred investment, including an explanation of the ranking of these options to the committed project. Alternative options could include, but are not limited to, <i>generation</i> options, demand side options, and options involving other <i>distribution or transmission networks</i>. 	
(h) the results of any joint planning undertaken with a <i>Transmission Network Service Provider</i> in the preceding year, including:	Section 10.1
<ul style="list-style-type: none"> (1) a summary of the process and methodology used by the <i>Distribution Network Service Provider</i> and relevant <i>Transmission Network Service Providers</i> to undertake joint planning; (2) a brief description of any investments that have been planned through this process, including the estimated capital costs of the investment and an estimate of the timing (month and year) of the investment; and (3) where additional information on the investments may be obtained; 	
(i) the results of any joint planning undertaken with other <i>Distribution Network Service Providers</i> in the preceding year, including:	Section 10.2
<ul style="list-style-type: none"> (1) a summary of the process and methodology used by the <i>Distribution Network Service Providers</i> to undertake joint planning; (2) a brief description of any investments that have been planned through this process, including the estimated capital costs of the investment and an estimate of the timing (month and year) of the investment; and (3) where additional information on the investments may be obtained; 	
(j) information on the performance of the <i>Distribution Network Service Provider's Network</i> , including:	Section 8
<ul style="list-style-type: none"> (1) a summary description of reliability measures and standards in <i>applicable regulatory instruments</i>; (2) a summary description of the quality of <i>supply</i> standards that apply, including the relevant codes, standards and guidelines; (3) a summary description of the performance of the <i>distribution network</i> against the measures and standards described under subparagraphs (1) and (2) for the preceding year; 	

NER schedule 5.8	Document reference
<p>(4) where the measures and standards described under subparagraphs (1) and (2) were not met in the preceding year, information on the corrective action taken or planned;</p> <p>(5) a summary description of the <i>Distribution Network Service Provider's</i> processes to ensure compliance with the measures and standards described under subparagraphs (1) and (2); and</p> <p>(6) an outline of the information contained in the <i>Distribution Network Service Provider's</i> most recent submission to the AER under the service target performance incentive scheme;</p>	
<p>(k) information on the <i>Distribution Network Service Provider's</i> asset management approach, including:</p> <p>(1) a summary of any asset management strategy employed by the <i>Distribution Network Service Provider</i>;</p> <p>(1A) an explanation of how the <i>Distribution Network Service Provider</i> takes into account the cost of <i>distribution losses</i> when developing and implementing its asset management and investment strategy;</p> <p>(2) a summary of any issues that may impact on the system limitations identified in the <i>Distribution Annual Planning Report</i> that has been identified through carrying out asset management; and</p> <p>(3) information about where further information on the asset management strategy and methodology adopted by the <i>Distribution Network Service Provider</i> may be obtained;</p>	Section 7
<p>(l) information on the <i>Distribution Network Service Provider's</i> demand management activities and activities relating to <i>embedded generating units</i>, including:</p> <p>(1) a qualitative summary of:</p> <p>(i) <i>non-network options</i> that have been considered in the past year, including <i>generation from embedded generating units</i>;</p> <p>(ii) key issues arising from <i>applications to connect embedded generating units</i> received in the past year;</p> <p>(iii) actions taken to promote <i>non-network</i> proposals or (for a <i>SAPS enabled network</i>) <i>SAPS</i> proposals in the preceding year, including <i>generation from embedded generating units</i>; and</p> <p>(iv) the <i>Distribution Network Service Provider's</i> plans for demand management and generation from <i>embedded generating units</i> over the forward planning period;</p> <p>(2) a quantitative summary of:</p> <p>(i) <i>connection</i> enquiries received under clause 5.3A.5 and of the total, the number for <i>non-registered embedded generators</i>;</p> <p>(ii) <i>applications to connect</i> received under clause 5.3A.9 and of the total, the number for <i>non-registered embedded generators</i>; and</p> <p>(iii) the average time taken to complete <i>applications to connect</i>;</p> <p>(3) a quantitative summary of:</p> <p>(i) <i>enquiries</i> under clause 5A.D.2 in relation to the <i>connection of micro embedded generators or non-registered embedded generators</i>; and</p> <p>(ii) <i>applications for a connection service</i> under clause 5A.D.3 in relation to the <i>connection of micro embedded generators or non-registered embedded generators</i>;</p>	Section 6

NER schedule 5.8	Document reference
(m) information on the <i>Distribution Network Service Provider's</i> investments in information technology and communication systems which occurred in the preceding year, and planned investments in information technology and communication systems related to management of <i>network assets</i> in the forward planning period; and	Section 9
(n) a regional development plan consisting of a map of the <i>Distribution Network Service Provider's</i> network as a whole, or maps by regions, in accordance with the <i>Distribution Network Service Provider's</i> planning methodology or as required under any <i>regulatory obligation or requirement</i> , identifying: <ul style="list-style-type: none"> <li data-bbox="261 663 1142 723">(1) sub-transmission lines, zone substations and transmission-distribution connections points; and <li data-bbox="261 730 1142 831">(2) any system limitations that have been forecast to occur in the forward planning period, including, where they have been identified, overloaded primary distribution feeders. 	Appendix D – Regional Overviews and Network Visualisation Portal
(o) the analysis of the known and potential interactions between: <ul style="list-style-type: none"> <li data-bbox="261 896 1121 956">(1) any <i>emergency frequency control schemes</i>, or emergency controls in place under clause S5.1.8, on its <i>network</i>; and <li data-bbox="261 963 1161 1064">(2) <i>protection systems or control systems of plant connected to its network</i> (including consideration of whether the settings of those systems are fit for purpose for the future operation of its <i>network</i>), <p data-bbox="261 1111 1142 1173">undertaken under clause 5.13.1(d)(6), including a description of proposed actions to be undertaken to address any adverse interactions; and</p>	Section 5.3
(p) for a <i>SAPS enabled network</i> , information on the <i>Distribution Network Service Provider's</i> activities in relation to <i>DNISP-led SAPS projects</i> including: <ul style="list-style-type: none"> <li data-bbox="261 1267 1070 1328">(1) opportunities to develop <i>DNISP-led SAPS projects</i> that have been considered in the past year; <li data-bbox="261 1335 1126 1395">(2) committed projects to implement a <i>regulated SAPS</i> over the <i>forward planning period</i>; and <li data-bbox="261 1402 1126 1547">(3) a quantitative summary of: <ul style="list-style-type: none"> <li data-bbox="357 1449 1054 1476">(i) the total number of <i>regulated SAPS</i> in the <i>network</i>; and <li data-bbox="357 1482 1126 1547">(ii) the total number of premises of <i>retail customers</i> supplied by means of those <i>regulated SAPS</i>; and 	Section 6.8
(q) the <i>system strength locational factor</i> for each <i>system strength connection point</i> for which it is the <i>Network Service Provider</i> and the corresponding <i>system strength node</i> .	

Appendix C – Forecasting Methodology

Schedule 5.8(b)(1) of the NER requires SA Power Networks to provide a description of the forecasting methodology it has used, sources of input information, and the assumptions applied in delivering the demand forecasts published within this document.

SA Power Networks has spent a large portion of 2025 migrating to a new demand forecasting tool, Vision by Blunomy. Due to the time and resources required to prepare data, migrate existing data, validate demand forecasting tool outputs and embed the Vision tool into planning and forecasting processes, SA Power Networks made the decision not to prepare a complete set of forecasts in 2025. The core demand forecasts used in this 2025 DAPR publication were prepared in 2024 by SA Power Networks, aligned with the growth rates published in AEMO's 2024 ISP. These 2024 demand forecasts have been adjusted manually, where relevant, to reflect the latest major customer block load and transfer information available as of October 2025. SA Power Networks plans on producing and publishing a complete set of demand forecasts in 2026.

Load forecasting methodology

Maximum Demand Forecasts

SA Power Networks reviews its load forecast annually after each summer. These annual reviews consider the impact of the latest load recordings, recent system modifications and any new committed spot load or generation developments, in accordance with SA Power Networks' load forecasting procedure. SA Power Networks does not produce a winter load forecast due to majority of peak loads occurring in summer hot weather (air conditioning) and summer ratings being much less than winter ratings.

In 2018, SA Power Networks purchased a license from AEMO to use its existing connection point forecasting system. The load forecasting tool enables the production of connection point and zone substation forecasts at 10 PoE and 50 PoE levels. The tool performs regression analysis of the temperature sensitive component of the measured demand, to weather-correct recorded load readings with respect to historic temperatures over the preceding 30 years. Prior to performing the regression analysis, the actual load readings are adjusted to account for the impact of historic load transfers, historic spot loads, major customers, PV and embedded generation. This ensures the values regressed represent those underlying or native loads which are temperature sensitive. Upon completion of the regression analysis, post regression adjustments are made to add back previously removed spot loads or major customer load forecasts whilst forecast levels of negative loads such as PV and generation are added to arrive at the final forecast value. The forecasts produced assume that other forms of embedded generation are not operating.

In order to account for econometric factors, the temperature corrected PoE spatial forecasts are reconciled to the next level of the network (i.e. zone substations are reconciled to transmission connection points, transmission connection points are reconciled to the aggregated state / SA Power Networks total level). The forecasting tool also considers the impact of past and future embedded generation (including PV), spot loads, transfers and the behaviour of major customers, when arriving at its final forecast values for the nominated PoE level. The tool also considers the time shift of demand due to PV in arriving at the underlying or native demands which are regressed. Native demand in a region is demand that is met by local scheduled, semi-scheduled, non-scheduled and non-registered generation and by generation imports to the region, excluding the demand of local scheduled loads.

With respect to future spot loads, increases are only considered for inclusion within the relevant asset's forecast (e.g. zone substation or connection point) where the spot load (cumulative) is committed and represents more than 5% of the substation's installed transformer capacity. It is therefore possible that a new load considered as a spot load for the purposes of a zone substation's forecast will not be considered for the upstream connection point, because the spot load is likely to be less than 5% of the installed

transformer capacity at the connection point. Only those loads for committed customer projects or State Government projects with a high likelihood of proceeding are considered for inclusion as spot loads within the moderate forecast. Even then, the customers' forecast load is reduced to 50-90% of the submitted demand to allow for over-estimation by the customer, and load diversity, depending on load type and area knowledge. Similarly, only actual or committed load reductions (e.g. due to measured changes or announced closures) are considered as spot load reductions. For most instances, residential developments are not included as future spot loads as this load type is deemed to be captured within the underlying substation growth rate.

The connection point forecast was reconciled against the future 20-year trend of the categories "Residential Business" + "Electrification" + "Electric Vehicle" forecast under AEMO's SA system "central" demand scenario contained within its 2024 ISP. Connection Points dominated by non-temperature sensitive major customer load (e.g. Snuggery Industrial and Whyalla LMF) were subject to manually set growth rates.

The reconciliation process modifies the transmission connection point forecast, thereby considering the global impact of energy efficiency measures, PV, electric vehicle uptake, fuel substitutions (aka electrification) and any other economic factors as forecast by AEMO, for South Australia (e.g. the reconciliation process uses AEMO's ISP underlying forecast, reduced by the forecast PV and storage growth at each connection point) to produce a reconciled coincident and non-coincident forecast for each connection point substation. The major customers are separately forecast based on their measured demand and their advice of their future plans and historical usage. A number of these customers have modified or are about to modify their demand requirements. Each zone substation forecast trend is then reconciled to the upstream transmission connection point substation's reconciled non-coincident forecast, similarly, modifying the zone substation forecast to include consideration of global factors considered by AEMO within their ISP forecasts. The result is the creation of a reconciled coincident and non-coincident forecast for each zone substation.

Minimum Demand Forecasts

With the increasing penetration of CER in South Australia, SA Power Networks has recognised the importance of producing minimum demand forecasts to enable early identification of any constraints or operating issues resulting from diminishing minimum demand and ultimately increasing reverse / export flows through its network.

As a result, since 2019, SA Power Networks has produced minimum demand forecasts for its transmission connection point and zone substations. In addition, SA Power Networks commenced publication of sub-transmission line forecasts from 2022.

SA Power Networks' methodology for forecasting minimum demands relies on the identification of historic minimum demands for each zone and connection point substation excluding spurious minimum readings due to faults or offloads. These minima typically occur on mild, fine weekend days or public holidays. SA Power Networks reviews measured minimum demands observed during the preceding financial year in deriving its minimum demand forecasts.

The methodology employed sees the underlying demand determined through the addition of a calculated, theoretical CER output and any other form of embedded generation to the measured values. The methodology assumes a 70% diversity factor for small-scale residential and commercial PV systems and that there is no load growth in this underlying demand.

Forecasts of future year's minimum values then rely on the application of CER forecasts. The growth of small residential and commercial systems (i.e. capacity 100kW and below) reconciles to the AEMO ISP forecasts. In 2022, SA Power Networks collaborated with an external provider to implement an improved CER forecasting methodology. The outcomes were to expand the historic growth derivation to the earliest installations, circa early 2000s. Additional demographic parameters are now also considered, including home and vehicle ownership, dwelling arrangements, income, age, education level and the type and proportion of energy

usage (i.e. electricity, gas). Improving the forecasting approach for these smaller systems was the priority as they are the collective majority of CER on the distribution network. The total CER forecast however also includes the larger CER systems – which are forecast differently.

Larger CER systems (i.e. greater than 100kW) are only increased according to committed connection enquiries. No growth is applied to established systems. Reconciliation to the AEMO ESOO published capacities for these systems would not be useful as the forecast figures (up to 30 MW) also represents TNSP connected systems.

The forecast minimum demand for each connection point and substation are produced by subtracting the forecast CER output for each future year from the existing underlying demand. These forecasts are intended to represent the minimum demand expected to occur as at 1 July in the year stated (e.g. the 2024 minimum forecast is the forecast as at 1 July 2024). SA Power Networks is continuing to review its minimum demand forecasting methodology to ensure its ongoing suitability for integrating Energy Storage Systems and EV loads in addition to PV.

Constraint identification

All identified peak demand constraints and their timings described in this report are based on the forecasts produced by the forecast tool under 10 PoE and 50 PoE levels (as applicable). All forecasts consider the historical measured loads, adjusted for any transfers, spot loads, PV, embedded generation or major customers. The historic period selected can vary (e.g. where the asset has existed for less than five years, the forecast will only consider historic demands over this period). Potential changes in customer demand due to the effects of PV installations and demand management programs have also been considered within the forecasts.

Any identified minimum demand constraints and their timings are based on comparison of the minimum demand forecasts with the equipment ratings of the relevant substations in the reverse or exporting direction. Potential voltage driven constraints under minimum demand conditions across the network have not been assessed or identified but may be in the future.

The timing of the various network augmentations proposed within this DAPR are based on the comparison of the relevant forecast with the relevant asset ratings in accordance with SA Power Networks' planning criteria.

In the case of SA Power Networks' sub-transmission lines, these forecasts have been developed through modelling of the zone substation 10 PoE coincident forecasts using system load flow modelling software. The line flows indicated by these models are then used to determine the timing of any constraint. The intent of the modelling is to recreate the scenario which will result in the highest forecast load in the relevant line.

Whilst many of SA Power Networks' country zone substations are radially connected, a large proportion are "daisy chained" from a single transmission connection point with the sub-transmission lines entering the zone substation and subsequently continuing to supply other zone substations in series. For those sub-transmission lines which only supply a single zone substation, the sub-transmission line forecast is based on the zone substation's non-coincident forecast.

The timing of augmentation projects detailed within this DAPR are based on SA Power Networks' load forecasts which have been reconciled against the normal AEMO load forecast as detailed in their 2024 ISP.

Individual forecasts for zone substations consider long term usage, measured growth, local customer 10 PoE behaviour and the impact of embedded generation including PV (both existing and forecast).

The total connection point forecast is a non-coincident summation of demands across the distribution network. The coincident demand for the total distribution network is less than the summation of the non-coincident values due to diversity between connection points (e.g. time of day and customer type), the


impact of embedded generation and large customers. The total State forecast is lower again due to the diversity between transmission and distribution customers, distribution losses and transmission system connected generation.

PV Generation Effects

Since 2009, SA Power Networks has experienced a significant increase in the level of installed solar PV systems, from negligible penetration levels of less than 20 MW in 2009/10 to today's installed capacity of 2,687 MW as at 1 July 2025. This represents more than half of SA Power Networks' peak system demand and has resulted in SA Power Networks having one of the highest PV penetration levels as a proportion of system demand in the nation. As a proportion of SA Power Networks' 919,000 customers, approximately 40% have a PV system installed.

This increase has been driven by several factors including initial significant State Government "feed in tariffs" and the subsequent large reductions in the cost of installing such systems. Figure 10 indicates the level of installed PV inverter capacity within the distribution network as at 1 July for each respective year.

Figure 10. Total installed PV inverter capacity per annum




As a result, the implementation of PV systems has altered the supply - demand balance in all regions over this period to the extent that the impact of PV needs to be accounted for within the spatial demand forecasts.

Since 2009 the increasing level of PV systems have altered the daily demand profile and shifted the peak demand period at a zone substation level from the traditional 17:00 – 18:00 hour period to 19:00 – 20:00 hour. With respect to transmission connection points and state demand, the effect of these PV systems has had a similar impact, with the time of peak demand shifting from 17:00 to 19:00 Central Standard Summer Time.

This time shift in demand has been considered within SA Power Networks' load forecasts.

Figure 11. Example load profile comparison



The energy output of PV systems is inherently variable and is affected by factors such as:


- Shading from trees and nearby structures;
- Panel orientation with respect to the sun (i.e. time of day);
- Ambient temperature (i.e. PV panels exhibit reduced efficiency at higher temperatures);
- Panel to inverter capacity; and
- General cleanliness / efficiency of the system.

As is the case with more traditional forms of embedded generation, in order to account for the impact of PV generation on the network and subsequently its zone substation and connection point forecasts, the forecasting tool used by SA Power Networks attempts to forecast the level of PV generation at each daily half hour interval for each month of the summer in order to correct the measured daily demand to its underlying demand value prior to performing any temperature correction analysis.

The methodology employed by the forecasting tool to estimate the amount of PV output is based on:


- the installed capacity of PV systems at both zone substation and connection point level (as at the first day of each month);
- apportionment of the total annual output of these systems to each half hour and month based on solar insolation data from Renewables SA (refer to Figure 12 for an example of a single month’s curve).

Figure 12. PV Output versus Time of Day in January



The forecasting tool uses the data provided to determine, for each half hour, the estimated/latent impact of PV on the measured demand and the resultant underlying demand. This value is then added back to the measured daily demand prior to performance of any temperature correction regression. Upon completion of the temperature correction, the effect of these PV systems is deducted from the forecast value at the nominated PoE level to arrive at the final, unreconciled forecast. Figure 13 below provides an example of the impact of PV on measured versus native demand.

Figure 13. Example of measured demand compared with underlying (native/latent) demand



AEMO’s ISP forecast growth in PV and storage is used to augment the forecast of underlying demand at each transmission connection point taking into account the time of the critical peak demand and the effectiveness of PV at this time.

Embedded Generation

SA Power Networks' forecasting tool treats non-PV embedded generation as a negative load. Given embedded generation may or may not be operating at any given time, its operation may result in misleadingly low / high demands if considered or not considered within the forecasting process.

The level of embedded generation output for each embedded generator for every half hour over the summer is recorded and added back to the relevant zone and/or connection point substation's measured transformer output to arrive at the underlying/native demand value used within the forecast tool's regression.

Upon completion of the regression analysis and arriving at a temperature corrected demand at the nominated PoE level by the forecast tool, those embedded generators whose operation is consistent (e.g. small biogas generators which operate irrespective of temperature or network demand levels) can then be deducted (outside the tool) from the temperature corrected demand to arrive at the final forecast demand level. Those embedded generators that have historically operated intermittently are assumed to not be operating and are not deducted from the model's forecast.

Spot Loads

SA Power Networks has only included spot load increases arising from committed customer projects and State Government funded or sponsored projects. Similarly, spot load decreases are only considered where they are due to committed load reductions.

Load Transfers

Known historic and forecast temporary and permanent load transfers are accounted for within the connection point and zone substation forecasts. Temporary transfers are applied as corrections to the raw SCADA data, whilst planned, long term transfers are catered for as post-regression adjustments to the weather corrected data.

Major Customers

Major customer loads are excluded / removed from the raw data prior to temperature correction and a forecast of these customer's demand is added to the forecasts as a post regression model adjustment. This is to prevent what are typically temperature insensitive loads from adversely affecting the temperature-sensitive portion of the measured load's regression.

Holiday Peaking Locations

The load forecasting tool considers loads recorded in the summer period between 1 November and 31 March excluding the Christmas holiday period from the Monday immediately prior to Christmas to the first Friday after New Years Day and excluding weekends and public holidays, to minimise the chance of distortion due to abnormal conditions. Although this provides a sound basis for reconciliation with the AEMO ISP for South Australia as the State demand peaks during this period, it does not provide accurate results for locations that peak during the holiday period (e.g. Christmas/New Year's Eve). For such locations, the forecasting tool allows us to include these periods within the data stream available to be considered for regression.

Appendix D – Regional Overviews

Eastern Suburbs Regional Overview

The SA Power Networks Eastern Suburbs region includes the area from Golden Grove in the north to Linden Park in the south and extends westwards to Prospect and North Adelaide and eastwards to the Adelaide Hills. There are two main transmission connection points in the Eastern Suburbs, being Northfield and Magill, with connections to the embedded ACR system (East Terrace and City West connection points) and Dry Creek Power Station. The forecast loads for the Eastern Suburbs system includes the ACR which covers the Adelaide CBD. The CBD system is an integral part of the Eastern Suburbs system.


Electricity is supplied throughout the Eastern Suburbs from zone substations supplied directly from the 66kV sub-transmission network. These substations are operated at 66,000 Volts stepped down to 11,000 Volts and upgraded when load exceeds capacity.

Table 40 lists SA Power Networks' Eastern Suburbs zone substations with SCADA, and Figure 14 shows the extent of the Eastern Suburbs region.

Table 40. Eastern Suburbs SCADA Substations

Source Connection Point	Associated SCADA Substations
Eastern Suburbs Meshed 66kV Network:	Burnside
City West – ACR	Campbelltown
Dry Creek – Central and East	Clearview
East Terrace – ACR	Golden Grove
Magill – Transformers 2 and 3	Harrow
Northfield	Hillcrest
	Holden Hill
	Hope Valley
	Ingle Farm
	Kent Town
	Kilburn South
	Linden Park
	North Adelaide
	Northfield
	Norwood
	Prospect
	Tea Tree Gully
	Woodforde
	Coromandel Place (ACR)
	East Terrace (ACR)
	Whitmore Square (ACR)
	Hindley Street (ACR)

Figure 14. Eastern Suburbs Regional Map



Western Suburbs Regional Overview

SA Power Networks' Western Suburbs region includes the region from the Adelaide metropolitan coast, south to West Beach, extending south-east to Richmond, north-east to Cavan, and north-west to the LeFevre Peninsula. There are four main transmission connection points in the region, being Torrens Island Power Station, LeFevre, New Osborne and Kilburn. The region contains a significant amount of generation sources which greatly influence the operation of the 66kV sub-transmission network, although these are not embedded generators as they are connected to ElectraNet's transmission network.


Electricity is supplied throughout the Western Suburbs via zone substations. These zone substations are operated 66,000 Volts stepped down to either 11,000 Volts or 33,000 Volts.

Table 41 lists SA Power Networks' Western Suburbs zone substations with SCADA and Figure 15 shows the extent of the Western Suburbs region.

Table 41. Western Suburbs SCADA Substations

Source Connection Point	Associated SCADA Substations	
Western Suburbs Meshed 66kV Network: Dry Creek – West Kilburn LeFevre New Osborne Torrens Island	Athol Park	Kilburn
	Blackpool	Kilkenny
	Cavan	Largs North
	Cheltenham 33kV	LeFevre
	Cheltenham 11kV	New Osborne
	Croydon	New Richmond
	Croydon Park	Port Adelaide
	Findon	Port Adelaide North
	Flinders Park	Queenstown
	Fulham Gardens	Thebarton
	Glanville	Woodville 11kV
	Henley South	Woodville 33kV

Figure 15. Western Suburbs Regional Map



Northern Suburbs Regional Overview

SA Power Networks’ Northern Suburbs region includes Elizabeth and extends north to Gawler and south to Parafield Gardens. There are three transmission connection points in the Northern Suburbs, being Para and Parafield Gardens West and Munno Para.


Electricity is supplied throughout the region via zone substations. These substations are operated at 66,000 Volts stepped down to 11,000 Volts.

Table 42 lists SA Power Networks’ Northern Suburbs zone substations with SCADA, and Figure 16 shows the extent of the Northern Suburbs region.

Table 42. Northern Suburbs SCADA Substations

Source Connection Point	Associated SCADA Substations
Northern Suburbs Meshed 66kV Network:	Angle Vale
Para	Direk
Parafield Gardens West	Edinburgh
Munno Para	Elizabeth Downs
	Elizabeth Heights
	Elizabeth South
	Evanston
	Parafield Gardens
	Paralowie
	Penfield
	Salisbury
	Smithfield West
	Virginia
	Two Wells

Figure 16. Northern Suburbs Regional Map



Southern Suburbs Regional Overview

The SA Power Networks Southern Suburbs region includes the region from Glenelg North to the west extending north-east to North Unley, south-west to Aldinga, and south to Willunga, from where it supplies the Fleurieu region. There are four main transmission connection points in the Southern Suburbs: City West, Magill, Morphett Vale East and Happy Valley.


Electricity is supplied throughout the Southern Suburbs via zone substations. These zone substations are predominately operated at 66,000 Volts stepped down to 11,000 Volts. McLaren Vale is supplied at 33kV from Willunga Zone Substation.

Table 43 lists SA Power Networks' Southern Suburbs zone substations with SCADA, and Figure 17 shows the extent of the Southern Suburbs region.

Table 43. Southern Suburbs SCADA Substations

Source Connection Point	Associated SCADA Substations	
Southern Suburbs Meshed 66kV Network: City West – South Happy Valley Magill – Transformer 1 Morphett Vale East	Aldinga	Morphett Vale East
	Ascot Park	Morphettville
	Blackwood	Noarlunga Centre
	Clarence Gardens	North Unley
	Clarendon	Oaklands
	Cudmore Park	Panorama
	Glenelg North	Plympton
	Hackham	Port Noarlunga
	Happy Valley	Port Stanvac
	Keswick	SAW Happy Valley
	Kingswood	Seacombe
	Lower Mitcham	Seaford
	McLaren Flat TF1	Sheidow Park
	McLaren Flat TF2	Tonsley East
		Tonsley Park
		Willunga 33kV
		Willunga 11kV

Figure 17. Southern Suburbs Regional Map



Adelaide Central Region Overview

SA Power Networks’ ACR includes the area east of West Terrace, north of South Terrace, west of East Terrace, and south of the River Torrens and contains the Adelaide CBD.

The ACR is meshed within the Eastern Suburbs sub-transmission network system, supplied via East Terrace and City West transmission connection points, with other sub-transmission lines supplying the ACR from the Magill and Northfield transmission connection points.

Electricity is supplied throughout the ACR via zone substations. These zone substations are operated at 66,000 Volts stepped down to either 11,000 Volts or 33,000 Volts.


Customers are supplied from SA Power Networks’ distribution system via 33kV and 11kV feeders. The ACR feeder system is characterised by cables installed within an extensive duct and manhole system. These feeders are extended and upgraded as required to meet customer demand and customer connection requests. Large customer projects may require a zone substation upgrade as well as feeder modifications, therefore SA Power Networks should be notified as early as possible during the planning stages of a project so that customer connection requirements can be met.

Table 44 lists SA Power Networks’ ACR zone substations with SCADA, and Figure 18 shows the extent of the ACR region.

Table 44. ACR SCADA Substations

Source Connection Point	Associated SCADA Substations
ACR Meshed 66kV Network:	Coromandel Place
City West – ACR	East Terrace 11kV
East Terrace	East Terrace 33kV
	Hindley Street 11kV
	Hindley Street 33kV
	Whitmore Square

Figure 18. ACR Regional Map



Barossa Regional Overview

SA Power Networks’ Barossa region includes the Barossa Valley extending north to Stockwell, south to Williamstown and west to Dorrien and Lyndoch. There is one transmission connection point in the Barossa: Dorrien 132/33kV Substation.

Electricity is supplied to the various towns and localities throughout the Barossa Region via zone substations. These zone substations are operated at 33,000 Volts stepped down to 11,000 or 7,600 Volts.


Customers are supplied from SA Power Networks’ distribution system via 7.6kV and 11kV primary distribution feeders, which are connected to zone substations. These feeders are extended and upgraded as required to meet customer demand and customer connection requests. In addition, some customers are supplied from 19kV SWER systems. Large customer projects may require a zone substation upgrade as well as feeder modifications, therefore SA Power Networks should be notified as early as possible during the planning stages of a project so that customer connection requirements can be met.

Table 45 lists SA Power Networks’ Barossa zone substations with SCADA, and Figure 19 shows the extent of the Barossa region.

Table 45. Barossa SCADA Substations

Source Connection Point	Associated SCADA Substations
Dorrien	Angaston Barossa South TF1 Barossa South TF2 Dorrien TF4 Dorrien TF5 Gomersal North Lyndoch Lyndoch South Nuriootpa Sandy Creek Stockwell TF1 Stockwell TF2 Williamstown Williamstown South

Figure 19. Barossa Regional Map



Eastern Hills Regional Overview

SA Power Networks' Eastern Hills region includes the region from Milang extending north to Williamstown, west to Crafers, and east to Nairne. There are three main transmission connection points in the Eastern Hills, being the meshed Mount Barker / Mount Barker South, Angas Creek, and a minor transmission connection point at Kanmantoo Copper Mine.

Electricity is supplied to the various towns and localities throughout the Eastern Hills via zone substations. These zone substations are operated at either 66,000 Volts stepped down to 11,000 Volts or 33,000 Volts stepped down to 11,000 Volts or 7,600 Volts.


Customers are supplied from SA Power Networks' distribution system via 7.6kV and 11kV primary distribution feeders which are connected to zone substations. These feeders are extended and upgraded as required to meet customer demand and customer connection requests. In addition, some customers are supplied from 19kV SWER systems. Large customer projects may require a zone substation upgrade as well as feeder modifications, therefore SA Power Networks should be notified as early as possible during the planning stages of a project so that customer connection requirements can be met.

Table 46 lists SA Power Networks' Eastern Hills zone substations with SCADA, and Figure 20 shows the extent of the Eastern Hills region.

Table 46. Eastern Hills SCADA Substations

Source Connection Point	Associated SCADA Substations	
Angas Creek	Birdwood Chain of Ponds Forreton Hermitage Houghton Kersbrook Lobethal Mount Pleasant	
Mount Barker / Mount Barker South	Aldgate Balhannah 33kV Brukunga Hahndorf Langhorne Creek Meadows Milang Mt Barker 11kV Mylor	Nairne Piccadilly Stirling East Strathalbyn Uraidla 11kV Uraidla 33kV Verdun Woodside
Kanmantoo Copper Mine		

Figure 20. Eastern Hills Regional Map



Eyre Peninsula Regional Overview

SA Power Networks' Eyre Peninsula region includes the region south of Whyalla, and west to Ceduna. Transmission connection points are located at Port Lincoln, Whyalla, Wudinna, and Yadnarie.

Electricity is supplied to the various towns and localities throughout the Eyre Peninsula region via zone substations. These zone substations are operated at either 66,000 Volts stepped down to 11,000 Volts or 33,000 Volts stepped down to 11,000 Volts.


Customers are supplied from SA Power Networks' distribution system via 11kV primary distribution feeders, which are connected to zone substations. These feeders are extended and upgraded as required to meet customer demand and customer connection requests. In addition, some customers are supplied from 19kV SWER systems. Large customer projects may require a zone substation upgrade as well as feeder modifications, therefore SA Power Networks should be notified as early as possible during the planning stages of a project so that customer connection requirements can be met.

Table 47 lists SA Power Networks' Eyre Peninsula zone substations with SCADA, and Figure 21 shows the extent of the Eyre Peninsula region.

Table 47. Eyre Peninsula SCADA Substations

Source Connection Point	Associated SCADA Substation
Port Lincoln Terminal	Coffin Bay Cummins Little Swamp Point Boston Poonindie Port Lincoln City Port Lincoln Docks Port Lincoln Marina Tumby Bay Uley Uley South
Whyalla Central	Whyalla City Whyalla North Whyalla Stuart
Wudinna	Ceduna Moorkitabie Polda Streaky Bay Tarlton Wudinna
Yadnarie	Arno Bay Boothby Caralue Cleve 11kV Cleve 33kV Cowell Darke Peak Lock

Figure 21. Eyre Peninsula Regional Map



Fleurieu Peninsula Regional Overview

SA Power Networks' Fleurieu Peninsula region includes the region south of Willunga extending south-east to Goolwa, south-west to Cape Jervis, and further south-west to Kangaroo Island. The Fleurieu Peninsula is supplied via the Southern Suburbs meshed transmission connection points.

Electricity is supplied to the various towns and localities throughout the Fleurieu Peninsula via zone substations. These zone substations are operated at either 66,000 Volts stepped down to 11,000 Volts or 33,000 Volts stepped down to 11,000 Volts.


Customers are supplied from SA Power Networks' distribution system via 11kV primary distribution feeders, which are connected to zone substations. These feeders are extended and upgraded as required to meet customer demand and customer connection requests. In addition, some customers are supplied from 19kV SWER systems. Large customer projects may require a zone substation upgrade as well as feeder modifications, therefore SA Power Networks should be notified as early as possible during the planning stages of a project so that customer connection requirements can be met.

Table 48 lists SA Power Networks' Fleurieu Peninsula zone substations with SCADA, and Figure 22 shows the extent of the Fleurieu Peninsula region.

Table 48. Fleurieu Peninsula SCADA Substations

Source Connection Point	Associated SCADA Substations
Southern Suburbs Meshed 66kV Network	American River Cape Jervis 33kV Cape Jervis 11kV Goolwa Kingscote MacGillivray Myponga Penneshaw Rapid Bay Second Valley Square Water Hole Victor Harbor Yankalilla 33kV Yankalilla 11kV

Figure 22. Fleurieu Peninsula Regional Map



Mid North and Yorke Peninsula Regional Overview

SA Power Networks' Mid North and Yorke Peninsula region includes the region from Clare extending north to Wilmington, south to Mallala and the Yorke Peninsula. There are several main transmission connection points in the Mid North and Yorke Peninsula, being Dalrymple, Ardrossan West, Clare North, Hummocks, Kadina East, Brinkworth, Waterloo and Templers. A map of this region can be found in Figure 24.

Electricity is supplied to the various towns and localities throughout the Mid North and Yorke Peninsula via zone substations. These zone substations are operated at 33,000 Volts stepped down to 11,000 or 7,600 Volts.

Customers are supplied from SA Power Networks' distribution system via 7.6kV and 11kV primary distribution feeders, which emanate from the zone substations. These feeders are extended and upgraded as required to meet customer demand and customer connection requests. In addition, some customers are supplied from 19kV SWER systems. Large customer projects may require a zone substation upgrade as well as feeder modifications, therefore SA Power Networks should be notified as early as possible during the planning stages of a project so that customer connection requirements can be met.

Table 49 lists SA Power Networks' Mid North and Yorke Peninsula zone substations with SCADA, while Figure 23 shows the extent of the Mid North and Figure 24 shows the extent of the Yorke Peninsula region.

Table 49. Mid North and Yorke Peninsula SCADA Substations

Source Connection Point	Associated SCADA Substations	
Ardrossan West	Ardrossan Maitland Minlaton	Port Julia Port Vincent
Brinkworth	Brinkworth Town Collinsfield Georgetown	Hoyleton Kybunga Spalding
Clare North	Burra TF2	Clare
Dalrymple	Edithburgh Marion Bay Port Giles	Stansbury Warooka Yorke town
Hummocks	Balaklava Paskeville	Port Clinton
Kadina East	Kadina Moonta	Wallaroo
Templers	Freeling Freeling North Gawler Belt TF1 Gawler Belt TF2 Hamley Bridge	Kapunda TF1 Kapunda TF2 Mallala Wasleys
Waterloo	Auburn Eudunda Marrabel	Riverton Robertstown Waterloo Town

Figure 23. Mid North Regional Map





Figure 24. Yorke Peninsula Regional Map



Murraylands Regional Overview

SA Power Networks' Murraylands region includes the region from Punyelroo in the north to Coonalpyn in the south and extends eastwards to Pinnaroo and west to Narrung. There are three main transmission connection points in the Murraylands region, being Mannum, Mobilong and Tailem Bend.

Electricity is supplied to the various towns and localities throughout the Murraylands region directly from the 33kV sub-transmission network or via zone substations. These zone substations are operated at 33,000 Volts stepped down to 11,000 Volts or 7,600 Volts and are upgraded when load exceeds capacity.


Customers are supplied from SA Power Networks' distribution system via 33kV sub-transmission lines and 7.6kV and 11kV primary distribution feeders, which emanate from zone substations. These lines and feeders are extended and upgraded as required to meet customer demand, customer connection requests and to maintain QoS. In addition, some customers are supplied from 19kV SWER systems. Large customer projects may require a zone substation upgrade as well as feeder or 33kV line modifications. Therefore, SA Power Networks should be notified as early as possible during the planning stages of a project so that customer connection requirements can be met.

Table 50 lists SA Power Networks' Murraylands zone substations with SCADA, and Figure 25 shows the extent of the Murraylands region.

Table 50. Murraylands SCADA Substations

Source Connection Point	Associated SCADA Substations	
Mannum	Belvedere Road Caloote Cambrai Mannum Town	Nildottie Punyelroo Teal Flat Walker Flat
Mobilong	Monarto Central Monarto South Murray Bridge North	Murray Bridge South Mypolonga
Tailem Bend	Binnies Campbell Park Coomandook Coonalpyn Geranium Jervois Lameroo Meningie	Narrung Parilla Pinaroo Pinaroo South Tailem Bend Town White Sands Woods Point

Figure 25. Murraylands Regional Map



Riverland Regional Overview

SA Power Networks' Riverland region includes the region from Berri extending north-west to Morgan, south-west to Swan Reach, and north-east to Renmark and Paringa. There are two main transmission connection points in the Riverland, being Berri/Monash and North West Bend.

Electricity is supplied to the various towns and localities throughout the Riverland region via zone substations. These zone substations are operated at either 66,000 Volts stepped down to 11,000 or 33,000 Volts, or 33,000 Volts stepped down to 11,000 Volts.

Customers are supplied from SA Power Networks' distribution system via 33kV and 11kV primary distribution feeders, which are connected to zone substations. These feeders are extended and upgraded as required to meet customer demand and customer connection requests. Large customer projects may require a zone substation upgrade as well as feeder modifications, therefore SA Power Networks should be notified as early as possible during the planning stages of a project so that customer connection requirements can be met.


There is one system limitations forecast for substations under minimum demand conditions in the Riverland region during the next five years, refer to 6.2.1.

Table 51 lists SA Power Networks' Riverland zone substations with SCADA, and Figure 26 shows the extent of the Riverland region.

Table 51. Riverland SCADA Substations

Source Connection Point	Associated SCADA Substations
Berri / Monash	Berri Glossop Loveday Loxton Lyrup Paringa 11kV Paringa 33kV Pyap Remark Woolpunda
North West Bend	Cadell Cordola Morgan Portee Qualco Ramco Roonka Swan Reach 11kV Swan Reach 33kV Waikerie

Figure 26. Riverland Regional Map



South East Regional Overview

SA Power Networks' South East region includes the region from Tintinara in the north to Port MacDonnell in the south and extends westwards to the coast and eastwards to the Victorian border. There are six main transmission connection points in the South East, being Keith, Kincaig, Snuggery, Mount Gambier, Blanche and Penola West. A map of this region can be found at the end of this section.

Electricity is supplied to the various towns and localities throughout the South East region directly from the 33kV sub-transmission network or via zone substations. These zone substations are operated at 33,000 Volts stepped down to 11,000 Volts (7,600 Volts at Robe) and are upgraded when load exceeds capacity.

Customers are supplied from SA Power Networks' distribution system via 33kV lines and 11kV primary distribution feeders and 19kV SWER systems. These lines and feeders are extended and upgraded as required to meet customer demand, customer connection requests and to maintain QoS. Large customer projects may require a zone substation upgrade as well as 11kV feeder or 33kV line modifications.


Therefore, SA Power Networks should be notified as early as possible during the planning stages of a project so that customer connection requirements can be met.

Table 52 lists SA Power Networks' South East zone substations with SCADA, and Figure 27 shows the extent of the South East region.

Table 52. South East SCADA Substations

Source Connection Point	Associated SCADA Substations	
Blanche	Allendale East Glencoe Kongorong Mount Gambier North	Mount Gambier West Mount Schank Tantanoola
Keith	Bordertown Keith 11kV	Kumorna Padthaway
Kincaig	Inverness Kingston SE Lucindale	Naracoorte Naracoorte East
Mount Gambier	Mount Gambier Tarpeena South	
Penola West	Coonawarra Nangwarry Penola	
Snuggery	Beachport Kalangadoo West Millicent	Robe South End

Figure 27. South East Regional Map



Upper North Regional Overview

SA Power Networks' Upper North region includes the Upper North areas incorporating the major towns of Port Augusta and Port Pirie. Transmission connection points are located at Baroota, Davenport West, Leigh Creek South, Mount Gunson, Neuroodla, and the meshed connection points at Bungama and Port Pirie.

Electricity is supplied to the various towns and localities throughout the Upper North Region via zone substations. These zone substations are operated at 33,000 Volts stepped down to 11,000 Volts.

Customers are supplied from SA Power Networks' distribution system via 11kV primary distribution feeders, connected to zone substations or 19kV SWER systems. These feeders are extended and upgraded as required to meet customer demand and customer connection requests. Large customer projects may require a zone substation upgrade as well as feeder modifications, therefore SA Power Networks should be notified as early as possible during the planning stages of a project so that customer connection requirements can be met.

Table 53 lists SA Power Networks' Upper North zone substations with SCADA, and Figure 28 shows the extent of the Upper North region.

Table 53. Upper North SCADA Substations

Source Connection Point	Associated SCADA Substations	
Baroota	Baroota Town Booloroo Centre Bungama-Napperby Melrose Orroroo	Port Germein Telowie Wilmington Wirrabara Forest
Davenport West	Port Augusta Port Augusta West TF1 Port Augusta West TF2	Quorn Stirling North TF1 Stirling North TF2
Leigh Creek South		
Mount Gunson		
Neuroodla	Hawker	
Port Pirie / Bungama	Caltowie Crystal Brook Gladstone Jamestown	Peterborough Port Broughton Port Pirie South Yongala

Figure 28. Upper North Regional Map

